

上海氟络国际贸易有限公司

FLUO SHANGHAI INTERNATIONAL TRADE CO.,LTD.

ROOM 2003,NO 1, JILONG ROAD ,CHINA (SHANGHAI)PILOT FREE TRADE ZONE

Tel: +86-021-58710356

Fax: +86-0579-87645878

CERTIFICATE OF ANALYSIS

Sample name: REFRIGERANT GAS R507A

BATCH NO: 20260331

Sample source: 11.3KG PER CYLINDER

Produce time:MARCH 31,2026

Test standard: AHRI 700-2019

Sampling time:MARCH 31,2026

Density items	Standard demands	Results
Smell	Colourless and no smelling	Colourless and no smelling
Appearance	Colourless and not turbid	Colourless and not turbid
Purity,%	≥99.9	99.99
HFC-143a,%	49.5±1	49.6
HFC-125,%	50.5±1	50.4
Moisture%	≤0.001	0.00082
Evaporation residue%	≤0.005	0.0009
Acidity (as HCl) %	≤0.0001	<0.0001
Fouling gas %	≤1.5	0.26
Chloride (Cl),%	Conformity	Conformity
Product amount:18645.00KGS	Final conclusion: Conformity	
Tester: SHENG LI Checker: ZHEWEI GONG Auditor: SHAOXIONG TANG	上海氟络国际贸易有限公司 Fluo Shanghai International Trade Co.,Ltd. 潘登	