



NOTES:

1. NEW CIRCUIT BREAKER OF REQUIRED SIZE AS MENTIONED ABOVE IN THE DRAWING HAS TO BE INSTALLED IN THE MSB 440V AC SECTION.
2. SPARE BREAKER/SPARE SPACE AVAILABILITY FOR INSTALLING NEW BREAKER ETC. IN THE SWITCHBOARD HAS TO BE CHECKED ONBOARD.
3. MODIFICATION REQUIRED IN THE EXISTING SWITCHBOARD HAS TO BE DONE BY THE RESPECTIVE VENDOR.

[illegible]