


SAP Equip ID:	TBA	Pole Length / Class:	50 / 3	Code:	GO 95	Structure Type:	Angle
PM Order Number	35378297	Species:	DOUGLAS FIR	GO 95 Rule:	At Installation (New)	Pole Strength Factor:	0.25
Estimator LAN ID	B4LB	Setting Depth (ft):	8.0	Construction Grade:	A	Transverse Wind LF:	1.00
Sketch Location	LOC_1	G/L Circumference (in):	38.27	Loading District:	Heavy	Wire Tension LF:	1.00
Joint Pole Number	PG225283XB-1	G/L Fiber Stress (psi):	7,600	Ice Thickness (in):	0.50	Vertical LF:	1.00
Notification	117820328	Allowable Stress (psi):	1,819	Wind Speed (mph):	48.41	Pole Factor of Safety:	4.77
Aux Data 6	Unset	Fiber Stress Ht. Reduc:	No	Wind Pressure (psf):	6.00	Vertical Factor of Safety:	8.89
Latitude:	38.23402	Longitude:	-120.518361	Elevation:	2660.4'	Bending Factor of Safety:	5.48



Pole Capacity Utilization (%)	Height (ft)	Wind Angle (deg)
Crossarm allowance 300 lbs		
Maximum	83.9	40.0
Groundline	49.4	0.0
Vertical	45.0	35.5

Pole Moments (ft-lb)	Load Angle (deg)	Wind Angle (deg)
Crossarm allowance 300 lbs		
Max Cap Util	4,010	205.0
Groundline	12,980	155.7
GL Allowable	26,905	
Overturn	91,000	

Guy System Component Summary				Load From Worst Wind Angle on Pole		Individual Maximum Load With Overload Applied	
Description	Lead Length (ft)	Lead Angle (deg)	Height (ft)	Nominal Capacity (%)	Wind Angle (deg)	Max* Load Capacity (%)	Wind Angle (deg)
Anchor - 20M	20.0	27.0		46.4	181.2	46.5	175.6
EHS 7/16 (Down)			40.0	73.7	181.2	73.7	175.6
EHS 7/32 (Down)			24.0	62.5	181.2	62.5	175.6
Anchor - 20M	20.0	275.0		43.3	181.2	45.3	125.0
EHS 7/16 (Down)			37.0	69.6	181.2	72.5	130.0
EHS 7/32 (Down)			24.0	54.0	181.2	58.1	120.0
System Capacity Summary:				Adequate		Adequate	

Groundline Load Summary - Reporting Angle Mode: Load - Reporting Angle: 155.7°										
	Shear Load* (lbs)	Applied Load (%)	Bending Moment (ft-lb)	Applied Moment (%)	Pole Capacity (%)	Bending Stress (+/- psi)	Vertical Load (lbs)	Vertical Stress (psi)	Total Stress (psi)	Pole Capacity (%)
Powers	3,957	456.5	72,770	560.6	270.5	10,608	723	6	10,614	583.6
Comms	1,506	173.7	16,873	130.0	62.7	2,460	550	5	2,464	135.5
GuyBraces	-4,864	-561.1	-79,725	-614.2	-296.3	-11,622	15,795	136	-11,486	-631.5
GenericEquipments	14	1.6	369	2.9	1.4	54	490	4	58	3.2
Pole	185	21.3	1,779	13.7	6.6	259	1,334	11	271	14.9
Crossarms	15	1.8	273	2.1	1.0	40	108	1	41	2.2
Risers	39	4.5	371	2.9	1.4	54	0	0	54	3.0
Insulators	15	1.7	269	2.1	1.0	39	37	0	39	2.2
Pole Load	867	100.0	12,980	100.0	48.2	1,892	19,038	163	2,055	113.0
Pole Reserve Capacity			13,925		51.8	-73			-237	-13.0

Load Summary by Owner - Reporting Angle Mode: Load - Reporting Angle: 155.7°

	Shear Load* (lbs)	Applied Load (%)	Bending Moment (ft-lb)	Applied Moment (%)	Pole Capacity (%)	Bending Stress (+/- psi)	Vertical Load (lbs)	Vertical Stress (psi)	Total Stress (psi)	Pole Capacity (%)
PG&E	281	32.4	6,625	51.0	24.6	966	14,682	126	1,092	60.0
Comm	401	46.2	4,576	35.3	17.0	667	3,021	26	693	38.1
Pole	185	21.3	1,779	13.7	6.6	259	1,334	11	271	14.9
JOINTLY OWNED	0	0.0	0	0.0	0.0	0	0	0	0	0.0
Totals:	867	100.0	12,980	100.0	48.2	1,892	19,038	163	2,055	113.0

Detailed Load Components:

Power		Owner	Height (ft)	Horiz. Offset (in)	Cable Diameter (in)	Sag at Max Temp (ft)	Cable Weight (lbs/ft)	Lead/Span Length (ft)	Span Angle (deg)	Wire Length (ft)	Tension (lbs)	Tension Moment* (ft-lb)	Offset Moment* (ft-lb)	Wind Moment* (ft-lb)	Moment at GL* (ft-lb)
Primary	2 (7/1) ACSR (SPARATE) HVY	PG&E	41.00	43.70	0.3250	0.48	0.107	205.9	205.7	205.9	1,690	2,857	-4	58	2,910
Primary	2 (7/1) ACSR (SPARATE) HVY	PG&E	41.00	43.72	0.3250	0.49	0.107	206.8	206.7	206.8	1,690	2,795	6	61	2,862
Primary	2 (7/1) ACSR (SPARATE) HVY	PG&E	38.00	43.83	0.3250	1.49	0.107	281.0	94.5	281.0	1,690	2,009	1	201	2,211
Primary	2 (7/1) ACSR (SPARATE) HVY	PG&E	38.00	43.83	0.3250	1.49	0.107	281.4	94.4	281.4	1,690	2,005	-1	201	2,205
											Totals:	9,665	3	521	10,189

Comm		Owner	Height (ft)	Horiz. Offset (in)	Cable Diameter (in)	Sag at Max Temp (ft)	Cable Weight (lbs/ft)	Lead/Span Length (ft)	Span Angle (deg)	Wire Length (ft)	Tension (lbs)	Tension Moment* (ft-lb)	Offset Moment* (ft-lb)	Wind Moment* (ft-lb)	Moment at GL* (ft-lb)
Overlashed Bundle	1.25" Communication Bundle	Comm	24.00	7.20	0.2420	7.29	0.121	281.5	94.5	282.0	1,200	900	4	156	1,060
Telco	CU CABLE	Comm	23.95	7.20	1.0000		0.600	281.5	94.5	282.0			6	60	66
Overlashed Bundle	1.25" Communication Bundle	Comm	24.00	7.20	0.2420	3.78	0.121	206.9	206.5	207.1	1,200	1,171	2	43	1,216
Telco	CU CABLE	Comm	23.95	7.20	1.0000		0.600	206.9	206.5	207.1			4	17	20
											Totals:	2,071	16	275	2,363

Generic Equipment		Owner	Height (ft)	Horiz. Offset (in)	Offset Angle (deg)	Rotate Angle (deg)	Unit Weight (lbs)	Unit Height (in)	Unit Depth (in)	Unit Diameter (in)	Unit Length (in)	Offset Moment* (ft-lb)	Wind Moment* (ft-lb)	Moment at GL* (ft-lb)	
Imported	15 kVA 1PH TX	PG&E	34.50	16.72	93.0	0.0	490.00	--	--	--	--	20	31	52	
												Totals:	20	31	52

Crossarm		Owner	Height (ft)	Horiz. Offset (in)	Offset Angle (deg)	Rotate Angle (deg)	Unit Weight (lbs)	Unit Height (in)	Unit Depth (in)	Unit Length (in)	Offset Moment* (ft-lb)	Wind Moment* (ft-lb)	Moment at GL* (ft-lb)
----------	--	-------	-------------	--------------------	--------------------	--------------------	-------------------	------------------	-----------------	------------------	------------------------	----------------------	-----------------------

Normal	8L Composite Dead-End Arm	PG&E	41.00	-6.03	206.6	206.6	54.00	3.63	4.63	96.00	-1	36	35
Normal	8L Composite Dead-End Arm	PG&E	38.00	-6.20	94.6	94.6	54.00	3.63	4.63	96.00	-1	4	3
Totals:											-2	40	38

Riser	Owner	Height (ft)	Horiz. Offset (in)	Offset Angle (deg)	Rotate Angle (deg)	Unit Weight (lbs)	Unit Height (in)	Unit Depth (in)	Unit Diameter (in)	Unit Length (in)	Offset Moment* (ft-lb)	Wind Moment* (ft-lb)	Moment at GL* (ft-lb)
Riser 4" PG&&E 45.0° H:31.0	PG&E	31.00	6.32	45.0	45.0	31.00	372.00	4.00	4.00	372.00	0	52	52
Totals:											0	52	52

Insulator		Owner	Height (ft)	Horiz. Offset (in)	Offset Angle (deg)	Rotate Angle (deg)	Unit Weight (lbs)	Unit Diameter (in)	Unit Length (in)	Offset Moment* (ft-lb)	Wind Moment* (ft-lb)	Moment at GL* (ft-lb)
Pin	Pin-Poly Light 7.5	PG&E	41.15	-44.00	108.8	0.0	6.00	5.50	7.50	0	4	4
Deadend	Dead-End Insulator	PG&E	41.00	42.00	304.7	-0.6	4.00	3.90	18.75	0	7	7
Deadend	Dead-End Insulator	PG&E	41.00	-42.00	108.4	0.5	4.00	3.90	18.75	0	7	7
Pin	Pin-Poly Light 7.5	PG&E	38.15	44.00	192.7	0.0	6.00	5.50	7.50	0	4	4
Deadend	Dead-End Insulator	PG&E	38.00	42.00	193.0	0.0	4.00	3.90	18.75	0	7	7
Deadend	Dead-End Insulator	PG&E	38.00	-42.00	356.2	0.0	4.00	3.90	18.75	0	7	7
Bolt	Insulator	Comm	24.00	0.00	147.4	147.4	8.99	3.00	8.00	0	1	1
Totals:									0	38	38	

Guy Wire and Brace		Owner	Attach Height (ft)	End Height (ft)	Lead/Span Length (ft)	Wire Diameter (in)	Percent Solid (%)	Lead Angle (deg)	Incline Angle (deg)	Wire Weight (lbs/ft)	Rest Length (ft)	Stretch Length (in)
EHS 7/16	Down	PG&E	40.00	0.00	20.00	0.438	75.00	27.0	63.2	0.399	49.38	1.75
EHS 7/32	Down	Comm	24.00	0.00	20.00	0.219	75.00	27.0	50.0	0.096	35.03	1.09
EHS 7/16	Down	PG&E	37.00	0.00	20.00	0.438	75.00	275.0	61.4	0.399	46.61	1.56
EHS 7/32	Down	Comm	24.00	0.00	20.00	0.219	75.00	275.0	50.0	0.096	35.03	0.95

Guy Wire and Brace (Loads and Reactions)		Elastic Modulus (psi)	Rated Tensile Strength (lbs)	Guy Strength Factor	Allowable Tension (lbs)	Initial Tension (lbs)	Loaded Tension*2 (lbs)	Maximum Tension² (lbs)	Applied Tension³ (lbs)	Vertical Load (lbs)	Shear Load In Guy Dir (lbs)	Shear Load At Report Angle (lbs)	Moment at GL³ (ft-lb)
EHS 7/16	Down	2.30e+7	20,800	0.50	10,400	700	7,668	7,668	7,664	6,841	3,454	-2,159	-84,374
EHS 7/32	Down	2.30e+7	5,400	0.50	2,700	700	1,688	1,688	1,686	1,292	1,083	-677	-15,925
EHS 7/16	Down	2.30e+7	20,800	0.50	10,400	700	7,538	7,538	7,238	6,354	3,465	-1,697	-61,001
EHS 7/32	Down	2.30e+7	5,400	0.50	2,700	700	1,568	1,568	1,458	1,118	937	-459	-10,614
									Totals:	15,605	8,939	-4,991	-171,914

Anchor/Rod Load Summary	Owner	Rod Length AGL (in)	Lead Length (ft)	Lead Angle (deg)	Strength of Assembly (lbs)	Anchor/Rod Strength Factor	Allowable Load (lbs)	Max Load² (lbs)	Load at Pole MCU³ (lbs)	Max Required Capacity² (%)
Anchor - 20M	JOINTLY OWNED	30.00	20.00	27.0	40,000	0.50	20,000	9,294	9,288	46.5
Anchor - 20M	JOINTLY OWNED	30.00	20.00	275.0	40,000	0.50	20,000	9,062	8,653	45.3

Pole Buckling													
Buckling Constant	Buckling Column Height* (ft)	Buckling Section Height (% Buckling Col. Hgt.)	Buckling Section Diameter (in)	Minimum Buckling Diameter at GL (in)	Diameter at Tip (in)	Diameter at GL (in)	Modulus of Elasticity (psi)	Pole Density (pcf)	Ice Density (pcf)	Pole Tip Height (ft)	Buckling Load Capacity at Height (lbs)	Buckling Load Applied at Height (lbs)	Buckling Load Factor of Safety
0.71	35.50	35.06	10.74	10.00	7.32	12.19	2.38e+6	60.00	57.00	42.00	41,935	423.06	2.22

Notes		
Date	Author	Description
10/4/2015	BEN1	Set Height to Minimum of 3.25 ft Below Primary Conductor

v3.5.8

PGE Master Catalog - May-04-2023

PLDBID: 7701105176

50'-3" wood 8' deep.

Load Case: GO 95 Heavy Grade A At Installation (l:0.5in W:6psf)

Analyzed Wind Speed: 48.4 mph

Configured Snow Loading: Heavy w/ 0.5 in. ice

Construction Grade/Type: Grade A At Installation.

Required Pole Safety Factor = 4

Confirm correct number of PG&E Primary, Secondary, Neutral spans on
Construction Drawing include and align with (+/-10'):

Primary: 2-2 (7/1) ACSR (SPARATE) HVY 206 Deg. 206 Ft.

Primary: 2-2 (7/1) ACSR (SPARATE) HVY 94 Deg. 281 Ft.

Confirm correct detailing of equipment on Construction Drawing

(Cutouts are not shown on ConDwg):

15 kVA 1PH TX

Riser 4" PG&E 45.0" H:31.0

Done. No audit item issues detected

Select "OK" to copy contents to Clipboard

OK

Cancel