alert from an edge controller
dedupe: same room + severity within 60 s → drop;
confirmed room → never re-assessed
features: readings, rates, faulty-sensor list,
spread risk (door graph), evacuation route

LLM verdict {is_fire, confidence, reasoning, alert}
Qwen2.5-14B · p50 2.1 s
(unreachable → rule-based fallback)

is_fire and
confidence ≥ 0.7 ?

no

WATCH 60 s
orange card

in between: keep watching

readings after 60 s
(live sensors only) ?

smoke < 2 and CO < 5

yes

smoke ≥ 10 and CO ≥ 20

CONFIRM
release doors on the other floors (once per incident)
evacuation routes · viewer effects · red card

ESCALATE on readings
(same as confirm)

confirmed room:
readings clear for 60 s ?

yes

STAND-DOWN to the edge
floor_clear · relock · remove card

when no room is
confirmed or watched

ALL CLEAR
lock every floor · clear viewer