edge level0 (active, Pi)

edge level1 + level2

fds-server

BuildSim

13:45:52.680 fire/start A109 (control API)
readings every ~1 s; spread to A108, A110, corridor

13:46:07.357 smoke 14.3, CO 37.7 → FIRE
(isolation forest 17.5 ms)

PUT 41 doors closed_unlocked
+14.7 s after ignition, no server involved

13:46:07.358 alert A109
severity = confirmed

13:46:10.326 LLM verdict: is_fire, confidence ≥ 0.7
(2 967 ms, Qwen2.5-14B)

13:46:10.351 doors: release
(+25 ms after the verdict)

PUT 46 + 37 doors closed_unlocked
(server pushes effects, red card, route)

13:46:17 A110, corridor: fire
(neighbours, assessed in parallel)

13:46:37.688 fire/stop A109
smoke and CO decay (CO halves every ~60 s)

readings clear (smoke < 2, CO < 5)
for 60 s per room

13:52:54 … 13:53:59 stand-down per room
last one: floor_clear = true

13:53:59.621 PUT 41 doors closed_locked

13:53:59.171 ALL CLEAR: doors: lock

PUT 46 + 37 doors closed_locked
(server clears effects and cards)