

LOCKED
(closed_locked, normal state)
edge: FIRE on this floor
(same tick, no server)
server: stand-down,
floor_clear = true
(edge: no room critical)
server: doors release
(cross-floor)
server: ALL CLEAR
doors lock
RELEASED — own release
this floor's controller
confirmed a fire here
(own_release = true)
RELEASED — server release
fire on another floor;
server commanded release
(server_release = true)
ALL CLEAR lock
→ ignored while own
fire is confirmed
edge: own fire
confirmed
server: cross-floor
release arrives
stand-down, floor_clear
→ own release cleared,
doors stay open
RELEASED — both
own fire and cross-floor
release active