

Building Inspection Report

Date of Inspection: February 12, 2026

Property: 742 Evergreen Terrace, Unit 3B

Inspector: D. Kowalski, PE | License #IL-2019-04281

1. Structural Assessment

Load-bearing walls on the north and east elevations are in good condition with no visible cracking or deflection. The steel lintel above the garage opening shows surface oxidation but no section loss. Foundation walls are dry with no evidence of water intrusion or efflorescence. Slab-on-grade is level within acceptable tolerances.

2. Electrical Systems

Main panel is a 200A Square D with 30 of 40 spaces occupied. All breakers tested and holding. GFCI protection is present in the kitchen, bathrooms, and exterior outlets. Arc-fault breakers are installed on bedroom circuits per 2020 NEC. Smoke detectors are hardwired with battery backup in all required locations.

4. HVAC

Forced-air gas furnace (Carrier, 80k BTU, 96% AFUE) installed 2022. Central AC condenser (Carrier, 3-ton, SEER 16) appears original to the 2019 build. Ductwork is insulated flex in the attic; no visible damage or disconnections. Filter is clean. Thermostat is a Nest Learning model, responsive.

5. Roof and Exterior

Architectural shingles are in good condition with no missing tabs or exposed underlayment. Flashing at the chimney and vent pipes is sealed. Gutters and downspouts are clear and directing water away from the foundation. Fascia and soffit are intact with no signs of pest intrusion.