Terminal schedule (review only): Synthetic residential

Revision 02; snapshot schema pp-design/2

Design hash (SHA-256): 29de91c8087e9e7713de93026108e53899659f28ff8139600aa3ce0f94d477b6

Rules 2026.10.23.1; renderer 2026.10.31.v2-2

Review content only, derived from the saved model's data. Not an execution document. It does not state or check any rating, cross-section, colour, numbering convention, electrical compatibility or standards requirement, and no template or pattern in it has been reviewed unless its review status says so.

Sources: [user] entered by a user; [data] from the server's design or the configuration's data; [assumption ...] a value its input stated as an assumption, with its statement; [unresolved] the model holds no value.

Board	Owner	Terminal	Kind	Required	Net signal [origin]	Connected to	Template; pattern	Findings
DB-V	NB (component)	1	bar_outlet [data]	required [data]	SYN-N [derived]	NB:2, XD:1	tenant/synth-dist-bar-3way/v1; tenant/synth-pe-n-distribution/v1	template_unreviewed
DB-V	NB (component)	2	bar_outlet [data]	— [unresolved]	SYN-N [derived]	NB:1, XD:2	tenant/synth-dist-bar-3way/v1; tenant/synth-pe-n-distribution/v1	template_unreviewed
DB-V	NB (component)	3	bar_outlet [data]	not required [data]	— [no net]	—	tenant/synth-dist-bar-3way/v1; tenant/synth-pe-n-distribution/v1	template_unreviewed
DB-V	NB (component)	F	bar_feed [data]	— [unresolved]	— [no net]	—	tenant/synth-dist-bar-3way/v1; tenant/synth-pe-n-distribution/v1	template_unreviewed, terminal_requiredness_unresolved
DB-V	PB (component)	1	bar_outlet [data]	required [data]	SYN-PE [derived]	PB:2, XD:1	tenant/synth-dist-bar-3way/v1; tenant/synth-pe-n-distribution/v1	template_unreviewed
DB-V	PB (component)	2	bar_outlet [data]	— [unresolved]	SYN-PE [derived]	PB:1, XD:2	tenant/synth-dist-bar-3way/v1; tenant/synth-pe-n-distribution/v1	template_unreviewed
DB-V	PB (component)	3	bar_outlet [data]	not required [data]	— [no net]	—	tenant/synth-dist-bar-3way/v1; tenant/synth-pe-n-distribution/v1	template_unreviewed
DB-V	PB (component)	F	bar_feed [data]	— [unresolved]	— [no net]	—	tenant/synth-dist-bar-3way/v1; tenant/synth-pe-n-distribution/v1	template_unreviewed, terminal_requiredness_unresolved
DB-V	XD (strip)	1 inner p1 L1	neutral [data]	— [n/a: strip point]	SYN-N [derived]	NB:1, XD:1	tenant/synth-strip-pen-2level/v1; tenant/synth-pe-n-distribution/v1	template_unreviewed
DB-V	XD (strip)	1 outer p1 L1	neutral [data]	— [n/a: strip point]	SYN-N [derived]	XD:1	tenant/synth-strip-pen-2level/v1; tenant/synth-pe-n-distribution/v1	template_unreviewed
DB-V	XD (strip)	1 inner p1 L2	protective_earth [data]	— [n/a: strip point]	SYN-PE [derived]	PB:1, XD:1	tenant/synth-strip-pen-2level/v1; tenant/synth-pe-n-distribution/v1	template_unreviewed
DB-V	XD (strip)	1 outer p1 L2	protective_earth [data]	— [n/a: strip point]	SYN-PE [derived]	XD:1	tenant/synth-strip-pen-2level/v1; tenant/synth-pe-n-distribution/v1	template_unreviewed
DB-V	XD (strip)	2 inner p2 L1	neutral [data]	— [n/a: strip point]	SYN-N [derived]	NB:2, XD:2	tenant/synth-strip-pen-2level/v1; tenant/synth-pe-n-distribution/v1	template_unreviewed
DB-V	XD (strip)	2 outer p2 L1	neutral [data]	— [n/a: strip point]	SYN-N [derived]	XD:2	tenant/synth-strip-pen-2level/v1; tenant/synth-pe-n-distribution/v1	template_unreviewed

Board	Owner	Terminal	Kind	Required	Net signal [origin]	Connected to	Template; pattern	Findings
DB-V	XD (strip)	2 inner p2 L2	protective_earth [data]	— [n/a: strip point]	SYN-PE [derived]	PB:2, XD:2	tenant/synth-strip-pen-2level/v1; tenant/synth-pe-n-distribution/v1	template_unreviewed
DB-V	XD (strip)	2 outer p2 L2	protective_earth [data]	— [n/a: strip point]	SYN-PE [derived]	XD:2	tenant/synth-strip-pen-2level/v1; tenant/synth-pe-n-distribution/v1	template_unreviewed

Structural findings (22: 0 blocking, 22 warning, 11 unresolved)

Severity	Code	Message	Location	Approval	Execution	Confirm
WARNING	pattern_unreviewed	uses pattern tenant/synth-pe-n-distribution/v1, which no qualified engineer has reviewed; it may not be executed	pattern=tenant/synth-pe-n-distribution/v1	does not block approval	execution blocker	yes
WARNING	template_unreviewed	uses template global/legacy-circuit_breaker/v1, which no qualified engineer has reviewed; it may not be executed	board_id=DB-V, component=c-07d6411568ee4b612a326df6, template=global/legacy-circuit_breaker/v1	does not block approval	execution blocker	yes
WARNING	template_unreviewed	uses template global/legacy-circuit_breaker/v1, which no qualified engineer has reviewed; it may not be executed	board_id=DB-V, component=c-203120c3e5bd0656d613e610, template=global/legacy-circuit_breaker/v1	does not block approval	execution blocker	yes
WARNING	template_unreviewed	uses template global/legacy-circuit_breaker/v1, which no qualified engineer has reviewed; it may not be executed	board_id=DB-V, component=c-239faad7d6415ded37662083, template=global/legacy-circuit_breaker/v1	does not block approval	execution blocker	yes
WARNING	template_unreviewed	uses template global/legacy-residual_current_device/v1, which no qualified engineer has reviewed; it may not be executed	board_id=DB-V, component=c-5a4a38dc96615cfd83e69733, template=global/legacy-residual_current_device/v1	does not block approval	execution blocker	yes
WARNING	template_unreviewed	uses template global/legacy-circuit_breaker/v1, which no qualified engineer has reviewed; it may not be executed	board_id=DB-V, component=c-7c7886a4354432f7bbd84b74, template=global/legacy-circuit_breaker/v1	does not block approval	execution blocker	yes
WARNING	template_unreviewed	uses template global/legacy-circuit_breaker/v1, which no qualified engineer has reviewed; it may not be executed	board_id=DB-V, component=c-934a49521f447ba9e46e5ec9, template=global/legacy-circuit_breaker/v1	does not block approval	execution blocker	yes
WARNING	template_unreviewed	uses template tenant/synth-dist-bar-3way/v1, which no qualified engineer has reviewed; it may not be executed	board_id=DB-V, component=k-7747a191058bb950aee299ef, template=tenant/synth-dist-bar-3way/v1	does not block approval	execution blocker	yes
WARNING	template_unreviewed	uses template tenant/synth-dist-bar-3way/v1, which no qualified engineer has reviewed; it may not be executed	board_id=DB-V, component=k-8788af5120e774e426b7c36a, template=tenant/synth-dist-bar-3way/v1	does not block approval	execution blocker	yes
WARNING	template_unreviewed	uses template tenant/synth-strip-pen-2level/v1, which no qualified engineer has reviewed; it may not be executed	board_id=DB-V, strip=s-0a7e22f9e492b54ae52aed03, template=tenant/synth-strip-pen-2level/v1	does not block approval	execution blocker	yes
WARNING / UNRESOLVED	terminal_requiredness_unresolved	terminal F of component k-7747a191058bb950aee299ef is in no net and its template does not say whether it must be connected; unresolved	board_id=DB-V, component=k-7747a191058bb950aee299ef, terminal=feed	does not block approval	—	yes

Severity	Code	Message	Location	Approval	Execution	Confirm
WARNING / UNRESOLVED	terminal_requiredness_unresolved	terminal F of component k-8788af5120e774e426b7c36a is in no net and its template does not say whether it must be connected; unresolved	board_id=DB-V, component=k-8788af5120e774e426b7c36a, terminal=feed	does not block approval	—	yes
WARNING	wire_attribute_assumed	wire w-7a62bb919bb2da2ffd501f41's colour is an assumption (a-75adfff7a8a9439e00df4ad6); confirm it	assumption=a-75adfff7a8a9439e00df4ad6, attribute=colour, board_id=DB-V, wire=w-7a62bb919bb2da2ffd501f41	does not block approval	—	yes
WARNING / UNRESOLVED	wire_attribute_unset	wire w-98ec805f97a0d5d6d6e9b8e1 has no colour; no rule sets it yet	attribute=colour, board_id=DB-V, wire=w-98ec805f97a0d5d6d6e9b8e1	does not block approval	—	yes
WARNING / UNRESOLVED	wire_attribute_unset	wire w-b37b5548f57074883c15036f has no colour; no rule sets it yet	attribute=colour, board_id=DB-V, wire=w-b37b5548f57074883c15036f	does not block approval	—	yes
WARNING / UNRESOLVED	wire_attribute_unset	wire w-b5f4095c51b3ff391915bdfe has no colour; no rule sets it yet	attribute=colour, board_id=DB-V, wire=w-b5f4095c51b3ff391915bdfe	does not block approval	—	yes
WARNING / UNRESOLVED	wire_attribute_unset	wire w-7a62bb919bb2da2ffd501f41 has no cross_section_mm2; no rule sets it yet	attribute=cross_section_mm2, board_id=DB-V, wire=w-7a62bb919bb2da2ffd501f41	does not block approval	—	yes
WARNING / UNRESOLVED	wire_attribute_unset	wire w-98ec805f97a0d5d6d6e9b8e1 has no cross_section_mm2; no rule sets it yet	attribute=cross_section_mm2, board_id=DB-V, wire=w-98ec805f97a0d5d6d6e9b8e1	does not block approval	—	yes
WARNING / UNRESOLVED	wire_attribute_unset	wire w-b37b5548f57074883c15036f has no cross_section_mm2; no rule sets it yet	attribute=cross_section_mm2, board_id=DB-V, wire=w-b37b5548f57074883c15036f	does not block approval	—	yes
WARNING / UNRESOLVED	wire_attribute_unset	wire w-b5f4095c51b3ff391915bdfe has no cross_section_mm2; no rule sets it yet	attribute=cross_section_mm2, board_id=DB-V, wire=w-b5f4095c51b3ff391915bdfe	does not block approval	—	yes
WARNING / UNRESOLVED	wire_attribute_unset	wire w-7a62bb919bb2da2ffd501f41 has no number; no rule sets it yet	attribute=number, board_id=DB-V, wire=w-7a62bb919bb2da2ffd501f41	does not block approval	—	yes
WARNING / UNRESOLVED	wire_attribute_unset	wire w-b5f4095c51b3ff391915bdfe has no number; no rule sets it yet	attribute=number, board_id=DB-V, wire=w-b5f4095c51b3ff391915bdfe	does not block approval	—	yes

Findings (0 blocking, 4 warning, 6 info)

[WARNING] DB-V: Loads without a power factor were taken at cos phi 0.9. (default_power_factor; source: policy; engineering confirmation required)

[WARNING] DB-V: 1 circuit(s) have no cable length given; their voltage drop is not checked. (voltage_drop_unchecked; source: policy; engineering confirmation required)

[WARNING] DB-V: Each cable's withstand k²S² is in the cable list; compare it with the selected breaker's let-through I²t at 6 kA from its maker's curve (ABB handbook §2.4). (short_circuit_withstand; source: policy; engineering confirmation required)

[WARNING] DB-V: Circuit rules are this software's defaults, not confirmed by the company's engineers. (rules_unconfirmed; source: policy; engineering confirmation required)

[INFO] DB-V: Incomer raised to 63 A, 1.6 x the 32 A breaker after it, for discrimination. (discrimination_incomer_raised; source: policy)

[INFO] DB-V: Breakers are rated for at least 6 kA breaking capacity against 6 kA prospective at the board; each RCCB's conditional short-circuit current with the breaker ahead of it must reach it too. (breaking_capacity;

source: policy)

[INFO] DB-V: Leave 1 spare outgoing ways (20 %). (spare_ways; source: policy)

[INFO] DB-V: Each breaker is rated at least 1.6 x the largest breaker after it, so they discriminate on overload. On short circuit, miniature breakers discriminate only up to the upstream breaker's instantaneous trip

(about 5 x In for curve C); where total selectivity is required, confirm it from the manufacturer's selectivity tables. (discrimination; source: policy)

[INFO] DB-V: Cables sized for method B1, 30 °C, 1 grouped circuit(s), 70 °C insulation. (cable_conditions; source: policy)

[INFO] DB-V: Enclosure: ABB Mini Center compact GDMS332 RX (2CVA250001P0001), 2 rows of 16 modules, H x W x D 498 x 400 x 117 mm, IP41, busbar 200/250 A, 35 kA; 24 modules are left for spare ways (ABB Distribution Boards

catalogue (1SKC802027C0201), Mini Center compact, pp. 5, 7). The outgoing terminal strip is not counted. (enclosure_selected; source: policy)