

Fire Extinguisher Inspection

Location	
Date	
Performed By	

Monthly inspection shall include a check of at least the following: Report any faults				
1	Is the fire extinguisher unobstructed and accessible?	Y	N	
2	Is it hung on a bracket?	Y	N	
3	Is it positioned at a height no higher than four feet?	Y	N	
4	Are the operating instructions on nameplate legible?	Y	N	
5	Is the nozzle (hose) intact?	Y	N	
6	Is the nozzle (hose) free and clear of debris?	Y	N	
7	Is the pin intact?	Y	N	
8	Is the anti-tamper (plastic) seal intact?	Y	N	
9	Does the gauge show in the green - fully charged?	Y	N	
10	Is the Service company tag attached, signed and dated (annual)?	Y	N	

Signature	
-----------	--

Comments	
----------	--