

To appear in the *Journal of Building Performance Simulation*
Vol. 00, No. 00, Month 20XX, 1–17

Research Article

Urban and building multiscale co-simulation: case study implementations on two university campuses

Clayton Miller^{a*}, Daren Thomas^a, Jérôme Kämpf^b, and Arno Schlueter^a

^a*Architecture and Building Systems (A/S), Institute of Technology in Architecture (ITA), ETH Zürich, Zürich, Switzerland;*

^b*Solar Energy and Building Physics Laboratory (LESO-PB), Ecole Polytechnique Fédérale de Lausanne (EPFL), Lausanne, Switzerland*

(Submission for review on April 30, 2016)

This paper describes the co-simulation process of the building and urban scale models of two campuses of higher education buildings in Switzerland. The campuses are modeled at both the building level, using the EnergyPlus simulation engine, and at the urban scale using the CitySim engine. A co-simulation framework is used to execute simulations from both engines concurrently with an exchange of information to leverage the various strengths of each. In the first case study, on-site weather and measured performance data are then compared to the output from two modeling scenarios: building-scale simulation using EnergyPlus and co-simulation of the engines. A partial calibration process is implemented to reconcile the simulations with the measured data of a targeted office building on campus. In the second case study, the co-simulation results are compared to the both the CitySim simulation and EnergyPlus engines. The results show that coupling of EnergyPlus with CitySim resulted in a -20% and -7.5% impact on cooling consumption and a +2.8% and +4.8% impact on heating consumption. Challenges encountered with the urban scale calibration and the strengths and weaknesses of the developed process are discussed.

Keywords: Building-scale simulation, Calibrated energy models, CitySim, Co-simulation, EnergyPlus, Urban-scale simulation

1. Introduction

123

Urban scale building performance simulation is a process that empowers the analysis and optimization of cities. Urban populations are growing around the world at an unprecedented rate. A transition from urban to rural is underway and 2.5 billion people are expected to join cities throughout the world (United Nations 2014). Expansions of entire districts and even cities is not an uncommon phenomenon, especially in East Asia and Africa. Urban scale modeling is in the midst of an intense focus on the research community with six key areas of practice: technology design, building design, urban climate, systems design, policy assessment, and land use and transportation (Keirstead, Jennings, and Sivakumar 2012). The ability to simulate the interaction between large collections of buildings enables the development and testing of optimization and planning scenarios for this new development (Dorer et al. 2013).

The CitySim simulation engine is an example of such a program designed and optimized for urban-scale simulation. CitySim is an urban performance simulation engine that comprises a Solver

*Corresponding author. Email: miller.clayton@arch.ethz.ch

¹Clayton's notes are red!

²Jerome's notes are blue!

³Daren's notes are green!

module as well as a graphical user interface. It focuses on the energy flows of multiple simplified building models and their interdependent relationship with their urban climate (Robinson et al. 2009). CitySim includes building thermal, urban radiation, occupant behavior, and plant/equipment models integrated as a single simulation engine. CitySim simulates multiple buildings up to city scale using simplified models to achieve a good compromise between modeling accuracy, computational overheads, and data availability. Each building's thermal behavior is based on an electrical analogy using a two node resistor- capacitor network. The internal lighting, people, and miscellaneous loads are modeled using a simplified occupancy-based approximation. The heating, ventilation, and air-conditioning (HVAC) systems are modeled using a single equation that approximates the total mass flow rate required to meet the sensible and latent loads of each building as a whole. Each of these simplifying approximations empowers the urban-scale simulation to have reasonable execution times on the number of buildings being simulated.

Building performance simulation is a mature domain of research relative to urban scale efforts. The use of whole building simulation engines originated in the 1960s with the US government's development of the BLAST and DOE-2 hourly energy simulation programs (Lawrie et al. 2001). In 1996, development on a new simulation engine, EnergyPlus, began in order to combine the advantages of previous efforts in a single, modular program. EnergyPlus, as a result, has become a popular choice in detailed whole-building performance simulation due to the breadth of mechanical, renewable, and electrical systems that can be modeled. EnergyPlus specifically excels in its ability to model unique mechanical system types such as decoupled centralized cooling (Miller and Sekhar 2010) and low exergy heating and cooling systems (Hersberger and Sagerschnig 2013). Additionally, EnergyPlus is designed to provide a high resolution in which internal loads and natural ventilation technologies can be modeled in detail at the building level.

Both building and urban-scale simulation domains have rightfully chosen boundary conditions that reflect their key goals while seeking to minimize the input parameters necessary and run-times of the engines themselves. This focus results in certain deficiencies concerning modeling various phenomenon. For example, urban scale simulation highly simplifies the building systems and internal load models, thus making a retrofit analysis at the systems level difficult. And whole building simulation in EnergyPlus neglects many of the various contextual consideration of the urban environment such as long wave radiation exchange with adjacent surfaces and localized urban weather effects (Lawrie et al. 2001).

To address the deficiencies of the individual engines, the current effort seeks to couple building and urban scale simulation. The research in this paper is part of a larger coupling effort in which various engines are connected and co-simulated to create a more comprehensive analysis of the urban scale (Dorer et al. 2013; Allegrini, Dorer, and Carmeliet 2012). The target is the computational interface between the building energy model, using EnergyPlus, and the urban energy model using CitySim. An overview of the larger scope is shown in Figure 1 and the context of the coupling task appears as the interface between the City Energy Simulation (CES) model and the Building Energy Simulation (BES) model.

The coupling and co-simulation process is implemented on two case studies in Switzerland. The first case study is the ETH Zürich Hoenggerberg campus in Zürich, Switzerland. The campus was modeled in the CitySim simulation engine and co-simulated using work-flow automation. The target of this case study is to evaluate the differences between the coupled and solo EnergyPlus simulations based on the variables exchanged. This scenario includes the use of measured data for heating and cooling within their respective seasons to compare to the simulation results. The second case study is the EPFL campus in Lausanne, Switzerland. The objective of this scenario is to evaluate the differences between coupled and uncoupled versions of the CitySim simulation engine.




Figure 1. EnergyPlus and CitySim coupling are part of the wider context. Each block in the diagram represents an environment, with the tool/engine name in *italics* ((Thomas et al. 2014), adapted from (Dorer et al. 2013))

This paper describes the achievement of several objectives:

- (1) Automation of the process of simultaneous meta-data extraction from a building information model (BIM) for the creation of both building and urban-scale performance models for a real-world campus of buildings
- (2) Co-simulate the urban and building scale models through concurrent information exchange
- (3) Implement a simplified calibration procedure based on reconciling the co-simulation output results for a target building using measured energy performance data from the campus energy information system (EIS)

The first two objectives have been demonstrated in a simplified context in previous literature (Thomas et al. 2014; Miller et al. 2015). The innovation in the current publication is an extension of this research through the modeling and co-simulation of real-world case studies. With respect to the third contribution, to the best of the authors' knowledge, no previous study has compared the results of a building and urban-scale co-simulation procedure to measured data from a real-world campus.

1.1. Previous multi-scale coupling studies

Previous attempts of information exchange have been implemented between simulation engines at various scales. Much of the initial co-simulation work in the literature is done at the subsystem and building-scale. Previous studies have analyzed strong and loose coupling of engines at this scale (Trčka, Hensen, and Wetter 2010; Wetter 2011). Coupling of building-scale simulation with urban-scale computational fluid dynamics (CFD) is attempted for modeling natural ventilation (Zhang et al. 2013) and to improve energy prediction (Bouyer, Inard, and Musy 2011). A comprehensive review of energy and airflow modeling of neighborhoods and university campuses was published that includes strategic aspects of coupling different types of models (Srebric, Heidarinejad, and Liu 2015). EnergyPlus has been coupled with ENVI-met, a micro-climate computational fluid dynamics (CFD) program (Yang et al. 2012). It was also coupled with simplified lumped parameter models to facilitate comparison with measured sensor data (Martin et al. 2015). EnergyPlus and the TEP Urban Canopy Model program were coupled to quantify the influences of urban localized weather effects on whole building simulation (Bueno et al. 2011) and urban weather generation (Bueno et al. 2013).

2. Methodology

2.1. Coupling process

The coupling process of a simplified single zone model and contextual surrounding buildings is described in previous studies (Thomas et al. 2014), which forms the basis for the methodology in the current effort. This process utilizes the Design Performance Viewer (DPV) and associated workflow. The DPV is a tool written to extract and simulate an EnergyPlus input data file (IDF) from an AutodeskTM RevitTM BIM (Schlueter and Thesseling 2009). The central philosophy behind the tool is a rapid simulation of the building information model from the earliest design possible and can be used throughout the life-cycle of the building including retrofit analysis (Miller et al. 2014). This process is achieved by augmenting the information in the BIM with default values and abstracting information not relevant for energy simulation. The tool already has a simplified notion of surrounding buildings, which are modeled in the BIM as simple mass objects without further information and are exported as shading surfaces to EnergyPlus. This functionality is used for creating the CitySim mass scene and leads to a crude model of the urban context of the building. The current DPV philosophy of allowing the designer to iterate rapidly on early design decisions based on feedback about the performance of the design remains. This approach includes streamlining the process where running a simulation requires no effort from the designer due to automatic creation of input files, execution, and analysis of the results.

The coupling process of EnergyPlus and CitySim is shown in Figure 2. First, the DPV is used to extract an EnergyPlus simulation model from the BIM. The DPV utilizes the Revit API to extract geometrical information about the building and the physical properties of walls, windows, doors, roofs, and floors. This information is encoded in the BIM model as wall types, roof types, floor types as well as window and door families. Wherever possible, the tool uses the layering and materials of the construction types, enhancing them with physical attributes relevant to EnergyPlus. Where not defined, it assumes default values.




Figure 2. Overview diagram of the coupling process including tools and outputs (Thomas et al. 2014)

Next, geometry is created to be used in both the CitySim and EnergyPlus models as buildings and surfaces surrounding the building targeted in the IDF. This feature of the DPV is used for including shading surfaces in the EnergyPlus simulation model: it uses so-called *mass objects* in the BIM model as surrounding buildings. The DPV model views these buildings as a series of shading surfaces. A transformation is added to the DPV model that produces an input file for the CitySim solver. This file uses an XML format describing the buildings in a scene for simulation, including

their construction types, geometry, and systems for heating and cooling. The main BIM is extracted to the CitySim scene as one of the buildings to be simulated, with the properties of the construction types matching those in the DPV model. The glazing ratio is calculated based on the window and wall areas of the DPV model. Shading surfaces are grouped into buildings based on the mass object from which they were extracted. These neighboring buildings use default construction properties for walls and roofs, and we assign them a default glazing ratio. These defaults can be overridden by custom properties applied to the mass objects in the BIM much in the same way as the model elements of the main building are enriched with DPV information.

As of version 8.1.0, EnergyPlus supports exporting a simulation model as a Functional Mock-up Unit (FMU) (Nouidui, Wetter, and Zuo 2014; JModelica 2014). This feature introduces new IDF objects to specify the interface such an FMU exposes. These objects define which output variables are exported by the FMU and which variables are imported. The FMU export functionality is closely linked to the Energy Management System (EMS) of EnergyPlus. Co-simulation exchange variables either mimic an EnergyPlus schedule, an EMS variable or drive an EMS actuator. Since the model used by CitySim to simulate a building is more abstract than the model used by EnergyPlus, the EMS is used to aggregate certain values. CitySim does not model windows separately. Therefore, a weighted average of window and wall surface temperatures is calculated with EMS subroutines.⁴

The FMU creation process is the basis for coupling the two models at each timestep in the simulation. Figure 3 illustrates this process from both the EnergyPlus and CitySim perspective. The augmented IDF file is fed to the *EnergyPlusToFMI* script (Nouidui and Wetter 2014). Once configured, this script produces an FMU file based on the augmented IDF file and the weather file to be used as well as a DLL file implementing the Functional Mock-up Interface that can load the IDF file, locate EnergyPlus and run the simulation.




Figure 3. Simulation information exchange between CitySim and EnergyPlus using FMI (Thomas et al. 2014)

2.2. Coupled variables

Several key urban-scale weather variables are sent to EnergyPlus from CitySim to account better for the localized effects of surrounding buildings, geography and climate conditions. These variables include various outdoor air conditions such as dry bulb and wet bulb temperatures, dewpoint, humidity, wind speed and direction, and direct and diffuse solar radiation. These variables overwrite the input weather variables that EnergyPlus obtains from its weather file input. CitySim is designed to account for physical phenomenon inherent to urban environments, that are often neglected in building-scale simulation environments (Robinson and Stone 2004; Robinson et al. 2009). Long wave radiation exchange between the simulated building and its surroundings is sent to EnergyPlus; this process is described in detail in Section 2.3. Finally, CitySim shares its calculated occupancy schedules as it uses a more robust model of occupants behavior (Haldi and Robinson 2011).

⁴@JK: is this last statement correct?

Table 1. Values sent to EnergyPlus from CitySim by the FMU

Object	Variable Name	Description
Outdoor	Outdoor Drybulb	The outdoor dry-bulb temperature in °C
	Outdoor Dewpoint	The outdoor dewpoint temperature in °C
	Outdoor Relative Humidity	The outdoor relative humidity expressed in percent.
	Diffuse Solar	Diffuse horizontal irradiance in W/m ²
	Direct Solar	Beam normal irradiance in W/m ²
	Wind Speed	The outdoor wind speed in m/s
Long Wave Radiation	Wind Direction	The wind direction in degrees (N=0, E=90, S=180, W=270)
	Environmental Radiant Temp.	Calculated T_{env} from the sky, ground, and surrounding surfaces
	Environmental Radiant Heat	Calculated h_{env} from the sky, ground, and surrounding surfaces
	Gain Coefficient	
Zone	Occupation	Fraction of the maximum occupation (0.0-1.0) overrides the EnergyPlus occupation schedule with the CitySim stochastic schedule.

Variables sent to CitySim by EnergyPlus at each time step include several variables related to the calculation of heating and cooling loads of a targeted building. These variables are transferred due to the ability of EnergyPlus to model more detailed building systems, schedules, ventilation and internal load types than CitySim. For example, EnergyPlus is flexible enough to model a detailed radiant heating and cooling system that would be impossible in CitySim (Hersberger and Sagerschnig 2013). EnergyPlus is an engine optimized to accurately model building-scale systems. Thus, CitySim can take advantage of these models through coupling and co-simulation. EnergyPlus sends the heating and cooling loads, the surface temperatures of the exterior surfaces and the ventilation flow rates to CitySim.

Table 2. Values sent to CitySim from EnergyPlus by the FMU

Object	Variable Name	Description
Wall, Roof	Outside Surface Temperature	The temperature on the outside of the surface in °C
Wall	Average Outside Surface Temperature	The (weighted) average temperature of the surface on the outside in °C.
Zone	Total Heating Energy	The heating energy in Joules used in this timestep.
	Total Cooling Energy	The cooling energy in Joules used in this timestep.
	Zone Mean Air Temperature	The mean air temperature in the zone in °C
	Ventilation Volume Flow Rate	The flow rate in m ³ /s (standard density)

2.3. Long wave radiation exchange

Long wave radiation exchange in the urban scale environment is coupled in the co-simulation process. It requires the development of a set of approximations to reduce the number of coupled variables between the engines and to account for differences in the methods by which each engine calculates this value. A detailed description of Long Wave Radiation (LWR) variable exchange and approximation is found in a previously published study (Miller et al. 2015) on a simplified theoretical case.

In EnergyPlus, LWR exchange for a surface is calculated through the summation of radiation gain from the ground, sky, and air as seen in Equation 1 and Figure 4a (United States Department of Energy (DOE) 2015). The radiant heat transfer coefficient for each of these environmental variables is calculated according to Equation 2 with σ as the Stefan-Boltzmann constant and ϵ as the emissivity. A major assumption of this approach is that the modeled building's surfaces and those of adjacent buildings are at a uniform temperature and the LWR radiation exchange is negligible; a situation that is an oversimplification in an urban scale domain (Evins, Dorer, and Carmeliet 2014).

$$Q_{LWR,EnergyPlus} = h_{r,grd}(T_{surf} - T_{grd}) + h_{r,sky}(T_{surf} - T_{sky}) + h_{r,air}(T_{surf} - T_{air}) \quad (1)$$

178

$$h_{r,variable} = \frac{\epsilon\sigma(T_{surf}^4 - T_{variable}^4)}{T_{surf} - T_{variable}} \quad (2)$$

179 In comparison, CitySim calculates LWR exchange by calculating an aggregated equivalent tem-
 180 perature, T_{env} , and radiative heat transfer coefficient, $h_{r,env}$, from surrounding urban surfaces in
 181 addition to ground, sky, and air (Robinson et al. 2009). The calculation for T_{env} is expressed in
 182 Equation 3 with the F values being view factors of the surrounding environment including adjacent
 183 surfaces $i = 1..n$. $h_{r,env}$ is based on a first order Talyor development of the numerator of Equation 2
 184 around $(T_{surf} + T_{variable})/2$ and therefore $Q_{LWR,CitySim}$ is calculated using Equation 4.

$$\sigma T_{env}^4 = \sigma F_{sky} T_{sky}^4 + \sigma F_{grd} T_{grd}^4 + \sum_{i=1}^n \epsilon_i \sigma F_i T_i^4 \quad (3)$$

185

$$Q_{LWR,CitySim} = h_{r,env}(T_{surf} - T_{env}) \quad (4)$$

186 In the coupled simulation, EnergyPlus uses the CitySim supplied equivalent $h_{r,env}$ and T_{env} to
 187 calculate weighted $h_{r,sky}$, $h_{r,grd}$, and $h_{r,air}$ values using the view factors and the sky-to-air split
 188 ratio. Figure 4 illustrates the schematic differences between the solo and coupled simulations on
 189 a theoretical example of a target building with two adjacent buildings with surfaces available for
 190 radiation exchange.




Figure 4. Comparison of the LWR components between a) Solo EnergyPlus and b) Coupled CitySim/EnergyPlus configuration (Miller et al. 2015)

191 2.4. Work flow automation

192 The coupling, simulation and co-simulation process is completely managed within a program called
 193 VisTrails (VisTrails 2014). The implementation of this type of work flow is outlined in previous work
 194 focused on automating DPV using the Kepler platform (Thomas and Schlueter 2012). This process
 195 reduces the effort expended by a designer down to pressing a single button. This functionality allows
 196 an iterative design style informed by readily available simulation results. An automated work flow to
 197 tie the various steps together and maintain the effortless iterative design process. VisTrails enables
 198 the coupling of various work flow subprocesses script initializations, executions of the engines, and
 199 the compilation of the outputs. This tool empowers the coupling of various executable files and
 200 their connecting scripts in graphical diagrams that enhances reproducibility and process automation
 201 (Freire et al. 2014). The VisTrails work flow diagram for the first case study in this paper is seen in
 202 Figure 5.




Figure 5. Workflow in VizTrails

2.5. Simplified calibration

In the first case study, one aspect of this analysis is the comparison of actual measured performance of the target building on campus with the simulation results of the co-simulation. A simplified calibration procedure is adapted from previous research to compare the measured heating and cooling data available on campus with various simulation scenarios (Samuelson, Ghorayshi, and Reinhart 2015). This calibration procedure was utilized in the performance reconciliation of 18 buildings that were built according to the LEED Canada protocol and were under review of actualized performance. This protocol is unique in its analysis process to uncover design model deficiencies in a step-wise manner, utilizing the most easily accessible knowledge first and working towards equilibrium between measured and simulated. An appropriate balance between the effort of implementation and value generated through the calibration process.

3. Implementation

The co-simulation process is implemented on two case studies in Switzerland. The first is the ETH Zürich Hoenggerberg campus in Zürich, Switzerland. The focus of this case study is to compare the impact of the information exchange through co-simulation within the EnergyPlus engine. The intent on this campus was to develop techniques for retrofit analysis using EnergyPlus. The targeted building on this campus is the HPI Building. Raw measured data is available for many of the buildings on campus, thus a simplified calibration procedure is used to reconcile the simulation results.

The second case study is the EPFL campus in Lausanne, Switzerland. The targeted building, in this case, was the Quartier Nord complex. The focus of this study was to compare the output results of both CitySim and EnergyPlus. Reliable measured data for calibration is not currently available for this building.

3.1. Campus case study 1: ETHZ Hoenggerberg Campus

The ETH Zürich Hoenggerberg campus includes 32 higher education facilities with spaces allocated to laboratories, office space, lecture halls, cafeterias, data centers and other types of similar areas. The campus has a centralized energy management system (EMS) that contains 807 energy and water measurement points from heating, cooling, electricity, city gas, domestic hot water, grey water, and general water consumption.

The focus of the co-simulation process is that the performance of a targeted building is evaluated through solo and coupled methods. The HPI building on campus was chosen in this case study due to the amount and quality of measured data available from the EMS for this building. HPI is a 2,610 sq. meter building that is made up mostly of office space and classrooms. It also includes 400 m^2 convenience store and coffee shop. The building is indicated on a campus map shown in Figure 6 and is shaded red.




Figure 6. ETH Hoenggerberg campus map with the HPI building shaded red

3.2. Model development

In order to perform a co-simulation of the targeted buildings, initially a CitySim model of the campus is developed. Through the workflow automation process, this geometry was converted into an EnergyPlus input file as seen in Figure 7. The EnergyPlus input file is then used as an input to

243 execute EnergyPlus solo and co-simulation processes for the purpose of simplified calibration, and
 244 then to understand the magnitude of difference between these simulation scenarios.




Figure 7. The HPI building modeled with OpenStudio for Sketchup

245 3.3. Measured data collection and calibration

246 Energy data from the HPI building was collected and analyzed in the context of the simplified
 247 calibration procedures. The measured datasets are screened and aggregated into typical usage profiles
 248 to be used for the lighting, plug- loads, and HVAC equipment availability schedules and power
 249 densities. Figure 8 illustrates the aggregation examples of electrical energy for the HPI building.
 250 This profile was created through a filtering and clustering process known as *DayFilter* (Miller, Nagy,
 251 and Schlueter 2015). This profile is used to set the availability schedules as inputs into the EnergyPlus
 252 simulation to emulate the way occupants inhabit the building and how the building management
 253 system (BMS) controls the lighting and HVAC systems.




Figure 8. HPI Electrical Energy Typical Profiles

254 The measured and simulated data from both the co-simulation and EnergyPlus solo simulation
 255 was compared in order to create a realistic scenario for comparison. The calibration process was
 256 undertaken through a series of steps such as including local weather conditions for the simulation
 257 period and adding custom lighting schedules and power densities extracted from the measured data.
 258 The models were calibrated to the summer season (May-September) for cooling and the winter season
 259 (Jan-April and October to December) for heating. This approach was taken as the data quality for
 260 the measurements were deemed most accurate during the appropriate seasons. Figure 9 illustrates a
 261 comparison of the measured data with the simulations after the tuning process. The final calibrated
 262 EnergyPlus solo model had a normalized mean bias error (NMBE) of -9.36% and a coefficient of
 263 variation of root mean square error (CVRMSE) of 21.7% for cooling and -9.36% and 29.4% for
 264 heating. These metrics fall within the $\pm 10\%$ NMBE and $\pm 30\%$ CVRSME used in this case study
 265 for calibration. The goal of calibration, in this case, is to just bring the models to within a reasonable

range of reality in order to bring more confidence to analysis of the discrepancies between the solo and co-simulation scenarios.




Figure 9. HPI Measured vs. Co-Simulation and EnergyPlus Solo for Heating and Cooling Seasons

3.4. EnergyPlus co-simulation results

After calibration, a comparison of co-simulation and solo EnergyPlus simulations is made. For cooling, a discrepancy can be seen between co-simulation and solo EnergyPlus. Co-simulation results in a 20.2% decrease in predicted cooling energy, as seen in Figure 10. Figure 11 illustrates the difference in predicted heating energy consumption across the test year. A consistent offset exists across the time frame of days in January, the peak of the heating season. A more varied discrepancy across the heating months is noticed resulting an overall increase of heating prediction of 4.8% due to co-simulation. The exchange of long wave radiation for this particular site is substantial due to the proximity of surrounding buildings. These performance differences due to co-simulation are compared to a theoretical single-zone case study in which there was a 15-30% increase in heating energy and a 4-11% decrease in cooling energy (Miller et al. 2015). The results from this scenario are less extreme on the heating side and more on the cooling side than the theoretical case study.




Figure 10. HPI Co-Simulation vs. EnergyPlus Solo for Cooling




Figure 11. HPI Co-Simulation vs. EnergyPlus Solo for Heating

3.5. Campus case study 2: EPFL Quartier Nord

Quartier Nord is a whole new quarter of the École Polytechnique Fédérale de Lausanne (EPFL) campus located at its northwest corner. This complex includes a Convention Centre with an auditorium with a maximum capacity of 3000 (seated) people, housing for 516 students, retail and service areas and a hotel. As a public space, this ensemble is organized around the central plaza as seen in Figure 12).



Figure 12. The Quartier Nord at EPFL in Lausanne

With a particularly strong visual and formal identity, the SwissTech Convention Centre (STCC) is clearly the key protagonist.⁵ Applied with essential functions for the region, the building has definitely become the new landmark. Designed as a Minergie⁶ building, it includes modern energy conversion technologies to reduce its energy consumption. The focus of the co-simulation is realized on the STCC, simulated with the nearby buildings for housing, retail and service areas.

3.6. Model development

The information required in the simulation mainly comprises three parts: physical, geometrical and operational data. The geometry information including the shape, dimension, structure and materials was obtained from the Real Estate and Infrastructure Department of École Polytechnique Fédérale de Lausanne (EPFL), which was responsible for carrying out the project from call to tender to construction. However, since the documents provided were full of details but also conflicting with what has been installed as compared to the documents before construction, the task to realize a precise model of the buildings itself is rather tedious. Besides, it is even more challenging to get the

⁵move main sentence to start of paragraph

⁶ref?

operational data (daily occupancy, lighting, and electrical equipment usage level and ventilation rate) as the building has only recently been set in operation mode and as engineers and technicians have been working on improving the controls. Therefore, due to unreliable monitoring data, the calibration step of the model has been unfortunately⁷ abandoned.

Considering the lack of detailed information about the building, a so-called detailed reference case was modeled with EnergyPlus (Mauree et al. 2015) in which regulation standards applied in the design phase from the SIA norms were used to complete the missing information. A rendering of this model is seen in Figure 13.




Figure 13. The Quartier Nord modeled with OpenStudio for Sketchup⁹. The STCC on the left is the main focus of the study and is represented by two thermal zones.

The corresponding CitySim model was created by exporting a DXF file from EnergyPlus, and importing it into the Graphical User Interface of CitySim. Physical characteristics of the building were added to complete the CitySim model. Finally, the same script as described in Section 2 was used to export the model from CitySim to EnergyPlus, giving a simplified EnergyPlus model.

3.7. Comparison of EnergyPlus and CitySim

Both the CitySim and EnergyPlus engines are utilized in this case study. The first comparison to observe is the differences between the two engines when focused on the Quartier Nord building. When simulated in isolation, the CitySim engine predicts a 28.6% increase in heating load and a 44.4% increase in cooling load as compared to EnergyPlus. This phenomenon is due to the differences in the way each of these engines calculates heating and cooling loads. Use of the co-simulation process brings the engines to within 5.4%. Figure 14 illustrates these differences for cooling and Figure 15 for heating.

⁷delete: "unfortunately": we are cold hard scientists battling the evil nemesis that is entropy and his plan to suffocate everyone with the inevitable heat death of the universe. we have no time for lame excuses. we just abandon. no regrets. thug life!




Figure 14. Quartier Nord CitySim vs. EnergyPlus Solo for Cooling




Figure 15. Quartier Nord CitySim vs. EnergyPlus Solo for Heating

3.8. EnergyPlus co-simulation results

The Quartier Nord building is also simulated within the solo and cosimulation environments. When focusing on the EnergyPlus results, a 7.5% decrease in cooling energy is observed, as seen in Figure 16. A 2.8% increase in heating energy is observed, as seen in Figure 17. These differences are less pronounced than the HPI and theoretical case studies due to the number and proximity of surrounding buildings is not as large.¹⁰¹¹




Figure 16. Quartier Nord EnergyPlus Co-Simulation vs. Solo for Cooling

¹⁰I'm planning to elaborate on these sections but am struggling to interpret the results other than just "co-sim and solo are different" – what do you guys think?

¹¹well, for a start, the two case studies differ in the amount of LWR radiation. we could quantify that? also, the number of surfaces of the e+ model with viewfactor to surrounding buildings?




Figure 17. Quartier Nord EnergyPlus Co-Simulation vs. Solo for Heating

3.9. CitySim co-simulation results

When focusing solely on CitySim, a 26.9% decrease in heating energy is observed, as seen in Figure 18. A 49.1% decrease in heating energy is observed, as seen in Figure 19. These results align with the previous comparison of EnergyPlus and CitySim engines. The substantial differences between solo and co-simulation in these cases is a result of EnergyPlus transferring the heating and cooling load values at each time step.¹²




Figure 18. Quartier Nord CitySim Co-Simulation vs. Solo for Cooling




Figure 19. Quartier Nord CitySim Co-Simulation vs. Solo for Heating

¹²Jerome – I need some help interpreting these results – you mentioned that there is an expected delta between citysim and energypus in previous studies. Can you help elaborate on that?

4. Conclusion

The ability to couple and leverage the best aspects of multiple simulation engines can enhance the modeling of large scale urban agglomerations. This paper has outlined two such scenarios in which the building-focused EnergyPlus simulation engine is coupled and co-simulated with the urban-scale CitySim engine. This process is implemented through a fully automated work flow process that extracts geometry information at the urban-scale, creates the necessary input information, executes each engine with information exchange at each time step of targeted variables, and accumulates the results of analysis. The process has been implemented on simplified theoretical scenarios in the past and the key innovation with this work is in implementation on actual case study campuses and targeted buildings. The results illustrate that the differences between the co-simulation and solo environments are within range of previous theoretical models. More reliable results of the magnitude of differences between the simulation techniques can be extracted from these real-world scenarios.

Future work in using co-simulation models for buildings and campuses would more intensively utilize the model results in a practical implementation of retrofit scenarios or urban-scale energy systems research.

4.1. Acknowledgements

The authors would like to acknowledge the ETH Zürich Campus Facilities Department, the EPFL Real Estate and Infrastructure Department, and Emanuel Thoma for their assistance in this project. This research was funded by the Competence Center in Energy and Mobility (CCEM) under the Urban Multi-scale Energy Modeling (UMEM) project. The authors would also like to acknowledge Emanuel Thoma for his work in developing the geometric models.

References

- Allegrini, Jonas, Viktor Dorer, and Jan Carmeliet. 2012. "Influence of the urban microclimate in street canyons on the energy demand for space cooling and heating of buildings." *Energy and Buildings* 55: 823–832.
- Bouyer, Julien, Christian Inard, and Marjorie Musy. 2011. "Microclimatic coupling as a solution to improve building energy simulation in an urban context." *Energy and Buildings* 43 (7): 1549–1559.
- Bueno, Bruno, Leslie K Norford, Julia Hidalgo, and Grégoire Pigeon. 2013. "The urban weather generator." *Journal of Building Performance Simulation* 6 (4): 269–281.
- Bueno, Bruno, Leslie K Norford, Grégoire Pigeon, and Rex Britter. 2011. "Combining a Detailed Building Energy Model with a Physically-Based Urban Canopy Model." *Boundary-Layer Meteorology* 140 (3): 471–489.
- Dorer, Viktor, Jonas Allegrini, Kristina Orehounig, Peter Moonen, Govinda Upadhyay, Jérôme Kämpf, and Jan Carmeliet. 2013. "Modelling the urban microclimate and its impact on the energy demand of buildings and building clusters." In *Proceedings of BS2013: 13th Conference of International Building Performance Simulation Association*, 3483–3489. Chambéry, France: International Building Performance Simulation Association. Aug..
- Evins, Ralph, Viktor Dorer, and Jan Carmeliet. 2014. "Simulating external longwave radiation exchange for buildings." *Energy and Buildings* 75: 472–482.
- Freire, Juliana, David Koop, Fernando Seabra Chirigati, and Cláudio T Silva. 2014. "Reproducibility using VisTrails." *Implementing Reproducible Research* 33.
- Haldi, Frédéric, and D Robinson. 2011. "The impact of occupants' behaviour on building energy demand." *Journal of Building Performance Simulation* 4 (4): 323–338.
- Hersberger, Christian, and Carina Sagerschnig. 2013. "Thermal Modelling of a Low Exergy HVAC System in EnergyPlus: A Case Study." In *CISBAT*, 1139–1144. Lausanne, Switzerland. Sep..
- JModelica. 2014. "http://www.jmodelica.org/FMILibrary." <http://www.jmodelica.org/FMILibrary>.
- Keirstead, James, Mark Jennings, and Aruna Sivakumar. 2012. "A review of urban energy system models: Approaches, challenges and opportunities." *Renewable and Sustainable Energy Reviews* 16 (6): 3847–3866.

381 Lawrie, L K, Fred C Winkelmann, Fred Buhl, and Joe J Huang. 2001. "EnergyPlus: creating a new-generation
382 building energy simulation program." *Energy and Buildings* 33 (4): 319–331.

383 Martin, Miguel, Afshin Afshari, Peter R Armstrong, and Leslie K Norford. 2015. "Estimation of urban
384 temperature and humidity using a lumped parameter model coupled with an EnergyPlus model." *Energy
385 and Buildings* 96: 221–235.

386 Mauree, D, Y Yao, J KAEMPF, and J L Scartezzini. 2015. "Evaluation and Optimization of Renewable
387 Energy in the "Quartier Nord": Objective Zero-Power." *CISBAT 2015* .

388 Miller, C, Z Nagy, and Arno Schlueter. 2015. "Automated daily pattern filtering of measured building
389 performance data." *Automation in Construction* .

390 Miller, Clayton, and Chandra Sekhar. 2010. "Modeling of the Single Coil, Twin Fan Air-Conditioning System
391 in EnergyPlus." In *SimBuild 2010: Fourth National Conference of IBPSA-USA*, 201–206. New York, NY.
392 Aug..

393 Miller, Clayton, Daren Thomas, Silvia Domingo Irigoyen, Christian Hersberger, Zoltan Nagy, Dino Rossi, and
394 Arno Schlueter. 2014. "BIM-extracted EnergyPlus model calibration for retrofit analysis of a historically
395 listed building in Switzerland." In *In Proceedings of SimBuild 2014: 2014 ASHRAE/IBPSA-USA Building
396 Simulation Conference*, Atlanta, GA, USA. Sep..

397 Miller, Clayton, Daren Thomas, Jérôme Kämpf, and Arno Schlueter. 2015. "Long Wave Radiation Exchange
398 for Urban Scale Modeling within a Co-Simulation Environment." In *CISBAT*, Lausanne, Switzerland. Sep..

399 Nouidui, Thierry, Michael Wetter, and Wangda Zuo. 2014. "Functional mock-up unit for co-simulation
400 import in EnergyPlus." *Journal of Building Performance Simulation* 7 (3): 192–202.

401 Nouidui, Thierry Stephane, and Michael Wetter. 2014. "Tool coupling for the design and operation of
402 building energy and control systems based on the Functional Mock-up Interface standard." In *the 10th
403 International Modelica Conference, March 10-12, 2014, Lund, Sweden*, 311–320. Linköping University
404 Electronic Press. Mar..

405 Robinson, D, Frédéric Haldi, J Kämpf, Philippe Leroux, Diane Perez, Adil Rasheed, and Urs Wilke. 2009.
406 "CitySim: Comprehensive micro-simulation of resource flows for sustainable urban planning." In *Proceed-
407 ings of BS2009: 11th International Building Performance Simulation Association Conference*, Glasgow,
408 Scotland. Jul..

409 Robinson, D, and Andrew Stone. 2004. "Solar radiation modelling in the urban context." *Solar Energy* 77
410 (3): 295–309.

411 Samuelson, Holly W, Arash Ghorayshi, and Christoph F Reinhart. 2015. "Analysis of a simplified calibration
412 procedure for 18 design-phase building energy models." *Journal of Building Performance Simulation* 1–13.

413 Schlueter, Arno, and Frank Thesseling. 2009. "Building information model based energy/exergy performance
414 assessment in early design stages." *Automation in Construction* 18 (2): 153–163.

415 Srebric, Jelena, Mohammad Heidarinejad, and Jiying Liu. 2015. "Building neighborhood emerging properties
416 and their impacts on multi-scale modeling of building energy and airflows." *Building and Environment* 91
417 (C): 246–262.

418 Thomas, D, C Miller, J Kämpf, and Arno Schlueter. 2014. "Multiscale co-simulation of EnergyPlus and
419 CitySim models derived from a building information model." *BauSIM 2014: Fifth German-Austrian
420 IBPSA Conference* .

421 Thomas, Daren, and Arno Schlueter. 2012. "Customizable continuous building simulation using the de-
422 sign performance toolkit and Kepler scientific workflows." In *Proceedings of ECPPM 2012: eWork and
423 eBusiness in Architecture, Engineering and Construction*, 17–22. Reykjavik, Iceland: CRC Press.

424 Trčka, M, Jan Hensen, and M Wetter. 2010. "Co-simulation for performance prediction of integrated building
425 and HVAC systems—An analysis of solution characteristics using a two-body system." *Simulation Modelling
426 Practice and Theory* 18: 957–970.

427 United Nations. 2014. "World Urbanization Prospects: 2014 Update." 1–32.

428 United States Department of Energy (DOE). 2015. "EnergyPlus Engineering Reference Version 8.2: The
429 Reference to EnergyPlus Calculations." *The Reference to EnergyPlus Calculations* .

430 VisTrails. 2014. "www.vistrails.org." <http://www.vistrails.org>.

431 Wetter, Michael. 2011. "Co-simulation of building energy and control systems with the Building Controls
432 Virtual Test Bed." *Journal of Building Performance Simulation* 4 (3): 185–203.

433 Yang, Xiaoshan, Lihua Zhao, Michael Bruse, and Qinglin Meng. 2012. "An integrated simulation method
434 for building energy performance assessment in urban environments." *Energy and Buildings* 54: 243–251.

435 Zhang, R, Khee Poh Lam, S Yao, and Y Zhang. 2013. "Coupled EnergyPlus and computational fluid dy-
436 namics simulation for natural ventilation." *Building and Environment* .