What moves each number, once the measured values are held fixed

	Module room Cooling design capacity	Module room Heating design capacity	Module room Cooling, operating	Module room Cooling, ramp	Module room Heating, operating	Module room Heating, ramp	Module room Fastest reachable ramp	Climate chamber Cooling design capacity (sun on)	Climate chamber Heating design capacity (sun off)	Climate chamber Cooling, operating (sun on)	Climate chamber Cooling, ramp (sun on)	Climate chamber Heating, operating (sun off)	Climate chamber Heating, ramp (sun on)	Climate chamber Fastest reachable ramp (sun on)
setpoint min	0.07	0.05	0.03	0.07		0.05	0.08	0.14	0.08	0.96	0.14		0.08	0.16
setpoint max	0.12	0.18		0.12	0.44	0.18	0.21	0.07	0.13		0.07	0.96	0.13	0.16
ramp minutes	0.55	0.58		0.55		0.58		0.88	0.85		0.85		0.85	
max air surface dt							0.67							0.75
added mass coverage	0.31	0.33		0.31		0.33	0.48	0.03	0.03		0.03		0.03	0.12
south WWR	0.04		0.42	0.04										
ach			0.02		0.42									
south irradiance	0.03		0.39	0.03										
south shgc	0.03		0.39	0.03										
added mass thickness							0.10							
equipment w per m2					0.07									
roof U opaque					0.07									
vent supply temp										0.04		0.04		
south U opaque					0.03									
south u glazing					0.03									
occupants														
exchanger approach														
carnot efficiency														
supply dt														
target rh														

