

GSAS Operations Certification

Compliance Assessment Report

Building Name: QNB Tower - West Bay

Building ID: QNB-TOWER-01

Assessment Date: January 15, 2026

Report ID: GSAS-20260115-224956

Certification Type: Operations

GSAS Version: v2.1

Overall Score		1.02 / 3.00
Star Rating	★★■■■■■ (2 Stars)	
Target Rating	3 Stars	
Compliance Status	NEEDS ATTENTION	

Prepared for submission to Gulf Organisation for Research & Development (GORD)

1. Executive Summary

This report presents the GSAS Operations certification assessment for **QNB Tower - West Bay**. The building achieved an overall score of **1.02**, corresponding to a **2-Star** rating.

■ The building is **1 star(s) below target**. Improvement actions are recommended before certification submission.

Areas Requiring Attention:

- Urban Connectivity needs improvement (0%)
- Site needs improvement (0%)
- Energy needs improvement (20%)

2. Category Score Breakdown

Category	Weight	Score	Max	%	Status
Urban Connectivity	5%	0.0	4.0	0%	■
Site	10%	0.0	7.0	0%	■
Energy	24%	3.0	15.0	20%	■
Water	16%	1.0	10.0	10%	■
Materials	14%	0.0	9.0	0%	■
Indoor Environment	16%	4.0	13.0	31%	■
Cultural & Economic Value	5%	0.0	4.0	0%	■
Management & Operations	10%	0.0	8.0	0%	■

3. Detailed Criteria Assessment

Urban Connectivity (UC)

ID	Criterion	Score	Max	Status	BMS?
UC.1	Public Transportation	0.0	2.0	■	No
UC.2	Amenity Access	0.0	2.0	■	No

Site (S)

ID	Criterion	Score	Max	Status	BMS?
S.1	Land Preservation	0.0	2.0	■	No
S.2	Landscaping	0.0	2.0	■	No
S.3	Heat Island Effect	0.0	2.0	■	No
S.4	Light Pollution	0.0	1.0	■	No

Energy (E)

ID	Criterion	Score	Max	Status	BMS?
E.1	Energy Demand Performance	1.5	3.0	✓	Yes
E.2	Primary Energy & CO2	0.0	3.0	■	Yes
E.3	Energy Monitoring	1.5	2.0	✓	Yes
E.4	Renewable Energy	0.0	3.0	■	No
E.5	District Cooling	0.0	2.0	■	Yes
E.6	Efficient Lighting	0.0	2.0	■	No

Water (W)

ID	Criterion	Score	Max	Status	BMS?
W.1	Water Demand Performance	1.0	3.0	■	Yes
W.2	Water Recycling	0.0	3.0	■	No
W.3	Water Monitoring	0.0	2.0	■	Yes
W.4	Landscaping Water	0.0	2.0	■	No

Materials (M)

ID	Criterion	Score	Max	Status	BMS?
M.1	Regional Materials	0.0	2.0	■	No
M.2	Recycled Materials	0.0	2.0	■	No
M.3	Material Reuse	0.0	2.0	■	No
M.4	Life Cycle Assessment	0.0	3.0	■	No

Indoor Environment (IE)

ID	Criterion	Score	Max	Status	BMS?
IE.1	Thermal Comfort	2.0	3.0	✓	Yes
IE.2	Indoor Air Quality	2.0	3.0	✓	Yes
IE.3	Natural Ventilation	0.0	2.0	■	No
IE.4	Daylighting	0.0	2.0	■	No
IE.5	Acoustic Quality	0.0	2.0	■	No
IE.6	Views	0.0	1.0	■	No

Cultural & Economic Value (CE)

ID	Criterion	Score	Max	Status	BMS?
CE.1	Heritage & Culture	0.0	2.0	■	No
CE.2	Economic Impact	0.0	2.0	■	No

Management & Operations (MO)

ID	Criterion	Score	Max	Status	BMS?
MO.1	Commissioning	0.0	2.0	■	Yes
MO.2	Energy Management	0.0	2.0	■	Yes
MO.3	Waste Management	0.0	2.0	■	No
MO.4	Facility Management	0.0	2.0	■	Yes

4. BMS Data Evidence

The following data points were automatically collected from the Building Management System (BMS) to support the GSAS criteria scoring:

Criterion	Metric IDs	Last Updated	Auto-scored
E.1: Energy Demand Performance	energy_consumption, energy_bas	2026-01-15	Yes
E.2: Primary Energy & CO2	N/A	2026-01-15	Yes
E.3: Energy Monitoring	meter_count, submetering	2026-01-15	Yes
E.5: District Cooling	N/A	2026-01-15	Yes
W.1: Water Demand Performance	water_consumption	2026-01-15	Yes
W.3: Water Monitoring	N/A	2026-01-15	Yes
IE.1: Thermal Comfort	zone_temp, humidity	2026-01-15	Yes
IE.2: Indoor Air Quality	co2_level, outdoor_air	2026-01-15	Yes
MO.1: Commissioning	N/A	2026-01-15	Yes
MO.2: Energy Management	N/A	2026-01-15	Yes
MO.4: Facility Management	maintenance_compliance	2026-01-15	Yes

BMS integration enables continuous compliance monitoring and reduces manual data collection effort.

5. Improvement Recommendations

The following improvements are recommended to enhance the GSAS score, listed in order of impact:

Priority	Criterion	Category	Potential Gain	BMS Trackable
1	E.2: Primary Energy & CO2	E	+3.0 pts	Yes
2	E.4: Renewable Energy	E	+3.0 pts	No
3	E.5: District Cooling	E	+2.0 pts	Yes
4	E.6: Efficient Lighting	E	+2.0 pts	No
5	W.2: Water Recycling	W	+3.0 pts	No
6	M.4: Life Cycle Assessment	M	+3.0 pts	No
7	W.1: Water Demand Performance	W	+2.0 pts	Yes
8	W.3: Water Monitoring	W	+2.0 pts	Yes
9	W.4: Landscaping Water	W	+2.0 pts	No
10	IE.3: Natural Ventilation	IE	+2.0 pts	No

6. Certification Statement

This report has been automatically generated based on data from the Building Management System and manual inputs. The overall GSAS score of **1.02** qualifies the building for a **2-Star** Operations Certification.

Facility Manager: _____ Date: _____

GORD Reviewer: _____ Date: _____