

Ensurazone
401 Ryland St, Suite 100
Reno, NV 89502, US
775-737-1355
contact@ensurazone.com
www.ensurazone.aridiantechnologies.com

Name Ana Frank Customer ID 1234567 Assessment Date 12/31/0000

Contact# 555 555 Email ID anafrank@gmail.com

Address 13 Winding street San Diego 98765, CA, US

Ground proof Assessment Report

Structure Assessment						
Vegetation						
Inspected variables		Site findings	Recommendation			
Vegetation free area around 5ft from structure		Rose plants branches and lavenders are found 3ft away from the structure at the left side of the backyard	5ft area around the structure should be clear			
Combustible subs	tance					
Presence of Combustible Substance 30ft. area around the structure	Logs/ firewood pile	Exposed firewood beside the store	*/There should not be any 30ft area around */Propane (LPG) tanks should be kept have 10ft away from vegetation			
	Scrape	Scrape of rubber tires found beside the outdoor barbeque area				
	Flammable debris	None				
	Propane cylinder	Found				
	Wildgrass longer than 6"	*The length of grass is 5" high from the surface				
	Presence of low limbed conifer	Few branches of conifer tree in southwest of the structure are 5ft high from the ground				
Presence of Combustible Material on the structure		Not found	Structure should not made of or should be cleared fron all types of combustible material			
Deposits of leaves and pine needle on:	Gutters	Clear	Gutter, porch, roof-line and should be completely clear			
	Porch	Clear	from the from the pine needle and leaves			
	Roofline	Lots of pine needles found at the back of the side on the roof-line				
	Deck	Dry leaves found				

Caraan nuatastian	Attic	Carean missing and thore is a root	There should be sereens on attics, roofs and soffits and
Screen protection	Attic	Screen missing and there is a nest of the birds	There should be screens on attics, roofs and soffits and foundation vent (1/8 inch metal screening)
		of the birds	Toundation vent (1/8 inch metal screening)
	Chimney	Screen Covered	
	Soffit vent	Front soffit vent is broken	
	Foundation vent	Screen covered	

Space Assessment Zone1 Vegetation					
Density of trees	medium				
Distance of trees from the structure	5ft apart from the kitchen				
Arrangement of trees	Clustered Cluster size=2	Scattered apart by 10ft. recommended no conifer zone			
Location(directions)	(list of all trees found in all dimensions)				
Photograph	Photographic description Two lemon trees located aligned in north western direction may have a chance of becoming ladder fuel				
SME site findings zone 1	Comments of the SME regarding vegetation arrangement, number and the location of the trees				
	Space Assessment Zor	ne 2			
Vegetation					
Neighborhood growth of vegetation security threats	defensible space does not extend onto a neighboring property	Linking Your Defensible Space with Neighbors For wildfire protection since			
	low limbed conifers				
No. of trees	(count) exp. 15				
Density of trees	high				
Arrangement	Continues	Clumps of 2 to 3 trees can make the space defensible			
Space among the trees	Trees are scattered by Less than 10ft distance in different directions	Space should be >=20-30ft			
Size of clump	4	Size of the clump should be 2 to 3 trees			

	Stream		
	Road		
	Pond		
	Open meadow		
Site specific observations zone-2		SME observations	
Ladder fuel		Branches of 6 trees are 4ft high from the surface in different direction	The branches of trees should be above 6ft high from the surface
photograph from the site		SME comments about site	
Aspects	East West	North-east	The defensible space form the structure till zone-2 needs to be increased in case of steep slope
Topography			
		_	to be increased in case of steep slope
	North		Incorporate artificial barriers to improve resistance frim
	South		fire
	Northeast		
	Northwest		
	Southeast		
	Southwest		
Slope	Leveled	Medium Steep inclined	
	Medium steep		
	inclined		
	Steep inclined		