

BOQ : EXO – OXY – 200

| Sr. No. | Description | Unit | Qty | Unit Rate | Amount |
|------------|--|--------|-----|-----------|--------|
| 1 | Washroom Exhaust Air Foul Odor, Microorganisms & Pollutant Destruction System | No. | 1 | | |
| | Design, Sizing & Supply of Washroom area exhaust air odor & pollutant reduction/control and disinfection system using high concentration Gen. IV Electro - Chemical Oxidant [ECO] spray with high efficiency Bipolar Oxygen Ionization [BOI] technique. The entire odor control system has to be installed out of the duct & only odour disinfectant with riders to be injected using flexible tubing not more than 15 mm in duct carrying exhaust air. System / technology should be without any consumables, other than electricity. | | | | |
| | ITEM: EXO - OXY - 200 HSN Code: 84213920 | | | | |
| | System Specifications: | | | | |
| 1.1 | Treatment Methodology : Capture & Treat | | | | |
| 1.2 | Technology : ECO + BOI | | | | |
| 1.3 | Applied Dose : 80 - 150 ppb | | | | |
| 1.4 | Make: Chemtronics | | | | |
| 1.5 | Made in: India | | | | |
| | | | | | |
| 2 | Accessories : Standard | | | | |
| 2.1 | Oxygen Concentrator | | | | |
| 2.2 | Backflow Preventor | | | | |
| 2.3 | Skid - SS - 304 | | | | |
| 2.4 | ECO + BOI Diffuser Fixture | | | | |
| 2.5 | Piping & Tubing | | | | |
| | | | | | |
| 3 | Installation & Commissioning supervision Charges are Free. To and fro air fare, free boarding lodging and local conveyance to your account. Installation and Commissioning Visit Details - 1 Day; If above 1 day it will be charged extra Per day per Engineer. | | | | |
| | | | | | |
| 4 | Standard Packing, Forwarding & Freight Charges | System | 1 | | |
| 5 | Total Value | System | 1 | | |
| 6 | GST on Total Value | % | 18 | | |
| | | | | | |
| 7 | Grand Total | System | 1 | | |