

Synopsis: Closed-Loop Active Compensation for Needle Deflection and Target Shift During Cooperatively Controlled Robotic Needle Insertion

Patrick Donelan, *Graduate Student, Worcester Polytechnic Institute*, Debbie Guenther, *Graduate Student, Worcester Polytechnic Institute*, Arjan Gupta, *Graduate Student, Worcester Polytechnic Institute*, and Will Yingling, *Graduate Student, Worcester Polytechnic Institute*

Abstract—The abstract by Will goes here.

Index Terms—IEEE, IEEEtran, journal, LATEX, paper, template.

I. INTRODUCTION

THIS demo file will be edited by Will. It is intended to serve as a “starter file” for IEEE journal papers produced under LATEX using IEEEtran.cls version 1.8b and later. I wish you the best of success.

mds

February 7, 2023

A. Subsection Heading Here

Subsection text here.

1) *Subsubsection Heading Here*: Subsubsection text here.

II. METHODS AND MATERIALS

Sample text inside input file for Part 1 of materials and methods.

A. Feature Localization

For evaluation of the closed-loop active compensation during cooperatively controlled needle insertions, we use two cameras to capture real-time images of the needle tip and target within the robot workspace. This is a suitable substitute for medical imaging, in fact the compensation technique is not dependent on the modality of the medical image. The two cameras are placed orthogonal to each other, and are run by a standalone software application.

In the software application, we employed Farnebäck’s algorithm [1] to execute on captured video frames to localize the moving needle tip and obtain homogeneous transformations of the tip and the target. We used a color segmentation technique to demonstrate the active compensation.

B. Active Compensation

Before any targeting takes place, registration is performed by rigidly attaching a marker to the robot. For example, we would attach the marker with MR visible fiducials when moving through an MRI machine. This is visually supported by Figure 1.

All authors are software engineers in their professional life.




Fig. 1. Frames and transformations for image guidance registration

After the registration is complete, the marker is removed. The OpenIGTLink [2] communication protocol is used to pass down the frame and transformations from image-guidance software to the robot controller. As seen by Figure 1, the transformation sequence $T_{Pose}^{Home-1} T_{Reg}^{Home-1} T_{Reg}^{Image-1}$ is used to express the registration with respect to the robot pose.

Throughout the insertion, the robot continuously receives the tip and target locations with respect to the image. Using the known transformation matrices, it determines the tip and target with respect to the robot pose. Naturally it can then compute the target location with respect to the tip, or T_{Target}^{Tip} . This tells us our desired compensatory effort.

To achieve this compensatory effort in all the insertion trials of our work, we chose to use Gang Li’s novel CURV model [3], where both magnitude and direction of the desired effort can be implemented. Assume that θ is the current rotational angle of the bevel, and θ_d is the desired angle of the bevel for compensation. At any angular position, we can use the following equation.

$$\hat{\omega}(\theta, \theta_d) = 1 - \alpha e^{-\frac{(\theta - \theta_d)^2}{2c^2}} \quad (1)$$

Equation 1 gives the angular velocity as a function of θ and θ_d . Here, widening the Gaussian width c gives a bigger range of angles where rotation occurs below the nominal velocity. Also, increasing the Gaussian magnitude α leads to more deflection in θ_d . The authors of this synopsis recommend referencing Gang Li’s excellent dissertation [3] for the angular velocity profile graph of CURV. While CURV was used in

this work, it is possible to use other bevel tip based curvature models.

III. RESULTS

Lorem ipsum dolor sit amet, consectetur adipiscing elit, sed do eiusmod tempor incididunt ut labore et dolore magna aliqua. Ut enim ad minim veniam, quis nostrud exercitation ullamco laboris nisi ut aliquip ex ea commodo consequat. Duis aute irure dolor in reprehenderit in voluptate velit esse cillum dolore eu fugiat nulla pariatur. Excepteur sint occaecat cupidatat non proident, sunt in culpa qui officia deserunt mollit anim id est laborum.

IV. DISCUSSION

The conclusion goes here.

APPENDIX A

PROOF OF THE FIRST ZONKLAR EQUATION

Appendix one text goes here.

APPENDIX B

Appendix two text goes here.

ACKNOWLEDGMENT

The authors would like to thank...

REFERENCES

- [1] G. Farnebäck, "Two-frame motion estimation based on polynomial expansion," in *Proceedings of the 13th Scandinavian Conference on Image Analysis*, ser. SCIA'03. Berlin, Heidelberg: Springer-Verlag, 2003, p. 363–370.
- [2] J. Tokuda, G. S. Fischer, X. Papademetris, Z. Yaniv, L. Ibanez, P. Cheng, H. Liu, J. Blevins, J. Arata, A. J. Golby, T. Kapur, S. Pieper, E. C. Burdette, G. Fichtinger, C. M. Tempany, and N. Hata, "Openiglink: an open network protocol for image-guided therapy environment," *Int J Med Robot*, vol. 5, no. 4, pp. 423–34, 2009 Dec 2009.
- [3] G. Li, "Robotic system development for precision mri-guided needle-based interventions," 2016.

PLACE
PHOTO
HERE

Debbie Guenther Biography text here.



Arjan Gupta Arjan Gupta is an embedded software engineer employed by Lindsay Corporation. He graduated from the University of Kansas in May 2017 with a Bachelor of Science in computer engineering and a minor in mathematics. He is currently pursuing his Master of Science in robotics engineering at Worcester Polytechnic Institute.

PLACE
PHOTO
HERE

Will Yingling Biography text here.

PLACE
PHOTO
HERE

Patrick Donelan Biography text here.