Brief Introduction
ooo

traing and test of CNN
oooo

Summary
ooo

Noise Spectrum and Photon Response of MCP-PMT

– based on the onsite PMT testing data

Email： zhaor25@mail2.sysu.edu.cn

School of Physics

Brief Introduction
○○○

traing and test of CNN
○○○○

Summary
○○○

Outline

❶ Brief Introduction

❷ traing and test of CNN

❸ Summary

traditional methods of PDE evaluation

Calculate the expected p.e by "cut" or "fiting" of chagre spectrum.


图: "cut" the charge spectrum to count pedestal events

图: fit using a PMT photon response model

Brief Introduction
○●○

traing and test of CNN
○○○○

Summary
○○○

CNN

CNN can perform a powerful PSD and classify the waveforms, then we could get explicit p.e during one test.

图: tags of typical waveform from CNN


图: classification of events in one test

Brief Introduction
○○●

traing and test of CNN
○○○○

Summary
○○○

the expected photon number

If we do a "cut" is the charge spectrum@0.25 spe, the averager photon number μ can be acquired by[1]

$$\mu = -ln(\frac{N_0}{N}) \tag{1}$$

where N_0 is the number of pedestal(0 p.e) events, N is the total event number.

However, if we know explicitly the photon number of specific event, the μ value is :

$$\mu = 1 \times n_1 + 2 \times n_2 + \cdots + N \times n_N \tag{2}$$

where n_N is the number of N p.e events.

---

[1]E. H. Bellamy et al /Nucl. Instr. and Meth. m Phys . Res. A 339 (1994) 468-476

Brief Introduction
ooo

traing and test of CNN
●ooo

Summary
ooo

input of CNN

training data slecetion and
pre-process:

- random selection from
  different PMTs
- 1.5<QDC<1.7 for 1p.e
- 3.1<QDC<3.3 for 2p.e
- 4.7<QDC<4.9 for 3p.e
- 81ns ROI $\rightarrow$ 9×9 2D image
- normalization

Brief Introduction
○○○

traing and test of CNN
○●○○

Summary
○○○

CNN parameters

- 30k training waveform samples
- 2 convolution layers
- 4 output tags
- accuracy$\simeq 0.95$

图: input data

Brief Introduction
○○○

traing and test of CNN
○○●○

Summary
○○○

results of cnn

图: HAMAMATSU PMT

Brief Introduction
○○○

traing and test of CNN
○○○○●

Summary
○○○

results of cnn

图: NNVT PMT

summary

- PSD by CNN provide a new option for PDE evaluation.
- can achieve *sim*0.95 acuuracy with the traditional method using simple NN.
- much faster than traditionl methods in PDE evaluation.
- CNN can ectract more infromation from waveforms.

to list:

- refine the training samples and network structure.
- compare the accuracy in more details, for example using the reference tubes in container system.
- improve the input data quality.

Brief Introduction
○○○

traing and test of CNN
○○○○

Summary
○●○

THANKS

Brief Introduction
○○○

traing and test of CNN
○○○○

Summary
○○●

BACK-UP