

# **AI on the Grid**

## **An NI4AI Workshop**

**October 21, 2020**

# Course Overview

---

- Day 1 of 2 day course
  - Day 1: PMU Fundamentals
  - Day 2: Intro to AI
- Logistics
  - Day 2 will use the NI4AI platform
  - Sign up for a login [ni4ai.org](https://ni4ai.org)
  - Q&A on [www.slido.com](https://www.slido.com)
  - Event code #M053

# Opening Remarks

---

This course is put on by an initiative called NI4AI

A National Infrastructure for AI on the Grid

In addition to this workshop, NI4AI provides ...

- A data platform
- Open access data
- Skills development
- Collaboration opportunities
- Research ideas
- Panel discussions
- Coding challenges
- Hackathons
- Research talks
- Blog posts

**Subscribe for updates** <http://eepurl.com/he8jtj>

# Agenda

---

Day 1

## **Understanding PMU Data**

*Alexandra "Sascha" von Meier  
(UC Berkeley)*

## **Case Studies & Lessons Learned**

*Kevin Jones  
(Dominion Energy)*

## **Get Practice and Learn More**

*Laurel Dunn  
(NI4AI)*

Day 2

## **Big Data & Prediction**

*Sean Patrick Murphy  
(PingThings)*

## **Interfacing with Sensor Data**

*Chris Ryan  
(PingThings)*

## **Use Cases & Analytics**

*Mohini Bariya and Miles Rusch  
(UC Berkeley)*

# Understanding PMU data

*Alexandra “Sascha” von Meier*  
UC Berkeley



## Types of grid measurement data

Advanced Metering Infrastructure (AMI)

*kW and kWh consumption at customer meters,  
typically reported at 15-min resolution*

Supervisory Control and Data Acquisition (SCADA)

*Voltage or current magnitudes, reported at resolution  
on the order of several seconds*

Phasor Measurement Units (PMUs)

*Voltage or current magnitudes and phase angles,  
frequency and derivative quantities,  
reported roughly each cycle (25-120 Hz)*


Event-triggered Point-on-Wave (POW)

*256 to 1 million samples/sec of voltage or current  
waveform, reported for a short duration or on a  
continuous monitoring basis*


Continuous Point-on-Wave (CPOW)

For more, see: A. Silverstein and J. Follum: High-Resolution, Time-Synchronized Grid Monitoring Devices  
[https://naspi.org/sites/default/files/reference\\_documents/pnnl\\_29770\\_naspi\\_hires\\_synch\\_grid\\_devices\\_20200320.pdf](https://naspi.org/sites/default/files/reference_documents/pnnl_29770_naspi_hires_synch_grid_devices_20200320.pdf)

# Time scales for electric grid events and control



## Example: High-resolution voltage magnitude measurements in distribution systems



Voltage magnitudes on three phases, reported by micro-PMUs at 120 Hz  
Blue: Berkeley, CA, Red: Alameda, CA  
(ca. 20 km away via 115kV transmission)

### ***Use case examples***

*Identify high-impedance faults*

*Diagnose PV inverter trips*



*Determine connectivity by correlation:*


- ABC phase
- open/closed switch status

# Phasor Measurement Data a.k.a. Synchrophasors

*Phasor measurements of alternating current or voltage quantities give an abstract image of what is happening physically, based on an implicit model.*

*The phasor representation is synthesized from (many) raw analog measurements in a lossy compression algorithm.*






## Time Domain vs. Phasor Domain


*The sinusoidal function in the time domain*

$$v(t) = V_{max} \cos (\omega t + \phi)$$

*is written as the phasor*

$$V = |V| e^{j \phi}$$





## Getting to Phasor Notation

We assume a waveform is represented by a pure sinusoid:

$$v(t) = V_{max} \cos(\omega t + \phi)$$

Now we imagine that we are looking at the real part of a complex quantity

$$v(t) = \operatorname{Re}\{\mathbf{v}(t)\}$$

where  $\mathbf{v}(t) = \cos(\omega t + \phi) + j \sin(\omega t + \phi)$

$e^{jx} = \cos x + j \sin x$



Using Euler's equation, we format this as a complex exponential:

$$v(t) = \operatorname{Re}\{V_{max} e^{j(\omega t + \phi)}\} = \operatorname{Re}\{V_{max} e^{j\omega t} e^{j\phi}\}$$

For steady-state analysis, assuming we already know everything about frequency, we discard the "rotating phasor" and keep only the "stationary" exponential term with the phase angle:

$$v(t) = \cos(\omega t + \phi) \Rightarrow \mathbf{V} = V_{rms} e^{j\phi} = V_{rms} \angle \phi$$


Finally, in power engineering convention, we use the root-mean-square (rms) magnitude instead of the amplitude.



*Displaying waves as a phasor snapshot in time  
allows easy comparison – assuming everything is  
at the same frequency!*

$$v_1(t) = V_{1,max} \cos(\omega t + \phi_1)$$


$$v_2(t) = V_{2,max} \cos(\omega t + \phi_2)$$




*Measuring relative to a GPS clock, if the a.c. frequency is not exactly constant at 60.000 Hz, we will see the phase angle from a single measurement increasing and decreasing over time, wrapping around from +360 or -360 to 0°*

*In the steady state, phasors have physical meaning only as a difference between two locations.*

## Phasors on time-series display





*Measuring relative to a GPS clock, if the a.c. frequency is not exactly constant at 60.000 Hz, we will see the phase angle from a single measurement increasing and decreasing over time, wrapping around from +360 or -360 to 0°*




*In the steady state, phasors have physical meaning only as a difference between two locations.*


# The need for synchronization



# Phasor Measurement Units (PMUs)




*Crucial piece of technology:  
shared time reference*



**synchronous  
data**

## **useful real-time information for system operators**

# Time resolution for PMU measurements



*at 60 Hz*  
*sec*

*1 cycle  $\approx 0.016$*

*$0.1^\circ \approx 4.6 \mu\text{s}$*

## Describing phasor accuracy (or precision)




Figure courtesy of Harold Kirkham, PNNL

*Standard performance criterion for PMUs in the transmission system:*

*Total Vector Error (TVE)*

*$\pm 1\%$  of magnitude,  
projected as the radius of a circle*

## Total Vector Error: A Closer Look




Figure courtesy of Harold Kirkham, PNNL

Standard performance criterion for PMUs in the transmission system:

$\pm 1\%$  of magnitude,  
projected as the radius of a circle

$$\epsilon_\varphi = \sin^{-1} \left( \frac{1}{100} \right) = 0.573^\circ$$

Note: transmission-grade PMUs cannot resolve steady-state voltage phase angle differences in small distribution systems.

## Building some physical intuition


- AC frequency is (approximately) the same everywhere across a synchronous grid
- Synchronicity comes from rotating machines, electromagnetically coupled
- Imbalances in power generation vs. load make system frequency increase or decrease
- Local power injection or withdrawal can be visualized like a twist on a common rotating shaft
- Torque or twist drives power across the common shaft, analogous to voltage phase angle






Voltage phasor differences drive power flow across the grid

# Voltage phase angle contour map



**Voltage phasors are the state variables for the power network**




*Real and reactive power  $P_i$  and  $Q_i$  at the  $i^{th}$  bus  
are determined by all the  $V$ 's and  $\delta$ 's*

*Power flow across the network is described by a profile of voltage phasors*

*P depends more on  $\delta$ , Q more on V*


# Voltage phasor differences drive power flow across the grid

1




$$P_{12} \approx \frac{V_1 V_2}{X} \sin \delta_{12}$$


*Distance (impedance) matters:  
the farther you transmit a.c. power, the  
larger the voltage phase angle  
difference, and the more wobbly*



## Small-scale example: Voltage phase angle shift along a 12kV distribution circuit




# Voltage phasor differences drive power flow across the grid



*The phase angle difference  $\delta$  between locations drives a.c. power flow*



$$P_{12} \approx \frac{V_1 V_2}{X} \sin \delta_{12}$$



*Power flows from Unit 1 toward Unit 2*

## Thinking about the physics of angle stability

- Power imbalance manifests as a change in angle  $\delta$  and frequency  $\omega$
- Electromagnetic coupling provides negative feedback on rotor position:  
Power injected to the grid by a generator  $P_e$  is a function of  $\delta$
- Rotational inertia tends to hold  $\omega$  steady





Generator swing equation

$$M \ddot{\delta} + D \dot{\delta} = P_m - P_e(\delta)$$

# Thinking about the physics of angle stability


*Voltage angle is a key variable, but it was not directly observable without PMUs!*




Generator swing equation

$$M \ddot{\delta} + D \dot{\delta} = P_m - P_e(\delta)$$

## Example: Generator and transmission line trip event



## Example: Generator and transmission line trip event




## Example: Frequency oscillations after a sudden loss of generation

green: Southern California, near lost generator


black: Washington State

blue: Alberta, Canada


red: Alberta, Canada



time in seconds



frequency contour



*We didn't know about these before PMUs...*



Alberta  
0.4 Hz

East-West  
0.6 Hz

North-South  
0.25 Hz

California-Desert  
Southwest 0.5 Hz


## What if the signal is not strictly a cosine?



*Harold Kirkham, PNNL: "The Measurand:  
The Problem of Frequency."*

*PMUs still give valuable insight, but their outputs are not obvious to define.*

## What if the signal is not strictly a cosine?



courtesy of Harold Kirkham

*The PMU answers the question,  
“If this signal were a cosine, what would its amplitude, frequency and phase be?”*

## What if the signal is not strictly a cosine?

---

$$x(t) = X_m \cos(\omega t + \varphi)$$

$$x(t) = X_m \cos\left\{\left(\omega' + \frac{C_\omega}{2}t\right)t + \left(\varphi' + \frac{C_\varphi}{2}t\right)\right\}$$

*Allowing for  $\omega$  and  $\varphi$  to vary in time*


$$x(t) = X_m \cos\left\{\left(\omega' + \frac{C_\varphi}{2} + \frac{C_\omega}{2}t\right)t + \varphi'\right\}$$

*Grouping terms*

*Harold Kirkham, PNNL:  
"The Measurand: The Problem of  
Frequency."*

*There is more than one way to define frequency, phase, and rate of change of frequency (ROCOF).*

## Interesting times...



*Blue Cut Fire Incident, 2016:  
Inverters calculated frequency  
differently than might have been  
expected, and tripped offline.*

*NERC, "1,200 MW Fault Induced Solar  
Photovoltaic Resource Interruption Report,"  
June 2017*

*Observing and understanding the electric grid at increasingly higher resolution  
in space and time is increasingly important.*

# Case Studies & Lessons Learned

*Kevin Jones, PhD*  
Dominion Energy



Oct. '09 - Oct.  
'20

# Looking Back Over 10+ Years

- **2009** – Kicked off synchrophasor initiative; DOE SGIG Kickoff
- **2012** – Began standardized Relay-PMU sensor deployment
- **2013** – DOE SGIG Demonstration
  - Linear State Estimator v1.0 released as OSS
- **2014** – CERTS Synchrophasor Data Conditioning and Validation Project
- **2015** – DOE FOA970 Kickoff
- **2017** – DOE FOA970 Demonstration
  - Linear State Estimator v2.0
- **2017** – DFR PMU Conversion Begins
  - Towards total transmission system coverage
- **2018** – Analytics Journey Begins
  - High performance sandbox for use case development
- **2019** – Go-Live of Cloud-Hosted PingThings' Platform
- **2020** – Leaning into Data Analytics

2018

# Hitting the Wall



# A Path Forward for Synchrophasors

*We must drive down the cost of working with data!*

## THE RIGHT TOOL FOR THE JOB


High resolution time series (e.g. synchrophasors) is a special comp. sci problem • Big Data technologies evolved towards specialization • Not all time-series DBs are equal • Historians make data history • Data at rest stays at rest

## NO SINGULAR “KILLER APP”; ENSEMBLE INSTEAD

The literature is full ( $10^3$ s) of proposed applications • Each utility may have niche use cases • Value prop. of individual use cases is myopic

## ANALYTIC EXPERIMENTATION >> A PRIORI “GUESSES”

We need to use lean methodologies, not guesses that play out over years, to arrive at our highest valued use cases



# A Fork in the Road. . .



## Technology

- First-Principles Approach
- Platform vs Siloed Applications
- Cloud vs On-Prem

## Engineering vs Real-time Operations

- Rapid prototyping & integration
- Quicker ROI for synchrophasors

## Capital vs O&M

- Larger company/societal impact

# PingThings` PredictiveGrid Platform




## PREDICTIVEGRID IS A PLATFORM-AS-A-SERVICE

This means we pay an annual subscription as an *all-in-cost* for:

- All Platform Features
- Infrastructure
- Maintenance
- Scheduled Upgrades
- Security
- Services

The combination of best-in-class tech, hosted in the cloud, and supported by a world-class team allows us to achieve at a scale and pace that would be otherwise impossible.




*Zero to streaming data in under 4 months.*  
We can do more with less [people, time, and resources]  
with PingThings & PredictiveGrid.

# Human-Scale Data Exploration

YOU MUST LOOK AT YOUR DATA!

Any data,  
at your fingertips,  
instantly, fluidly.



```
{  
  "annotations": {  
    "acronym": "VPHM",  
    "description": "Bath County DFR 1 CH 30: Valley 548 Ecn",  
    "devacronym": "DFR!BATH COUNTY_DFR_1",  
    "enabled": "true",  
    "equipment": "Line",  
    "id": "9d53aae7-ab34-4d1c-a7ea-e7a7484757fd",  
    "internal": "true",  
    "label": "Bath County Valley 548 Ecn",  
    "original_uuid": "8212c3d1-bc50-53a4-a535-7375c35c72e0",  
    "phase": "C",  
    "receiving": "Valley 548",  
    "reference": "DFR!BATH COUNTY_DFR_1-PM30",  
    "sample_rate": "30"
```

# Data Exploration: A Case Study

Fault Analysis is a heavy user of Mr. Plotter.

## RAPID EVENT ANALYSIS

**Problem:** Event analysis is tedious and time consuming – delaying restoration time. 45-60 minutes per event to visualize and analyze the data.

**Solution:** Mr. Plotter makes this instantaneous and flexible (multiple locations at once) saving critical time and answer key questions during critical restoration activities.

**Opportunity:** 87 events in the last 365 days

## EVENT DATA REQUESTS

**Problem:** Generation often waits 45+ days to ask for event data but DFRs only store data for 30 days.

**Solution:** PredictiveGrid saves data forever and Mr. Plotter makes event data exports trivial.

**Opportunity:** ~20 events each year – mostly storm season for critical locations like Surry, North Anna, Greenville.

*“The plotter was worth the cost of admission ... because it makes the data real.”* -Brian Starling

# Rich, Programmatic Access

## PREDICTIVEGRID DRIVES DOWN THE COST OF ANALYTIC DEVELOPMENT

- Ad-hoc Analytics & Experimentation
  - *Exploration*
- Rapid & Targeted Use Case Development
  - *Exploitation*
- Great for Exploration and Exploitation.
- Great for beginner, intermediate, and advanced users.

jupyter PreprocessingData Last Checkpoint: 2 hours ago (autosaved) Logout Control Panel Trusted Python 3 Memory: 651 / 8192 M

**Filtering**

Since we are analyzing ambient data, slow moving operating point changes are the only "big" changes we see in the measurements. These need to be removed (typically using a high pass filter) in order to "see" the underlying oscillations clearly. Furthermore, depending on the frequencies of interest, it is a normal practice to remove higher frequency components from the data so that only the oscillations we care about are there in the signal and thus easy to identify. This is achieved through a carefully tuned low pass filter.

In this notebook, we are interested in oscillations from 0.5-2 Hz and therefore choose our filter cutoffs accordingly.

**Down Sampling**

Once high frequency dynamics are filtered, its a common practice to down sample (using Shannon's Theorem (sampling frequency  $\geq 2 \times$  max frequency)) since overly fast sampling results in successive samples being nearly identical which at times brings ill conditioning issues to the analytics being performed.

```
In [13]: f_filter = [0,2,3] # filter range
Vmdatagrid_filter = butter_filter(Vmdatagrid,'high',f_filter[0],fs) #detrend
Vmdatagrid_filter = butter_filter(Vmdatagrid_filter,'low',f_filter[1],fs) #denoise

# Down Sample
fs_re = 2*f_filter[1] # downsample (twice of highest frequency)
tdata_re = np.arange(tdata[0],tdata[-1],1e9/fs_re) # new time samples
Vmdatagrid_filter = [resample_data(Vmdatagrid_filter[i],tdata,tdata_re) for i in range(len(Vmdatagrid_filter))]
```

```
In [15]: plt.figure()
plt.plot(tdata,Vmdatagrid[0])
plt.title('Original Voltage Magnitude')
plt.figure()
plt.plot(tdata_re,Vmdatagrid_filter[0])
plt.title('Filtered Voltage Magnitude')
```

```
Out[15]: Text(0.5, 1.0, 'Filtered Voltage Magnitude')
```

Original Voltage Magnitude

# Our Team



Chetan Mishra, Ph.D.  
*Data Analytics Lead*



Chen Wang, Ph.D.  
*Data Analytics, Data Eng.*



Hesen Liu, Ph.D.  
*Data Analytics, Data Eng.*



Duotong Yang, Ph.D.  
*Modeling*



Benjamin Diller  
*Technology, Data Eng.* (*Joining Soon*)



Xin Xu  
*Data Analytics* (*Joining Soon*)




Marcelo de Castro Fernandes  
*Data Analytics Intern, Summer 2020*



Xianda Deng  
*Data Analytics Intern, Summer 2020*


# Promising Use Cases



# Beyond Synchrophasors

- Upload from UI
- Automated uploads from Sixth Man

COMTRADE  
Event Files



- Bulk historical uploads
- Synchronous updates
- From PI

Historical  
SCADA

- 10 Minute Network Snapshots from ANODE


Network  
Model /  
Snapshots

Future??

PingThings'  
Predictive  
Grid

# Today: Small Signal Analysis Case Studies

- Richness of ambient data
- Our homegrown toolbox is growing; dozens of techniques
- Must consider **system level** behaviors under **all operating conditions** across **months of history**
- This analysis requires working at a scale only made possible by PingThings` PredictiveGrid



# Recent Case Studies

And what they mean to Dominion and the industry...

# 1: Regional Industrial Dynamics

## Case Study: The Need to Improve Grid Models

### MOTIVATION


Distribution no longer passive • Regional dynamics influence integration of new devices • Avoid unwanted interactions • Solar and industrial use power electronics • Existing modeling practices overlook such dynamics

### OBSERVATIONS

“Stumbled” onto interesting dynamics in voltage magnitude • Found poorly damped modes varying rapidly between 0-15 Hz • Nearby polymer plant and pet food plant have frequent customer complaints

### TAKEAWAYS

Dynamics not reflected in models • Stumbling onto this implies many other locations with unaccounted dynamics • Matters when connecting other power electronic devices like solar



# 2: Regional Solar Dynamics

Case Study: The Need to Improve Grid Models & Analyses

## MOTIVATION


- Distribution no longer passive • Regional dynamics influence integration of new devices • Avoid unwanted interactions • Solar and industrial use power electronics
- Existing modeling practices overlook such dynamics

## OBSERVATIONS

- Sustained 8Hz oscillations observed at multiple locations • Invariant with operating conditions • From sunrise to sunset...solar! • Source identification through mode shape analysis of multiple locations • Confirmed solar plant

## TAKEAWAYS

- Dynamics not reflected in models • Solar interconnections will grow, exponentially increasing the likelihood of interactions • Needs to be accounted for during interconnection process



# 3: STATCOM Controller Dynamics Pt. 1

## Case Study: Performance Assessment of FACTS

### MOTIVATION


Investment in FACTS • Our duty to validate performance, suggest fixes, and influence future design • Feb 2019: topology change led to sustained oscillation • Found to be due to NSC • Deenergize control during low system strength.

### OBSERVATIONS

Spectral analysis shows 2-3 modes from 0-3Hz • Modes become poorly damped under certain conditions • Damping estimated over many days showing negative correlation with system loading

### TAKEAWAYS

Controller design didn't account for these system conditions • Need for adaptive gain adjustment hypothesized • Desire to validate hypothesis in the field



# 4: STATCOM Controller Dynamics Pt. 2

## Case Study: Performance Assessment of FACTS

### MOTIVATION



Investment in FACTS • Our duty to validate performance, suggest fixes, and influence future design • Sep 2020: STATCOM tested for NSC and NLS and multiple gain settings (100-70-50%) • Perfect *in-vivo* experiment to validate our observations.

### OBSERVATIONS

Poorly damped modes at 100% gain virtually gone at lower gains • NLS can be observed as a limiting factor for effective regulation during ambient conditions

### TAKEAWAYS

Confirms the need for adaptive gain • Confirms the need to validate performance of FACTS assets



# 5: STATCOM Controller Interactions

## Case Study: Performance Assessment of FACTS

### MOTIVATION


Investment in FACTS • Our duty to validate performance, suggest fixes, and influence future design • Neighboring STATCOMs may interact

### OBSERVATIONS

“Stumbled” onto poorly damped 1Hz V&I mode while baselining a region preparing for wind integration • Mode shape shows two STATCOMs participating 150deg+ out of phase

### TAKEAWAYS

STATCOMs can interact • Need for coordinated control  
• There are 4 STATCOMs, not 2 so need to expand study  
• Study still ongoing



# 6: SVC Dynamics

## Case Study: Performance Assessment of FACTS

### MOTIVATION



Investment in FACTS • Our duty to validate performance, suggest fixes, and influence future design

### OBSERVATIONS

6Hz poorly damped modes observed • Randomly vanish throughout the day • Showed to be characteristic of Q control mode of SVC • Local generation setpoint change pushed voltage out of bounds of SVC, activating V control mode and eliminating oscillation

### TAKEAWAYS

Interactions with other diverse, local assets can create unexpected interactions



# 7: Hydro Plant Dynamics

## Case Study: Data + Models for Diagnostic Analyses

### MOTIVATION



- How to mitigate oscillator behavior observed in data? •
- For local issues, usually a controller design issue • Data alone insufficient to create new control • Recreate phenomena in simulation • Use data to improve models
- Use models to identify mitigation

### OBSERVATIONS

- During plant operation, a [poorly damped 2Hz mode](#) is present • A modified model reproduces the oscillation in simulation • Sensitivity analysis then yields the appropriate control parameters to change

### TAKEAWAYS

- Gain of derivative block found to be most effective •
- Models can be manipulated to reproduce, diagnose, and identify suggested changes to mitigate observations from data • Implies a deeper synergy between data + models



# 8: Impacts of Arc Furnace



Case Study: Working with Real Data

## ABOUT

Arc Furnace (1) melts (orange box – higher variance, non-homogenous metal, varying Z), and (2) refines (blue box outside of orange box - less variance, constant Z)

## OBSERVATIONS + TAKEAWAYS

Impacts of Arc Furnace can be observed daily across the system • Aggravates FACTS devices • Cannot assume linearity • Must be compensated for in analysis of other dynamics



# 9: Nuclear Gen & Gas Gen Dynamics

## Case Study: Going Beyond Synchrophasor Data

### MOTIVATION


Observations in synchrophasor data are sometimes insufficient for diagnosis • How to leverage increased phasor reporting rates and waveform data to dive deeper?

### OBSERVATIONS

Original observation as <1Hz modes at nuclear plant GSU in phase angle w/r/t system • More prominent during summer • Hypothesized subsynchronous resonance/shaft dynamics • Triggered by combination of plant setpoint + grid condition • Strange symmetry • Similar observations at gas plant • 60Hz phasor data and waveform data imply hypothesis is correct because of higher frequency oscillations

### TAKEAWAYS

Sampling minutes of waveform data over days can help dive deeper when lower res data suggests the need • Study still ongoing to learn vs modes and grid state + plant setpoints • Will resume once we have mechanical measurements



# Metabolizing the Results

- Yes – it still takes time to turn these observations into business outcomes
- Yes – We're just getting started. Lots of left to explore/exploit.  
This will keep my team employed for 10+ years ;)
- But – there is now be no question of the value of **synchrophasors**, the **right data analytics tools**, and **investing in these competencies**.

# Why Does This Matter?

Consider a future where...



## INCREASED RENEWABLES

Exponentially increases the likelihood of undesirable device interactions.



## INCREASED DYNAMIC COMPENSATION DEVICES

As a key enabler of renewable integration, design must consider actual small signal characteristics.



## LIMITATIONS ON TRADITIONAL SOLUTIONS

New technologies will be required, data analytics can compensate for uncertainty.



## NEED FOR MULTI-MODAL INVESTMENT JUSTIFICATION

Data will become a necessary part of the simulation/model-based investment proposal process.



## GROWING WORKFORCE OF TECH-SAVVY ENGINEERS

Talent will be available to build data teams



# More Specifically. . .

## MODELING

Data and models are deeply synergistic.  
Data can be used to improve models and  
models can be used in a diagnostic fashion  
when field observations are made.

## PLANNING

Data greatly augments our ability to  
identify and refine proposals for  
improving the grid.

## DESIGN

Design of our assets will need to take  
into consideration actual system  
conditions observed at their planned  
installation location.

## INTERCONNECTIONS

Data driven small-signal analysis will  
need to become part of the  
interconnection analysis process.

# A New Competitive Advantage



## GROWTH OPPORTUNITIES

Competencies in grid data analytics such as those at Dominion Energy will become a **competitive advantage** for utility companies: improving **regulatory approval** and **access to affordable capital**.



## PANDORA'S BOX

Pandora's box is now open – now that it is known what is possible, it won't be long until it becomes a **de-facto standard**, perhaps even a **requirement**.



# A New Utility



- Unification of Physics + Data
  - Data Flows • Power Flows
- More Capital Efficient
  - Financial Capital • Human Capital
- Greater Adaptability

# A Fork in Your Road...



- The path is clear – start today.
- Questions?
  - [kevin.d.jones@dominionenergy.com](mailto:kevin.d.jones@dominionenergy.com)
- NASPI: [naspi.org](https://naspi.org)
  - Virtual Conference Nov 3-5
- NI4AI: [ni4ai.org](https://ni4ai.org)

# Graduate Student Internship Program

- Dominion hires graduate student interns each summer to work on exciting and challenging projects.
- Dozens have come in through the program, many are now full-time engineers at Dominion.
- The program has been active for over 10 years.
- Currently, we take ~10 students across all of T&D per summer.
- Applications for next summer are currently posted soon on the Dominion Careers website.



# Get Practice and Learn More

*Laurel Dunn*

NI4AI



# About NI4AI

---

**Short for:** National Infrastructure for AI on the grid

**About:** 3-year ARPA-E project funded under Open Innovation 2018


**Our goal:** Advance the use of AI in the industry

**Approach:** Eliminate barriers to analyzing grid data

**Project pillars:**

1. Provide access to a state-of-the-art data PLATFORM
2. Create DATA that analysts can readily use
3. Build COMMUNITY committed to developing new analytics

# Project Pillars



**Data**

**Platform**

**Community**


# The Platform

## PingThings' PredictiveGrid™

- Cloud-based platform
- Optimized for time series data
- Built for utilities
- Available to NI4AI users

## Provides

- Data visualization
- API access (Python & Julia)
- Collaboration tools



# Demo of Platform

---

<https://www.youtube.com/watch?v=cqnaSlqPuGU>

# Learn more about the platform

---

**Day 2 of this workshop**

**Python API documentation**

<https://btrdb.readthedocs.io/en/latest/>

**Blog posts tagged “set-up”**

<https://blog.ni4ai.org/tags/set-up/>

**Blog posts tagged “analytics” include code you can use**

<https://blog.ni4ai.org/tags/analytics/>

# The Data


**Open access** data

Collected by **real sensors**

**National coverage** of the grid

Captures **interesting dynamics**  
relevant to users & stakeholders

- Experimental data
- Pilot projects
- Anonymized industry data



*Have data you want analyzed?*

Contact [info@ni4ai.org](mailto:info@ni4ai.org)

# Datasets currently available to you

---

	Collections	Sensors	Duration	Features of interest
<b>Real-time</b>	ni4ai/ texas_pmus/	5	April-now	Real-time streaming data
<b>Point on Wave</b>	epfl/	3	6 events	Battery charging & discharging
<b>Wide Area Events</b>	transmission_events/	23	3 events	Switching events Oscillation
<b>Archive</b>	sunshine/	6	18 months	Distribution feeder with a PV array


[plot.ni4ai.org](http://plot.ni4ai.org)

# The Community

---

## Made up of ...

- Practitioners
- Researchers
- Students
- Utilities
- Vendors
- Hardware/sensor providers
- Anyone interested in grid data



# The Community

---

## How to engage

1. Use the platform
2. Attend workshops
3. Follow the blog
4. Do the exercises
5. Participate in competitions
6. Ask questions
7. Build your network
8. Make new collaborations
9. INSERT YOUR IDEA HERE



# Attend workshops

## 2020 Event & Conference Listing

Show 10 entries

Search:

Event	Dates	Location	Website
CIGRE Academy Webinar: PMU Fundamentals	October 21, 2020	Virtual	
CIGRE Academy Webinar: Intro to AI	October 28, 2020	Virtual	
NASPI Fall Working Group Meeting	November 3, 2020	Virtual	<a href="https://www.naspi.org/node/794">https://www.naspi.org/node/794</a>
IEEE SmartGridConn	November 11-13, 2020	Virtual	<a href="https://sgc2020.ieee-smartgridcomm.org/">https://sgc2020.ieee-smartgridcomm.org/</a>

[ni4ai.org/events](http://ni4ai.org/events)

# Follow the blog

Resources for Learning More   Data Sharing   Language Support

Home About Blog Team Events Contact Username Password Create an Account

Interacting with Data using "The Plotter"

v2.6.0-beta.2 build: release 2.6.0-beta.2  
build: build 2.6.0-beta.2  
test: dynamic directives arguments for v-on, v-bind and custom directives (19937)  
v1: original dynamic directive arguments / test: dynamic args for custom directives part: improve scoped slots change detection accuracy (199371)  
test: test cases for v-on/v-bind dynamic arguments  
refactor: v-bind dynamic arguments use bind helpers  
test: fix tests, resolve helper conflict

Training General Linear Models with the PredictiveGrid™

What's the Angle?

Magnitude

Angle

Input Signal and Fitted Model

Time (s)

Time (s)

Understanding PMU Angle Measurements

Mohini Bariya  
July 30, 2020

[blog.ni4ai.org](http://blog.ni4ai.org)

Tutorials

Exercises

Code

Research highlights

New ideas

Thought leadership

Event information

# Do the exercises

---

**“Do-it-yourself” exercises are designed for you to get practice asking questions of data**

- Assess data quality
- Monitor asset utilization
- Analyze grid frequency
- Quantify phase imbalance
- Locate disturbances

<https://blog.ni4ai.org/tags/do-it-yourself>

# Where you can go to learn more

---

## Follow developments in industry & research

- NASPI [www.naspi.org](http://www.naspi.org)
- CIGRE <https://cigre-usnc.org/>
- IEEE PES <https://www.ieee-pes.org/>
- PSERC <https://pserc.wisc.edu>
- PowerGlobe <http://listserv.nodak.edu/archives/Power-Globe.html>

## Follow NI4AI

Subscribe to the newsletter <http://eepurl.com/he8jtj>

Read the blog [blog.ni4ai.org](http://blog.ni4ai.org)

Look for announcements in PowerGlobe

# Thank you!

---

Contact us

[info@ni4ai.org](mailto:info@ni4ai.org)

Subscribe

<http://eepurl.com/he8jtj>

Upcoming Events

Oct 28 **Intro to AI**

Nov 3-4 **NASPI working group meeting**

Nov 11-13 **IEEE SmartGridComm**