

Site Name: Office of Chief Medical Examiner

Site Area: 120000 square foot

Site Type: Laboratory

Site EUI: 0.16282770 kBtu/square foot

EnergyStar Benchmark EUI: 115.30 kBtu/square foot

Site Energy Consumption: 19539.32 MMBtu

Source Energy Generation: 40367.90 MMBtu

Site Electricity Consumption: 11343.77 MMBtu

Site Gas Consumption: 8195.55 MMBtu

Site Oil Consumption: 0.00 MMBtu

Site Propane Consumption: 0.00 MMBtu

Site Water Consumption: 0.96 Gallon

Site Greenhouse Emission: 1483.37 Metric Tons

Site Savings Potential: 126949.50 Dollars

Energy Saving Potential: 11782.06 MMBtu

Greenhouse Gas Reduction: 432.96 Metric Tons