UK PERMITTED DEVELOPMENT CHECK (Class A, Part 1, GPDO)

Requirement	PD limit	Proposed	Status
Single storey rear extension - max depth (semi/terrace)	3.00 m	4.00 m	**CHECK**
Maximum overall height	4.00 m	2.70 m	**PASS**
Maximum eaves height	3.00 m	2.45 m	**PASS**
Roof materials to match / harmonise	-	Match existing	**PASS**
No verandas/balconies/raised platforms	-	None proposed	**PASS**
Not within a conservation area / AONB / listed	-	Assumed	**VERIFY**

DRAWINGS ISSUED

No.	Drawing title	Scale	Rev
00	Drawing register & PD check	NTS	P1
01	Location plan (schematic)	1:1250	P1
02	Proposed site / block plan	1:200	P1
03	Existing ground floor plan	1:100	P1
04	Existing first floor plan	1:100	P1
05	Existing elevations	1:100	P1
06	Proposed ground floor plan	1:100	P1
07	Proposed first floor plan	1:100	P1
08	Proposed elevations	1:100	P1
09	Proposed roof plan	1:100	P1
10	Proposed long section A-A	1:50	P1

NOTES

1. All drawings A3; do not scale - use figured dimensions only.
2. Read in conjunction with the planning application form and
3. the design & access statement.

PROPOSED SINGLE STOREY REAR EXTENSION

14 Example Road, Anytown, AB1 2CD

PROPOSED

REAR / SIDE EXTENSION

DRAWING REGISTER

SCALE		DRAWING No.	REV
NTS		**00**	**P1**
DRAWN	CHECKED	DATE	CLIENT
AI	—	October 2026	Mr & Mrs Sample