AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE OF PAGES

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER *(If applicable)*

6. ISSUED BY CODE	7. ADMINISTERED BY *(If other than Item 6)* CODE

8. NAME AND ADDRESS OF CONTRACTOR *(Number, street, county, State and ZIP Code)*

ISP GROUP LLC
16395 Biscayne Blvd Apt 818
Aventura, FL 33160-5743
UEI WA46PAMTYMQ7 CAGE 217F4

CODE FACILITY CODE

(X)

☐ 9A. AMENDMENT OF SOLICITATION NUMBER

9B. DATED *(SEE ITEM 11)*

☐ 10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED *(SEE ITEM 13)*

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☐ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☐ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	
☐	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: *(Specify authority)* THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES *(such as changes in paying office, appropriation data, etc.)* SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER *(Specify type of modification and authority)*

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (*Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER *(Type or print)*	16A. NAME AND TITLE OF CONTRACTING OFFICER *(Type or print)*
Aleksandr Orlov, Member	

15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		*(Signature of Contracting Officer)*	

1240LS26Q0079 – Manti-LaSal National Forest Culverts and Hardware

Q & A

Q: For CLINs 0001–0005, does the Government require a specific corrugation profile, such as 2-2/3" x 1/2", or may the contractor provide a manufacturer's standard corrugation profile meeting the stated diameter, length, 16-gauge, and galvanized CMP requirements?

A: FP-24 707.02 specifies that metallic-coated corrugated steel pipe must conform to AASHTO M 36, but it **does not require a specific corrugation profile** (e.g., 2-2/3″ × 1/2″). Therefore, the contractor may supply the manufacturer's standard corrugation profile, provided it meets the stated diameter, length, 16-gauge thickness, galvanization, and ends suitable for standard bands.

Q: Is there a specific ASTM, AASHTO, galvanizing, coating-weight, or material standard that the corrugated metal pipe must meet?

A: Per FP-24 Section 707.02 and 707.12:

- Corrugated steel pipe must conform to **AASHTO M 36**.
- Metallic coating must conform to **AASHTO M196, M 218, M 274, or M 289**.

Q: For CLINs 0006–0008, please confirm the required configuration/specification for the referenced "CMP Hugger Bands/Bolts," including whether a particular band width, gauge, bolt configuration, material, or galvanizing/coating requirement applies.

A: FP-24 Section 707 requires coupling bands consistent with AASHTO standards (**AASHTO M36 and AASHTO M196, M 218, M 274, or M 289)**. Contech's H-12 HUGGER Band is a typical FP-compliant solution:

- **Band width:** ~12″
- **Material:** galvanized steel (other coatings optional)
- **Bolt Configuration:** bolt-bar-strap connectors. O-ring gaskets are optional.
  - We would accept approved equal.

Q: The Schedule of Items describes the culvert ends as suitable for "standard bands," while CLINs 0006–0008 require "CMP Hugger Bands/Bolts." Please confirm that the specified hugger bands are intended to be compatible with and used with the culvert ends listed in CLINs 0001–0005, and whether any separate standard bands are required.

A: Yes—the specified hugger bands (e.g., Contech H-6, H-7, H-12) are designed to mate with rerolled annular pipe ends on CLINs 0001–0005. No additional "standard bands" are needed, as FP-24 directs coupling bands to be compatible with pipe ends under Section 707.

1240LS26Q0079 – Manti-LaSal National Forest Culverts and Hardware
Q: Please confirm whether multiple truckload deliveries and/or partial deliveries are acceptable, provided all required quantities are delivered within 60 calendar days after award.

A: FP-24 does **not restrict deliveries to single truckload shipments**. Unless the solicitation states otherwise, multiple and partial deliveries are acceptable—as long as all quantities are delivered within the **60-calendar-day** period post-award. This aligns with standard delivery terms under Federal contracts.

Q: Please confirm whether manufacturer technical data sheets demonstrating compliance with the specified diameter, length, gauge, galvanization, and compatible coupling/band system will be sufficient technical documentation for evaluation.

A: Yes—manufacturer-supplied technical data sheets that demonstrate compliance with the required **diameter, length, gauge, galvanization, and coupling/band system compatibility** will suffice as technical documentation for evaluation purposes.

Q: Please confirm whether any domestic-manufacturing or country-of-origin restrictions apply beyond the country-of-origin certification and applicable FAR 52.225 requirements contained in the solicitation.

A: The country of origin restrictions of FAR 52.225-3 and FAR 25.225-4 apply as well as the restrictions of PM "Restoring Reciprocity in Government Procurement" dated 9/16/2026. Canadian products will generally not be acceptable unless they are truly the only product that meets all quantity, quality, and technical requirements.

Q: Pipe specification. The Schedule of Items lists 16 gauge galvanized CMP with "ends for standard bands" but cites no standard. Will the Government accept helical corrugated steel pipe, 2-2/3 in x 1/2 in corrugation, with re-rolled annular ends, conforming to AASHTO M36 with AASHTO M218 galvanizing? If the Government requires a different profile, coating weight or standard, please name it.

A: Acceptable: helical corrugated steel pipe, 2-2/3″ × ½″ corrugation with rerolled annular ends, conforming to **AASHTO M 36** and **AASHTO M 218** galvanization

Q: Bands. For lines 0006 through 0008, what band width and type does the Government want (for example, 12 in corrugated hugger band for 18 in and 24 in pipe)? Are gaskets required?

A: Government requires annular "hugger" bands compatible with the pipe ends—typically **12″ wide H-12 style**, galvanized, with O-ring gaskets

Q: Band quantities. Line 0006 lists 15 bands for 30 pieces of 18 in pipe, line 0007 lists 60 bands for 120 pieces of 24 in pipe, and line 0008 lists 10 bands for 10 pieces of 36 in pipe. Please confirm these quantities are correct as written.

A: The CLIN line items match typical band-to-pipe counts (e.g., 15 bands for 30×18″ pipes); these are correct unless the contract plan specifies otherwise.

1240LS26Q0079 – Manti-LaSal National Forest Culverts and Hardware

Q: Deliveries. May the order arrive in more than one truckload within the 60 days, and what days and hours does the Price yard receive freight?

A: Multiple truckload shipments are acceptable within the 60-day window. Yard receiving hours should be confirmed with the contracting officer representative.

Q: Country of origin. Section 52.212-1 points to a country of origin table on page 8 of Attachment 1; the table appears under 52.225-4 on page 10. Please confirm the page 10 table is the one to complete.

A: Page 10 is the correct page to indicate country of origin for the items you offer in the table under 52.225-4.

Q: Payment. SF 1449 Block 18a is blank. Please confirm the payment office and the invoicing method (for example, IPP).

A: Invoicing shall be through IPP.gov.