INJAAZ FACILITY MANAGEMENT

HVAC & MEP Inspection Report

SITE / PROJECT	Test Site - Ajman Tower	2026-03-12
REFERENCE	HVAC-20260313	

Generated 13 March 2026 · CONFIDENTIAL

SITE INFORMATION

Site Name	Test Site - Ajman Tower
Visit Date	2026-03-12
Items Inspected	2
Total Photos	3
Generated	13 Mar 2026, 18:24 (GST)

INSPECTION ITEMS — 2

01

Chiller Unit A

HVAC

DESCRIPTION	Main chiller for building cooling	SPECIFICATION	500 TR
QUANTITY	1	COMMENTS	In good condition
BRAND	Carrier	PHOTOS	2

PHOTOS (2)





02

AHU-01

HVAC

DESCRIPTION	Air handling unit Floor 1	SPECIFICATION	10,000 CFM
QUANTITY	1	COMMENTS	Filter replacement recommended
BRAND	Trane	PHOTOS	1

PHOTOS (1)



SUPERVISOR REVIEW

Inspection completed. Minor maintenance required.

Supervisor Signature:	

Document signed on: March 13, 2026 at 18:24 (GST)