



# ArcticAir

BYO Cooling & Refrigeration

## CERTIFICATE OF COMFORMITY

# R507

PRODUCT NAME: REFRIGERANT GAS R507

WE HERE BY CERTIFY THAT THE ABOVE PRODUCT WAS TESTED AND FOLLOWING RESULTS HAVE BEEN OBTAINED.

ITEMS	SPECIFICATIONS	RESULT
Purity	$\geq 99.50\%$	99.90%
Moisture	$\leq 0.001\%$	0.0006%
Acidity(as Hcl)	$\leq 0.0001\%$	0.0001%
Evaporation residue	$\leq 0.01\%$	0.0006%
Non-condensable gases	$\leq 1.5\%$	0.7%

**CONCLUSION: CONFORMITY.**

浙江衢化氟化学有限公司  
ZHEJIANG QUHUA FLUOR-CHEMISTRY CO., LTD

(田) 蔡坤