



ArcticAir

BYO Cooling & Refrigeration

CERTIFICATE OF COMFORMITY

R134A

PRODUCT NAME: REFRIGERANT GAS R134A

WE HERE BY CERTIFY THAT THE ABOVE PRODUCT WAS TESTED AND FOLLOWING RESULTS HAVE BEEN OBTAINED.

| TEST ITEMS | UNIT | SPEC. | RESULTS |
|---|------|------------------------|-----------|
| APPEARANCE | | COLORLESS | COLORLESS |
| 1,1,1-2-TETRAFLUOROTHANE(R 134A)&R134 | % | 99.9MIN | 99.98 |
| ISOMER CONTENT | % | 0.2 MAX | 0.026 |
| WATER | PPM | 10 MAX | 6.78 |
| HIGH BOILING RESIDUE | % | 0.005 MAX | 0.005 |
| PARTICULATES/SOLIDS | | VISUALLY CLEAN TO PASS | PASS |
| ACIDITY | PPM | 1 | 0.13 |
| CHLORIDE | | PASS | PASS |
| AIR & OTHER NON CONDENSABLE IN VAPOR PHASE | % | 1.5 | 0.75 |

CONCLUSION: CONFORMITY.

浙江衢化氟化学有限公司
ZHEJIANG QUHUA FLUOR-CHEMISTRY CO., LTD

(田) 蔡坤