



ArcticAir

BYO Cooling & Refrigeration

CERTIFICATE OF COMFORMITY

R404A

PRODUCT NAME: REFRIGERANT GAS R404A

WE HERE BY CERTIFY THAT THE ABOVE PRODUCT WAS TESTED AND FOLLOWING RESULTS HAVE BEEN OBTAINED.

ITEMS	SPECIFICATIONS	RESULT
Purity	$\geq 99.80 \%$	99.94 %
Moisture	$\leq 0.001\%$	0.0005 %
Acidity(as Hcl)	$\leq 0.00001\%$	0.00001 %
Evaporation residue	$\leq 0.01 \%$	0.0003 %
Non-condensable gases	$\leq 1.5 \%$	NONE

CONCLUSION: CONFORMITY.

浙江衢化氟化学有限公司
ZHEJIANG QUHUA FLUOR-CHEMISTRY CO., LTD

(田) 蔡坤