

SAFE NUCLEAR POWER: INSTRUMENTATION, HUMAN OVERSIGHT, AND INFRASTRUCTURE TRANSITION

Arturo Salinas-Aguayo, *BS Computer Engineering, Class of 2027*

June 6, 2025

ECE 4900W: Communicating Engineering Solutions in a Societal Context

Dr. Shengli Zhou, SEC040-1255

Department of Electrical and Computer Engineering



University of Connecticut College of Engineering

Coded in L^AT_EX

Contents

ABSTRACT	3
I INTRODUCTION	4
II INSTRUMENTATION AND CONTROL (I&C) SYSTEMS	4
A. <i>Types of Plants</i>	4
B. <i>Reactor Monitoring Principles</i>	5
1) Thermal and Neutron Sensing.	5
2) Coolant and Moderator Instrumentation.	6
3) Control and Structural Monitoring.	6
4) Steam and Turbine System Sensing.	6
5) Integration with Digital Systems.	7
C. <i>Computerized Protection Systems</i>	7
III HISTORICAL LESSONS IN REACTOR SAFETY	8
A. <i>SL-1: The First Fatal U.S. Reactor Accident</i>	8
1) Sequence of Events	9
2) Root Cause Analysis	9
3) Engineering and Human Factors Implications	9
4) Aftermath and Lessons Learned	9
B. <i>Three Mile Island: Interface Confusion and Human Factors</i>	10
1) Sequence of Events	10
2) Design Oversights and Interface Failures	10
3) Human Factors and System Complexity	11
4) Legacy and Regulatory Reform	11
C. <i>Chernobyl and Reactor Design Faults</i>	12
1) Background and Test Scenario	12
2) Design Flaws and Positive Feedback	12
3) SCRAM-Induced Prompt Criticality	12
4) Core Destruction and Radiation Release	12
5) Operator Training and System Transparency	13
6) Aftermath and Human Toll	13
7) Legacy of Chernobyl	14
D. <i>Fukushima-Daiichi: Environmental Consequences</i>	14
1) Earthquake and Tsunami Impact	14
2) Station Blackout and Core Meltdown	15
3) Loss of Monitoring and Improvised Measures	15
4) Environmental and Human Consequences	15
5) U.S. Naval Involvement and Humanitarian Support	15
IV HUMAN FACTORS: THE ETHICAL DIMENSION OF AUTOMATION	16
A. <i>Human Factors Engineering</i>	16
B. <i>Operator Experience</i>	16

<i>C. Ethical Limits of Automation</i>	<i>17</i>
V ECONOMIC REALITIES AND INFRASTRUCTURE DECLINE	18
<i>A. Waste Management and Decommissioning Costs</i>	<i>18</i>
<i>B. Construction and Design of Future Plants</i>	<i>19</i>
<i>C. Migration from Nuclear to Renewable Energy Sectors</i>	<i>19</i>
<i>D. Integration Challenges and Opportunities</i>	<i>19</i>
VI CONCLUSION: A CAUTIOUS RETURN TO THE ATOM	20
REFERENCES	21

ABSTRACT

This paper investigates the evolving landscape of nuclear power through a comprehensive analysis of instrumentation and control (I&C) systems, historical reactor incidents, and the socio-economic infrastructure surrounding nuclear energy deployment. Drawing from first-hand experience with naval nuclear propulsion and supported by contemporary engineering literature, it examines the intersection of automation, human factors, and ethical oversight in reactor safety design. Case studies such as SL-1, Three Mile Island, Chernobyl, and Fukushima-Daiichi are revisited to illustrate the enduring role of the human operator and the limitations of technical systems in crisis scenarios.

While technological advancements, including full-scope simulations, digital interlocks, and passive safety mechanisms, have improved the safety margins of modern reactors, broader systemic challenges persist. These include the political stalemate surrounding nuclear waste management, the economic collapse of the domestic nuclear supply chain, and the migration of skilled labor toward renewable sectors. This paper argues that nuclear energy's long-term viability hinges not only on innovation, but also on institutional trust, operator training, and sustained industrial infrastructure. Amidst renewed interest in advanced reactors like Small Modular Reactors (SMRs) and the completion of projects like Vogtle Unit 4, the future of nuclear power remains possible, but precarious.

I. INTRODUCTION

Nuclear power has long promised a solution to global energy needs: it offers extremely high energy density, zero direct carbon emissions, and round-the-clock base-load generation. Its technical advantages position it as a powerful complement to intermittent renewable sources such as wind and solar. Yet despite its benefits, nuclear power continues to face formidable barriers to broader adoption. These include the legacy of historical disasters, long construction timelines, intense regulatory scrutiny, and growing public skepticism fueled by decades of sociopolitical and economic turbulence.

This paper synthesizes technical insights from nuclear operations, particularly in the context of naval propulsion reactors, with academic research on instrumentation, control, and human systems integration. It explores how the evolution of digital I&C systems has transformed modern plant safety while also introducing new vulnerabilities, particularly in terms of human-computer interaction. By revisiting major nuclear incidents and analyzing their root causes, this work highlights the ethical and operational boundaries of automation, the critical importance of experienced operators, and the design decisions that shape how human errors propagate—or are prevented.

Ultimately, this paper contends that the future of nuclear power depends not only on engineering excellence, but also on institutional resilience. While new technologies like SMRs and passive safety designs represent significant progress, they must be accompanied by policy reform, renewed investment in nuclear education and infrastructure, and a cultural shift toward sustainable, ethically grounded energy stewardship.

II. INSTRUMENTATION AND CONTROL (I&C) SYSTEMS

A. *Types of Plants*

Nuclear power plants can be classified by several characteristics, the most common being the type of coolant used to extract thermal energy from the reactor core. Table I categorizes four typical designs. Each has unique thermodynamic cycles and control architectures that dictate the required instrumentation, logic systems, and safety interlocks.

TABLE I
Types of Nuclear Power Plants [1]

Reactor Type	Coolant Medium	Neutron Moderator
Pressurized Water Reactor (PWR)	Light Water	Light Water
Boiling Water Reactor (BWR)	Light Water	Light Water
Heavy Water Reactor (CANDU)	Heavy Water (D ₂ O)	Heavy Water (D ₂ O)
Advanced Gas-cooled Reactor (AGR)	CO ₂ or Helium	Graphite

While this paper emphasizes PWR and BWR systems—depicted in Figures 1 and 2—reactors can also be categorized by neutron energy spectrum (thermal, intermediate, fast), fuel configuration (homogeneous or heterogeneous), purpose (research, power, breeding, or plutonium production), and net fissile yield (breeder vs. converter) [1].

B. Reactor Monitoring Principles

Instrumentation systems in nuclear power plants are designed to provide real-time, high-fidelity data on the most critical plant variables—particularly those affecting core reactivity, heat transfer, and plant integrity. These systems rely on a combination of neutron radiation sensors and thermal sensors, with sensor placement tailored to reactor type, as shown in Figures 1 and 2.




Fig. 1. Instrumentation layout for a typical PWR core [2].




Fig. 2. Instrumentation layout for a typical BWR core [2].

1) Thermal and Neutron Sensing.

Sensors for nuclear plant monitoring fall broadly into two categories: thermal sensors and nuclear-radiation sensors [1]. Thermocouples and resistance temperature detectors (RTDs) monitor coolant temperatures and structural heat loads, while neutron sensors directly measure fission activity. Because neutrons are uniquely tied to the fission process, neutron flux

detectors are essential for monitoring power distribution, total fission rate, and the rate of change of reactor power.

2) *Coolant and Moderator Instrumentation.*

Coolant system monitoring includes the following key measurements [1]:

- Coolant inlet and outlet temperatures (to track heat extraction).
- Flow rate into and out of the reactor (F_c), as well as through various coolant channels.
- Coolant pressure in both the core and outlet piping.
- Purity of coolant and its radioactivity, especially post-core.
- Moisture content (for gas-cooled systems), which may influence reactivity and heat transfer.

These measurements require temperature sensors, flowmeters, pressure transducers, gamma sensors, and humidity detectors. In light water reactors, precise detection of subcooled margin, void fraction, and departure from nucleate boiling (DNB) are paramount.

3) *Control and Structural Monitoring.*

In addition to thermal-hydraulic measurements, plant instrumentation also tracks key operational parameters:

- Position of control rods (L^*), crucial for reactivity control.
- Moderator and reactor water levels (L_m , L_r).
- Moderator temperature (T_m), especially in systems like CANDU reactors.
- Primary system pressure (P_p) and coolant outlet pressure (P_o).

Sensors used include linear variable differential transformers (LVDTs), water-level probes, and high-accuracy pressure transducers.

4) *Steam and Turbine System Sensing.*

Beyond the reactor itself, I&C systems must track parameters in the secondary loop and balance-of-plant systems. These include:

- Steam flow rate (F_s), steam quality, and pressure (P_g).
- Feedwater flow (F_f) and drum level (in BWRs).
- Turbine rotational speed, generator output power, and pump motor performance.

Such measurements use tachometers, electrical metering, differential pressure sensors, and dynamic vibration monitors, ensuring not only safe reactor operation but also efficient energy conversion and grid stability.

5) *Integration with Digital Systems.*

The increasing integration of digital logic enables centralized monitoring of these diverse parameters using high-speed buses and distributed control systems (DCS). Such systems can perform real-time diagnostics, apply fail-safe logic, and enhance overall plant safety and responsiveness.

These layered instrumentation systems—distributed across reactor, coolant, and steam systems—are designed to uphold the three core principles of nuclear safety: maintain reactivity control, ensure heat removal, and prevent release of radioactive materials. The careful selection and redundancy of sensors make them foundational to modern nuclear plant reliability.

C. *Computerized Protection Systems*

The progression toward digital protection systems has paralleled improvements in reactor safety and reliability. Engineered safety features (ESFs) are now fully integrated with digital I&C, simplifying operational logic through pre-programmed safety interlocks. These include automated trip logic and permissives designed to act faster than human operators during transient conditions [3].

- **SCRAM:** Rapid insertion of control rods into the reactor core to immediately terminate the chain reaction.
- **Pressure Relief Valves:** Automatic venting of steam or water to prevent overpressurization in the primary loop.
- **High/Low Pressure Trips:** Activate a SCRAM if loop pressure deviates beyond specified design tolerances.
- **Coolant Flow Trips:** Triggered by low primary loop flow, protecting against core overheating and fuel damage.
- **Temperature Differential Trips:** Monitor the hot leg and cold leg of the primary loop; trip the reactor if temperature gradients exceed safe limits.
- **Pressurizer Heater Control:** Automatic cycling of heaters to maintain loop pressure during load changes.

Figure 3 shows a representative logic diagram for a U.S.-based plant, illustrating how these subsystems are interlinked for layered protection.




Fig. 3. Representative reactor safety logic for a U.S. plant [3].

Critically, such systems are not intended for routine plant operation. Instead, their design assumes operator control remains primary and that automated systems intervene only during design-basis accidents or unanticipated transients. For example, while a pressurizer may tolerate pressures from 1500 psig to 2500 psig, licensed operators will typically maintain nominal pressure near 2250 psig¹ to ensure that automatic systems are not actuated unless multiple control layers fail.

Ultimately, these protection systems provide defense-in-depth and are structured around the core nuclear safety principles: control of reactivity, heat removal, and containment of radioactive materials. The move to digital logic enhances responsiveness but demands rigorous validation, fail-safe architectures, and operator situational awareness to maintain overall plant safety.

III. HISTORICAL LESSONS IN REACTOR SAFETY

A. SL-1: The First Fatal U.S. Reactor Accident

On January 3, 1961, the Army’s Stationary Low-Power Reactor Number One (SL-1) experienced the first fatal nuclear accident in U.S. history. During routine maintenance, the manual withdrawal of a control rod made the small test reactor prompt critical, leading to a steam explosion that destroyed the core and killed all three personnel on duty [4]. Figure 4 shows the post-incident state of the reactor vessel.

¹These numbers are shown purely for example and not based on existing plant design.



Fig. 4. The damaged SL-1 reactor core following the prompt critical excursion [4].

1) *Sequence of Events*

Local firefighters arrived in response to a fire alarm and found the facility abandoned. Coffee cups remained warm, and food was left uneaten. As radiation alarms activated on their dosimetry equipment, they realized a serious radiological event had occurred. Two operators were located dead from radiation exposure. The third, Richard Legg, was discovered impaled and pinned to the containment ceiling by a control rod—ejected upward during the reactor’s prompt critical event.

2) *Root Cause Analysis*

SL-1 used top-mounted control rods for reactivity control, which were manually withdrawn during maintenance procedures. Operators had previously documented that rods frequently stuck due to thermal expansion of the drive mechanisms. It became common to exert above-normal force during removal. On the night of the accident, the center control rod—the most reactivity-dominant—was pulled upward over 50 centimeters in a single motion, far beyond the safe insertion limit. The resulting reactivity spike caused a runaway chain reaction and a destructive power surge in under 4 milliseconds [4].

3) *Engineering and Human Factors Implications*

Despite repeated reports of sticking rods, the system lacked mechanical or procedural interlocks to prevent rapid withdrawal. A single operator retained full manual control, with no redundancy or supervisory lockouts. The SL-1 event shows the critical role of human factors engineering, particularly in minimizing design interfaces that allow unsafe manual operations.

4) *Aftermath and Lessons Learned*

The accident ended the U.S. Army’s independent nuclear program and reshaped reactor safety policy. Key engineering and operational reforms included:

- Mandatory interlock systems for reactivity-affecting maintenance tasks.
- Human-machine interface redesign to reduce physical leverage on control rods.
- Enhanced operator training in recognizing mechanical anomalies and enforcing procedural compliance.
- Systematic feedback integration from preventative maintenance logs into safety reviews.

SL-1 is now a foundational case in nuclear safety education, cited for both its engineering oversights and its tragic human cost. The accident remains a clear demonstration of how well-known mechanical issues—if left unresolved—can lead to fatal outcomes even in small-scale, research-focused facilities [4].

B. Three Mile Island: Interface Confusion and Human Factors

The Three Mile Island Unit 2 (TMI-2) accident occurred on March 28, 1979, near Harrisburg, Pennsylvania, and remains the most serious commercial nuclear accident in the United States. It was precipitated by the failure of a pressure-operated relief valve (PORV) that became stuck open during a minor malfunction. The valve allowed coolant to escape from the pressurizer, but due to inadequate instrumentation, operators believed it had closed properly [5].

1) Sequence of Events

The event began with a relatively minor mechanical issue: a malfunction in the secondary cooling system caused the reactor to automatically shut down. In response, the PORV opened to relieve pressure but failed to reseal. As coolant escaped from the system, the core began to overheat. However, operators—faced with a cascade of alarms and ambiguous signals—misinterpreted the problem. Believing the system to be overpressurized, they manually shut off the emergency core cooling system (ECCS), thereby worsening the core heat-up. This operator action, based on incomplete and confusing data, allowed the core to partially melt.

2) Design Oversights and Interface Failures

Although the specific model of relief valve had a history of sticking open at other nuclear facilities, including ones that caught the issue during routine maintenance, this design vulnerability remained unaddressed in TMI-2. The larger problem, however, lay in the information architecture available to operators. The control room flooded with alarms—many irrelevant or contradictory—led to cognitive overload. As seen in Figure 5, the control interface lacked a clear indication of the PORV status. Nowadays, a temperature sensor is typically placed downstream of all pressure relief valves to indicate the actuation of the system, with a clear, dedicated alarm for each one.



Fig. 5. The control room of TMI-2 on April 3, 1979, following the accident [5].

3) *Human Factors and System Complexity*

Prior to this event, the relationship between human performance and system design was underappreciated in reactor control engineering. It was often assumed that proper training and “common sense” would be sufficient for managing system faults. However, the TMI-2 accident highlighted that even well-trained operators can make catastrophic errors when systems are not designed to support human cognition under stress.

As a result of this accident, the field of human factors engineering gained legitimacy within the nuclear industry. Organizational and industrial psychology—especially the study of ergonomics and operator-centered design—emerged as crucial disciplines in instrumentation and control system development [6]. Operators needed interfaces not merely for function, but for situational awareness and decision-making under pressure. This marked a turning point in control room design philosophies, ushering in era-defining updates to alarm management, display hierarchy, and interface logic [3].

4) *Legacy and Regulatory Reform*

The Nuclear Regulatory Commission (NRC) and the Institute of Nuclear Power Operations (INPO) were restructured in the aftermath to emphasize operator performance, training, and usability engineering. New protocols required validation of human-system interfaces (HSIs), and updated control room standards began to emphasize clarity, prioritization of alarms, and the inclusion of status indicators that leave less to inference.

The TMI-2 incident stands as a foundational example in nuclear operations of how accidents may not arise solely from equipment failure, but from the interactions between human minds and poorly designed systems.

C. Chernobyl and Reactor Design Faults

1) Background and Test Scenario

The catastrophic accident at Chernobyl’s Reactor No. 4 occurred on April 26, 1986, during a late-night safety test. The test intended to verify whether the rotational inertia of the turbine could temporarily power the emergency coolant pumps in the event of a grid power failure [7]. The RBMK-1000 reactor involved was a Soviet-designed graphite-moderated, water-cooled system—flawed by both design and execution [8, 9].

2) Design Flaws and Positive Feedback

A defining flaw of the RBMK design was its *positive void coefficient*, which meant that a reduction in coolant (forming steam voids) actually increased the nuclear reaction rate. This characteristic starkly contrasts with most Western designs, where coolant voids introduce negative reactivity and suppress power output [10].

During the test, a buildup of xenon-135 (a neutron absorber) had suppressed reactor power. Operators, under pressure and facing decaying xenon levels, withdrew control rods to maintain minimum power. When reactivity returned, they initiated a SCRAM, inserting all control rods.

3) SCRAM-Induced Prompt Criticality

Ordinarily, a SCRAM should halt a reaction. However, the RBMK rods featured graphite tips that displaced neutron-absorbing water before inserting the boron carbide absorber sections. This caused a momentary *increase* in reactivity in the lower portion of the core, leading to a rapid, uncontrollable rise in power. The reactor reached a prompt critical state within seconds [8].

4) Core Destruction and Radiation Release

The core overheated instantly, rupturing fuel channels and vaporizing coolant. A violent steam explosion lifted the reactor’s 2,000-ton upper biological shield. A second explosion—possibly from hydrogen or steam—further breached the structure and exposed the graphite moderator, which caught fire. Figure 6 shows the aftermath of the explosion mere hours after the explosion. The fire lofted radioactive particles into the upper atmosphere, affecting much of Europe [9].



Fig. 6. Chernobyl Reactor No. 4 on April 27, 1986, 14 hours after the explosion [11].

5) Operator Training and System Transparency

Many plant workers had no clear understanding of the RBMK reactor's inherent instability. Critical safety data were often classified or minimized due to Cold War secrecy. The Soviet nuclear industry prioritized production of military-grade plutonium over safety, compounding operator vulnerability [11].

6) Aftermath and Human Toll

First responders—mostly firefighters and plant workers—entered the facility without radiation protection. Within weeks, dozens died from acute radiation syndrome. Long-term effects include increases in thyroid cancer and widespread environmental contamination. Despite this, many local engineers and volunteers heroically fought to limit the spread of damage.



Fig. 7. The “Elephant’s Foot”: a mass of corium under Reactor No. 4, composed of melted fuel, sand, and reactor structural materials [11].

7) *Legacy of Chernobyl*

The aftermath of Chernobyl catalyzed global reevaluation of nuclear safety, reactor design, and operator training. The international community pushed for increased transparency, safety audits, and enhanced containment strategies. The photograph in Figure 7 famously shows the “Elephant’s Foot,” a deadly corium formation. The strange visual static in the image is not lightning, but film degradation from intense radiation—testament to the unprecedented radioactive environment at the site.

The disaster marked a permanent shift in public perception of nuclear energy, influencing decades of policy and triggering a global slowdown in nuclear development.

D. *Fukushima-Daiichi: Environmental Consequences*

1) *Earthquake and Tsunami Impact*

On March 11, 2011, a magnitude 9.0 undersea megathrust earthquake struck off the northeastern coast of Honshu, Japan, triggering a tsunami with wave heights exceeding 14 meters. The Fukushima-Daiichi Nuclear Power Station, operated by TEPCO, was critically affected. Although the three operating reactors—Units 1, 2, and 3—successfully SCRAMed (shut down automatically), the tsunami flooded the site and disabled both the offsite grid connections and emergency diesel generators [12]. This unprecedented loss of power across all units is illustrated in Figure 8, which shows the reactor buildings after successive hydrogen explosions.



Fig. 8. Fukushima-Daiichi Nuclear Power Station: The four damaged reactor containments (from left: Units 4, 3, 2, and 1) on 16 March, 2011 [13].

2) *Station Blackout and Core Meltdown*

Following shutdown, nuclear reactors continue to emit decay heat, which can exceed several percent of nominal thermal power in the hours after fission halts. This residual heat must be actively removed to avoid core damage. At Fukushima, all cooling systems failed due to the flooding of diesel generators and electrical switchgear—many of which were located in basements vulnerable to tsunami inundation [14]. This left the plant in a condition known in the nuclear industry as *dead electric*, where no AC or DC power is available to operate pumps, valves, or even basic monitoring systems.

3) *Loss of Monitoring and Improvised Measures*

Operators at Fukushima recognized the danger but were rendered effectively blind by the loss of power. Unlike U.S. Navy reactor systems—where portable test equipment such as Fluke digital multimeters can be attached to terminals for passive thermocouple readings—the Fukushima design lacked redundant manual monitoring options. In a desperate act of ingenuity, personnel retrieved car batteries from nearby vehicles and wired them in series to restore minimal voltage to power essential instrumentation. Unfortunately, by the time this improvised power source was implemented, core damage in Units 1, 2, and 3 was already underway, with partial or full meltdown confirmed in post-event analyses [13].

4) *Environmental and Human Consequences*

While the total release of radioactive material was less than that of Chernobyl, Fukushima’s dual-trigger origin—a natural disaster followed by technological failure—had extensive consequences. Hydrogen explosions damaged reactor buildings, and emergency cooling water—now contaminated—leaked into the Pacific Ocean. Airborne dispersion of iodine-131 and cesium-137 prompted mass evacuations and long-term exclusion zones. The disaster left Japan facing not only technical containment challenges, but also long-lasting psychological, economic, and political fallout.

5) *U.S. Naval Involvement and Humanitarian Support*

As news of the crisis reached the global community, international responses were swift. Aboard the aircraft carrier *USS Ronald Reagan* (CVN-76), routine Air Particulate Detector

readings spiked during transit toward Japan. Recognizing the gravity of the situation, the commanding officer ordered the ship to provide humanitarian aid. The Reagan positioned itself offshore and used its dual nuclear reactors to reverse-feed electrical power into Japan’s devastated grid infrastructure, offering vital support during the early days of recovery and relief.

This cooperative effort emphasized the unique role nuclear-powered vessels can play in civilian emergency response—an often-overlooked advantage of maritime nuclear propulsion.

IV. HUMAN FACTORS: THE ETHICAL DIMENSION OF AUTOMATION

The role of trained human operators in the safe and reliable generation of nuclear power cannot be overstated. Despite vast improvements in automation, instrumentation, and control systems, the nuclear accidents at SL-1, Three Mile Island, Chernobyl, and Fukushima-Daiichi demonstrate that the human element remains indispensable. These incidents demonstrate the importance of sound judgment, situational awareness, and expert intervention when systems fail or behave unpredictably [3].

A. Human Factors Engineering

Human factors engineering (HFE) is the systematic application of knowledge about human capabilities, limitations, behaviors, and interactions to the design of systems, equipment, and tasks. In the nuclear industry, HFE plays a vital role in ensuring that complex control systems support rather than hinder operator performance—especially in high-pressure situations.

As nuclear plants have grown in complexity and power output, the design of control rooms has evolved to integrate ergonomic layouts, intuitive interface systems, and simulation-based training environments. This progression aims to reduce human error and improve decision-making reliability [3].

International standards like IEC 964 and IEC 60964 provide guidelines for human-system integration in nuclear control systems [15, 16]. These standards emphasize:

- Alignment between power production and safety objectives.
- Proper allocation of tasks between manual and automatic controls.
- Application of human performance data, including anthropometrics, cognitive psychology, and reliability analysis.

Key elements of human factors integration include the reliable *presentation of information*, *uniform control design*, well-thought-out *panel and display layouts*, and procedural integration via *full-scope simulators* that replicate real plant conditions [15, 16].

B. Operator Experience

While engineering design establishes operational parameters, it is the operator who understands the plant in real time. Experienced operators know how the system responds to subtle inputs—such as a one-second control rod shim or a 10 psig fluctuation in secondary steam

pressure. Similarly, machinery room technicians can predict how valve sequencing will affect temperature, flow, or turbine response.

In early prototype plants, small reactor cores were operated at constant loads by teams of scientists and engineers pushing the limits of atomic knowledge [3]. As commercial nuclear power scaled up, these systems became vastly more complex, and measurement accuracy and control precision grew increasingly important.

Modern operators are trained not only on procedural execution but also on pattern recognition, anomaly detection, and adaptive response. Their insights cannot be easily modeled or coded into automation algorithms, especially under degraded conditions or unforeseen emergencies.

C. Ethical Limits of Automation

While automation has dramatically improved reactor safety, it must be implemented with caution. In certain crisis scenarios, reliance on preprogrammed logic or incomplete models may lead to incorrect or delayed actions. Ethical considerations demand that humans remain at the center of safety-critical decisions, particularly when outcomes involve lives or large-scale environmental consequences.

One well-documented challenge in cognitive psychology is the *tunnel effect*, in which humans persist with an initial, incorrect interpretation of a situation, especially under stress [3]. This phenomenon is exacerbated when control system layouts are unintuitive or overwhelming. Retrofitting advanced instrumentation without corresponding operator retraining can invalidate experience and increase error likelihood.

Moreover, automated models are developed under assumptions that may no longer apply in aging plants. Changes to fuel characteristics, core configurations, or coolant flow paths can render original logic sequences obsolete. This can lead to spurious trips, false alarms, or missed safety signals—potentially costing a commercial plant lost megawatt-hours, or a naval reactor lost propulsion.

For these reasons, complete automation is neither practical nor desirable in contemporary nuclear power plants. A hybrid architecture—where human operators are empowered by automation, not replaced by it—is currently the safest and most reliable solution.




Fig. 9. Automation and human factors in nuclear power generation [3].

The optimal nuclear power plant integrates advanced control systems with a highly

trained crew. These operators undergo continuous simulation training for casualty scenarios and are equipped with real-time diagnostic tools. Such a system ensures robust safety, resilience to abnormal events, and operational excellence.




Fig. 10. The optimal balance between automation and human factors in nuclear power generation [3].

V. ECONOMIC REALITIES AND INFRASTRUCTURE DECLINE

Due to the high-profile mishaps discussed in Section III, the nuclear industry has suffered a significant loss of public trust. This erosion of confidence has contributed to financial uncertainty, stalled development, and a decline in domestic infrastructure to support new reactor construction. The resulting industrial contraction has drawn comparisons to the decline of the coal rail economy—once supported by a network of coal suppliers and rail hubs across the United States. As investment and skilled labor shift toward renewable energy, nuclear power is increasingly seen as an economically fragile legacy technology.

A. Waste Management and Decommissioning Costs

A commercial nuclear reactor undergoes refueling approximately every 18 to 24 months, with each cycle costing between \$50 million and \$100 million [17]. These costs include fuel handling, transport logistics, containment, and licensing. Spent fuel is highly radioactive and must be isolated from the environment for thousands of years, necessitating complex storage and oversight systems.

The U.S. currently stores most of its spent fuel onsite in dry cask storage, as it lacks a permanent geologic repository. The proposed Yucca Mountain site in Nevada was halted due to political opposition, leaving a critical infrastructure gap [18]. Meanwhile, the Department of Energy (DOE) estimates that total long-term waste management liabilities—including storage, monitoring, and decommissioning—could exceed \$500 billion over the next century [18]. Several private firms that formerly handled nuclear logistics and fuel services have

transitioned into renewable technologies or left the sector entirely, further weakening the industry’s support structure.

B. Construction and Design of Future Plants

The capability to construct new nuclear facilities has also diminished. The completion of Vogtle Unit 4 in Georgia—one of the first new U.S. reactors in decades—offered a glimmer of progress, but also exposed the harsh economic and logistical realities of modern nuclear construction. The project faced a decade of delays and billions in cost overruns, driven by labor shortages, supply chain gaps, and regulatory hurdles [19].

Domestic capacity to manufacture nuclear-grade components, such as reactor pressure vessels or reactor coolant pumps, has eroded. Only a few specialized forges worldwide are still capable of producing these massive components to the necessary ASME and NRC specifications. Simultaneously, industrial firms that once supported nuclear projects have shifted their operations toward building wind turbine towers, solar inverters, and battery storage systems. The opportunity cost of investing in nuclear has grown as renewables offer faster return on investment and benefit from robust public and private incentives.

C. Migration from Nuclear to Renewable Energy Sectors

Global investment patterns show a clear transition from nuclear to renewables. Engineering giants like Siemens and General Electric have scaled back or entirely exited nuclear ventures in favor of wind, solar, and energy storage [20]. In 2022 alone, global capital expenditures on solar and wind eclipsed nuclear investments by more than fivefold [17].

This migration is not merely market-driven; it is reinforced by regulatory environments. Post-Fukushima mandates have led to stricter safety requirements and more frequent inspections, raising compliance and licensing costs. Some U.S. plants face annual regulatory costs in excess of \$20 million [19]. These growing financial burdens make nuclear projects less attractive in both the public and private sectors.

D. Integration Challenges and Opportunities

Despite economic challenges, nuclear energy offers unique value as a source of stable baseload power. This makes it an ideal complement to intermittent renewable sources like wind and solar. However, current policy frameworks often prioritize short-term carbon reduction via rapidly deployable renewables, sidelining nuclear investments that require long lead times and upfront capital.

A salient example is the rise of offshore wind infrastructure in coastal cities such as New London, Connecticut. These projects attract federal and state subsidies, media attention, and educational investments, while nuclear plants are increasingly perceived as costly, inflexible, or outdated [21].

Public perception remains a formidable barrier. While nuclear power remains one of the lowest-carbon energy sources per unit of energy generated, its association with catastrophic events has left a lasting impact on societal attitudes. Without substantial policy reform and education efforts, nuclear energy will remain economically disadvantaged despite its technical merits.

VI. CONCLUSION: A CAUTIOUS RETURN TO THE ATOM

Nuclear power stands at a complex crossroads—one defined by profound ethical obligations, hard-earned technological lessons, and a rapidly shifting energy landscape. The historical record, shaped by the tragic events at SL-1, Three Mile Island, Chernobyl, and Fukushima-Daiichi, offers clear testimony to the irreplaceable role of human judgment in reactor safety. These accidents remind us that automation, while powerful, must be designed with the understanding that it supports rather than supplants trained human operators.

Human factors engineering has evolved into a critical field, embedding psychological, ergonomic, and procedural insights directly into plant design. Simulators, intuitive control room layouts, and refined information presentation now stand as defenses against the tunnel vision and decision fatigue that so often accompany crises. The ethical responsibility to keep a human in the loop—especially in decisions with irreversible consequences—cannot be ignored, even as algorithms grow more capable and systems more autonomous.

Yet, the technical and economic challenges facing nuclear power are sobering. The decline of manufacturing capacity, the shuttering of legacy vendors, and the migration of talent and capital toward renewables have left the nuclear sector precariously under-resourced. Without consistent policy support and industrial reinvestment, the risk of losing irreplaceable expertise and infrastructure grows with each passing year. The lack of a permanent waste repository and the mounting costs of decommissioning further complicate the long-term viability of the industry.

Still, all is not lost. Projects like Vogtle Units 3 and 4 in Georgia—despite cost overruns and delays—signal a possible turning point. They represent not only a technological achievement but also a renewal of confidence in the idea that nuclear energy can still play a vital role in our decarbonized future. The emergence of small modular reactors (SMRs), the refinement of passive safety designs, and renewed global interest in energy resilience have reinvigorated the conversation.

To move forward, we must blend the hard-won wisdom of past experience with the innovative tools of modern engineering. Nuclear power will never be perfect—but neither is any energy source. What makes it unique is the immense power it offers, not just in megawatts, but in the philosophical sense: a force that must be handled with reverence, precision, and foresight. The atom, split with care and humility, may yet illuminate a sustainable and responsible path forward.²

²An LLM was used strictly for formatting IAW IEEE Editorial Style Manual for Authors. All thoughts, prose, and conclusions are my own.

REFERENCES

- [1] J. M. Harrer and J. G. Beckerley, “Nuclear power reactor instrumentation systems handbook. volume 1,” Illinois, Jan. 1, 1973. [Online]. Available: <https://www.nrc.gov/docs/ML1403/ML14031A424.pdf>.
- [2] A. Pearson and C. G. Lennox, *The Technology of Nuclear Reactor Safety*. Cambridge, Mass: The MIT Press, 1964, p. 288.
- [3] International Atomic Energy Agency, “Modern instrumentation and control for nuclear power plants: A guidebook.,” Vienna, Austria, Tech. Rep., 1999.
- [4] C. Engineering, “Sl-1 reactor accident on january 3, 1961: Interim report,” May 15, 1961. [Online]. Available: <http://large.stanford.edu/courses/2017/ph241/berrios1/docs/ido-19300.pdf>.
- [5] J. S. Walker, *Three Mile Island: a nuclear crisis in a historical perspective*. Berkeley and Los Angeles, California: University of California Press, 2004.
- [6] N. Meshkati, “Human factors in large-scale technological systems’ accidents: Three mile island, bhopal, chernobyl,” *Industrial Crisis Quarterly*, pp. 133–154, 1991. DOI: 10.1177/108602669100500203. [Online]. Available: <https://doi.org/10.1177/108602669100500203>.
- [7] World Nuclear Association. “Chernobyl accident 1986.” Accessed: 2025-06-06. [Online]. Available: <https://world-nuclear.org/information-library/safety-and-security/safety-of-plants/chernobyl-accident.aspx>.
- [8] International Atomic Energy Agency, “The chernobyl accident: Updating of insag-1,” IAEA, Tech. Rep. INSAG-7, 1992, Accessed: 2025-06-06. [Online]. Available: https://www-pub.iaea.org/MTCD/publications/PDF/Pub913e_web.pdf.
- [9] U.S. Nuclear Regulatory Commission, *Background on chernobyl nuclear power plant accident*, Accessed: 2025-06-06, 2020. [Online]. Available: <https://www.nrc.gov/reading-rm/doc-collections/fact-sheets/chernobyl-bg.html>.
- [10] M. J. Driscoll, *Rbmk reactor characteristics – nuclear systems design project (22.33)*, <https://ocw.mit.edu>, Accessed: 2025-06-06, 2004.
- [11] G. Medvedev, *The Truth About Chernobyl*. Basic Books, 1991, ISBN: 9780465087725.
- [12] International Atomic Energy Agency, “The fukushima daiichi accident,” IAEA, 2015, Accessed: 2025-06-06. [Online]. Available: https://www-pub.iaea.org/MTCD/Publications/PDF/AdditionalVolumes/P1710/Publication/Fukushima-Daiichi_accident_report.pdf.
- [13] World Nuclear Association, *Fukushima daiichi accident*, Accessed: 2025-06-06, 2023. [Online]. Available: <https://world-nuclear.org/information-library/safety-and-security/safety-of-plants/fukushima-daiichi-accident.aspx>.
- [14] U.S. Nuclear Regulatory Commission, *Background on the fukushima daiichi nuclear accident*, Accessed: 2025-06-06, 2021. [Online]. Available: <https://www.nrc.gov/reading-rm/doc-collections/fact-sheets/japan-events.html>.

- [15] *Design for control rooms of nuclear power plants*, Accessed: 2025-06-06, International Electrotechnical Commission, 2009. [Online]. Available: <https://webstore.iec.ch/publication/724>.
- [16] I. E. Commision, “Design for control rooms of nuclear power plants, standard 964,” Geneva, Switzerland, Tech. Rep., 1989.
- [17] M. Schneider and A. Froggatt, “World nuclear industry status report 2022,” Tech. Rep., 2022. Accessed: Jun. 4, 2024. [Online]. Available: <https://www.worldnuclearreport.org/>.
- [18] U.S. Department of Energy, “Restoring america’s competitive nuclear energy advantage: A strategy to assure u.s. national security,” Tech. Rep., 2020. Accessed: Jun. 4, 2024. [Online]. Available: <https://www.energy.gov/sites/default/files/2020-09/restoring-americas-competitive-nuclear-energy-advantage.pdf>.
- [19] A. A. Forum, *The cost of nuclear power*, Accessed: 2025-06-06, 2021. [Online]. Available: <https://www.americanactionforum.org/research/the-cost-of-nuclear-power/>.
- [20] International Energy Agency, *World energy investment 2020*, Accessed: 2025-06-06, 2020. [Online]. Available: <https://www.iea.org/reports/world-energy-investment-2020>.
- [21] M. R. Abdussami and A. Verma, “Future energy landscapes: Analyzing the cost-effectiveness of nuclear-renewable integrated energy systems in retrofitting of coal power plants,” *Applied Energy*, p. 124460, 2025, ISSN: 0306-2619. DOI: 10.1016/j.apenergy.2024.124460. [Online]. Available: <https://www.sciencedirect.com/science/article/pii/S0306261924018439>.