



Technical Specifications of Envision 10100 kVA Transformer

DISCLAIMER

While every precaution has been taken in the preparation of this document, Envision Energy Co., Ltd (hereinafter refers to as “Envision Energy”) assumes no liability with respect to the operation or use of Envision Energy products and documentation described herein.

Envision Energy shall not be liable for any act or omission concerning the products or documentation, interruption of service, loss or interruption of business, loss of anticipatory profits, or punitive, incidental, or consequential damages in connection with the furnishing, performance, or any use of Envision Energy products or documentations provided herein.

Please use the latest version of the applicable specifications. Figures of this documentation do not necessarily reflect the exact scope of supply. The actual scope of supply is subject to technical alterations at any time.

Transformer Specification		
1	Type	3 winding, Oil immersed, Inverter duty Transformer
2	Rated Output kVA	10100 kVA
3	Vector Group	Dy11y11
4	Type of Cooling	ONAN/KNAN
5	Oil Type	Mineral Oil or FR3
6	Rated Voltage kV	
	1. HV	33
	2. LV	0.69-0.69
	3.Voltage Variation	± 10%
7	Rated Current A	
	1. HV	176.7
	2. LV1	4225.6
	3. LV 2	4225.6
8	Nos. of Phases	3
9	Rated Frequency Hz	50
10	Conductor material	
	1. HV	Aluminum
	2. LV	Aluminum
11	Tap Changer	OCTC
	1. Type	Off Circuit
	2. Tap Range - % Variation	±2×2.5%
12	Insulation Level	
	1. L.V.	LI - kV/AC 3 kV
	2. H.V.	LI 170 kV/AC 70 kV
13	Impedance%	Reactance 10.5%±10%
14	Short Circuit withstand duration	
	1. Three phase dead short Circuit at terminal with Rated voltage maintained on the other side.	2 second
	2. Single phase short circuit at terminal with rated Voltage maintained on other side.	2 second
15	Weight kg	
	1. Total	about 21000
16	Accessories	
	LV bushings	6 piece
	HV bushings	3piece

	Off-load tap changer	1 piece
	Pressure relief device	1 piece
	Oil-level indicator	1 piece
	Oil-temperature indicator	1 piece
	Gas relay	1 piece
	conservator tank	1 piece
	Air dryer	1 piece
	Capsule	1 piece
	Drain valve	1 piece
17	Signals	
	Pressure relief trip	1 piece
	Low oil level trip	1 piece
	Oil-temperature alarm and trip	1 piece
	Oil-temperature signal (-20~120°C)	1 piece
	Gas relay alarm and trip	1 piece