

Clarifications for the Request of Proposal (RFP)

Tender Name: Establishment of 250MW/1000MWh Standalone Battery Energy Storage System from 10MW/40MWh AC Capacity Projects on Build, Own and Operate (BOO) Basis with 15 Year Operational Period

Tender No. : TR/REP&PM/ICB/2026/001/C

No.	Clarification Requested	Clarification
1)	Reference: Bidding Documents - Eligibility and Technical Proposal Requirements a) a Bidder is permitted to propose more than one BESS, PCS, or EMS supplier within a single bid for the project; b) If multiple suppliers are permitted, whether is any limit on the number of suppliers per equipment category, and what technical or contractual conditions (e.g., interoperability, single-point warranty responsibility, common EMS integration) would apply.	Please refer to item 23 of Addendum 01
2)	Reference: Volume 3, Appendix 01, Clause 1 the Contracted Capacity stated in Volume 3, Appendix 01, Clause 1 can be revised or amended to reflect the actual Declared Capacity offered by the successful Bidder (i.e., up to 11MW), rather than being fixed at 10 MW, and if so, the mechanism by which this revision would be reflected in the Contract.	Yes. The Contracted Capacity specified in Volume 3, Appendix 01, Clause 1 shall be the Declared Capacity offered by the successful Bidder in Section 1 of Volume II (Bid Submission Form) . At the time of execution of the Contract, the Contracted Capacity will be amended, where applicable, to reflect the successful Bidder's Declared Capacity.
3)	Reference: General Tender Requirements - Grid Compliance Monitoring a) The precise technical scope and functionalities expected of the grid monitoring system (e.g., real-time monitoring of voltage, frequency, active/reactive power, harmonics, and other grid parameters); b) Any specific standards, certification, or type-test requirements applicable to the grid compliance monitoring equipment.	Please refer Addendum 01
4)	Reference: Interconnection/ Civil Works Requirements a) whose scope of work is it to design and construct the gantry near the GSS - i.e.,	a) Please refer Addendum 01 b) Standard – IEC 61000-4-30 Class A



	whether this falls within the Employer's scope or the Bidder/Contractor's scope; b) In the event that the construction of the gantry falls within the Bidder's scope, whether the land required for the construction of the gantry near the GSS will be provided by the Employer, or whether the Bidder is required to procure such land.	
5)	RTE is affected by temperature, the number of dispatches, and the content of dispatches. This time, the measurement point has been moved inside the GSS. If the RTE indicator is not met on a monthly basis but is met on an annual basis, can the unmet portion be returned in the same way as the availability mechanism?	The RTE requirement shall be assessed on a monthly basis. Accordingly, if the measured RTE during a particular month is below the specified minimum RTE, the shortfall shall not be carried forward or reconciled against the RTE achieved in subsequent months or at the end of the year.
6)	Requiring BESS projects to connect through dedicated 33 kV lines to the GSS, instead of allowing connection to existing lines or feeders where feasible, will unnecessarily increase CAPEX due to reduced flexibility. This would result in higher capacity charges and ultimately impose a greater cost on the public	Please refer Addendum 01
7)	Can NSO confirm that VAT, SSCL and other indirect taxes that may be imposed should also be excluded from the capacity charge for storage projects?	Please refer item 13 of Addendum 01
8)	The project timelines proposed in the RFP do not adequately account for the time required to obtain Bonded Warehousing approval, which typically takes 6 to 8 weeks. In addition, the Bonded Warehouse application can only be submitted after Financial Close. Therefore the COD as it stands is not realistic.	Please refer Addendum 01
9)	Obtaining CEA approval within one month from the ESA date appears overly ambitious. We therefore request extending this timeline to approximately two months while keeping the other milestones unchanged.	We believe 2 months from the Letter of Award would be sufficient to obtain the CEA approval.
10)	What happens if CEA approval cannot be obtained? Will NSO allow the developer to look for alternative land and extend the COD date?	If a need arises for change of land, it will be allowed, but a time extension will not be allowed.
11)	A Grid Interconnection Confirmation Letter should not be required at proposal submission. The Point of Interconnection will be established at the GSS premises by splitting the existing feeder through a gantry arrangement to provide a dedicated circuit for the BESS Facility. The Developer shall bear all losses and auxiliary consumption within the dedicated MV	Please refer to Addendum No. 01 . If the Bidder selects Option 2 under Section 11 of Volume II , submission of the Grid Interconnection Confirmation Letter is mandatory and shall form part of the Bid.



	interconnection system between the BESS Facility and the revenue metering point at the GSS.	
12)	Grid forming is listed as a mandatory requirement. Please clarify whether these standalone projects can practically have grid-forming capability.	Yes
13)	Please clarify whether SSCL is charged at the point of import for capital goods imported under the Bonded Warehousing scheme.	The applicability of the SSCL to the importation of capital goods under the Bonded Warehousing Scheme shall be governed by the prevailing laws and regulations in effect at the time of importation.
14)	A key constraint in the RFP is the requirement for the developer to secure an additional plot of land adjoining the GSS to install the metering cubicle, as installation within the GSS is not permitted. Please clarify who will provide this land and what procedure will apply if suitable land is unavailable.	Please refer Addendum No. 01, further, if developer chooses to draw 33kV interconnection line up to the GSS the cost of construction, finding land, cost of way leaves etc. will have to be borne by the developer.
15)	As developers can only place orders with suppliers after Financial Closure and there will be a lead time of 3-4 months, the COD date of May is not realistic. We therefore request that the COD be extended to at least 9 months from date of Financial Close.	Please refer Addendum No. 01
16)	The mechanism to adjust the CCR due to fluctuations in LKR against the USD is inadequate because 1) the ESA may not be signed within 1 month of the LOA due to the need to change the terms of the ESA; 2) proponents can only get financial close after the ESA signing and by the time proponents order the components and make payment, it could be 3 months from the ESA signing. Can the date P2 be the date of LC settlements instead?	1. The terms and conditions of the Energy Storage Agreement (ESA) shall not be amended following the issuance of the Letter of Award, in accordance with Clause 7.1 of Volume I. 2. No. The reference date P2 shall remain as specified in the Request for Proposals (RFP) and will not be changed to the date of Letter of Credit (LC) settlement.
17)	If the LOA is not issued within 150 days following the Closing Date, the proponent may face significant cost increases which make the project unviable. Note that in section 2.8.2.2 Financial Resources, the RFP even contemplates a situation where the bid evaluation process and decision for the award may take more than 1 year from the date of bid submission. Therefore, can the NSO incorporate a provision that allows the project proponent to withdraw its bid without any penalty if the LOA is not issued within 150 days or to adjust the CCR due to the cost increase arising from the delay?	Please refer to the provisions relating to the Bid Validity Period in the Request for Proposals (RFP). If the Letter of Award (LOA) is not issued within the initial 150-day Bid Validity Period , Bidders are under no obligation to extend the validity of their Bids. Accordingly, a Bidder may decline to extend the Bid Validity Period without any penalty, and the Bid Security shall not be forfeited.
18)	If the ESA is not signed as scheduled, proponents may face significant cost increases which make the project unviable. Therefore, can the NSO incorporate a provision that allows the project	Provided that the Project Proponent submits all documents and fulfills all requirements stipulated in the RFP for execution of the Energy Supply Agreement (ESA) within

	proponent to withdraw its bid without penalty if the ESA is not signed within 1 month of the ESA or to adjust the CCR due to the cost increase arising from the delay?	the prescribed timeframe, the ESA signing appointment will be arranged accordingly without unnecessary delay. Therefore, any withdrawal of the bid shall be subject to the applicable provisions and penalties specified in the RFP.
19)	What if there are changes in taxes and other regulations after the Closing Date? Can there be a provision for the CCR to be adjusted and/or for proponents to withdraw their bids without any penalty because such changes may render the project unviable?	No provision will be made for adjustment of the CCR or for withdrawal of a Bid without penalty due to changes in taxes or other regulations after the Closing Date,
20)	If a bidder is the lowest-ranked bidder for two projects at the selected GSS using a single land plot, can the developer use one line for both projects?	Yes. A common grid interconnection line may be used, subject to compliance with the applicable technical requirements and obtaining the necessary approvals from the EDL
21)	The RFP requires installation of a Grid Code Compliance Monitoring System with features including real-time measurement, power quality monitoring, and fault ride-through monitoring. We seek clarification on: 1. Will NSO specify the make and model of the monitoring equipment, or will the Project Company be permitted to propose equipment that meets the functional requirements? 2. Who will be responsible for the ongoing maintenance and calibration of this system? 3. Will the data from this system be used for billing and verification?	1. No 2. Developer 3. Yes
22)	80dB needs to be clarified whether it refers to the noise of the equipment or the noise of the site, and what standards should be followed for the noise measurement points, or is it sufficient to only provide the equipment report?	The 80 dB noise limit shall be demonstrated to comply with the manufacturer's equipment test reports.
23)	In Annex A, 05.11 / 05.12 states that the level of harmonic voltage should be in accordance with the requirements of Section 3.17.2.5 Grid Connection Code. However, Section 3.17.2.5 mentions that the different frequency multiples and voltage distortion rates within the project should be agreed upon in the project. However, the current tender document does not specify the background voltage distortion rate of the grid. How should this be handled?	Project developer shall measure the background voltage distortion at the specified connection point during the harmonic voltage measurement stage.



24)	In Annex A, 05.13 states that 0.3 times the BESS rated power in reactive power must be provided at 33kV. Does the rated power here refer to the bid capacity power specified in the tender? A 05.02 also mentions providing ± 3 Mvar reactive power. Which one should be followed?	The reactive power capability requirement shall be ± 0.3 times the rated active power of the BESS.
25)	In Annex A, are all the tests mentioned in 05.24 required to be conducted on-site? If not which ones need to be conducted on-site, and which ones can be completed through other methods?	Please refer to Annex I for the Commissioning Test Schedule
26)	In Annex D, what is the specific definition of the measurement indicator "Number of Remaining round trip cycles per year at Boundary"?	The "Number of Remaining Round Trip Cycles per Year at Boundary" refers to the remaining available equivalent full round-trip cycles of the BESS, measured at the Point of Interconnection (Boundary), after accounting for the cycles already utilized during the relevant Contract Year. This parameter shall be determined based on the methodology specified in the Request for Proposals (RFP).
27)	In Annex D, it is mentioned that SCADA reports PPC signals to NSCC according to the IEC 104 communication protocol. If the PPC itself supports the IEC 104 protocol for direct communication with NSCC, is a gateway still required?	Yes
28)	In Annex A, 03.02 mentions three levels of access permission. What are these three levels, and what is the scope of permission for each level? How are they provided?	This will be communicated during implementation stage as stipulated in A 03.02
29)	In Annex A, 04 mentions that the frequency range for steady-state operation is 49.5Hz to 50.5Hz, with the maximum and minimum operating frequencies being 53Hz and 47Hz, respectively. However, in A 05.04, the frequency range for steady-state operation is 47-52Hz, with the maximum and minimum frequencies being 55Hz and 45Hz, respectively. Which one should be taken as the standard?	The Project Proponents shall comply with the requirements specified in Clause A 05.04 of Annex A .
30)	section 7.1 in Volume I states that "Following the issuance and acceptance of the Letter of Award, no qualifications, reservations, proposed amendments, deviations, or modifications to the terms and conditions of the ESA shall be entertained." Does this mean that the ESA template in the current bidding document is the final version?	Yes



31)	If frequency regulation or voltage regulation occurs when the equipment is in standby mode and is not scheduled by the power grid, energy loss will be caused. Will this part be considered in the RTE?	Yes
32)	In Appendix A. 05.16, it is mentioned that the active power is prioritized by default in the case of high or low voltage. Does this mean that when the power grid performs active power scheduling, if high or low voltage occurs, the power grid still needs to perform scheduling based on the preset active power?	The plant should have the capability to operate in both P and Q priority modes. NSO will specify the mode based on system requirements. If Q priority mode is activated, active power output might change based on the reactive power output.
33)	Please clarify the specific definition and expected control effect of the following control functions in A.05.22(a)iii: h. Normal and emergency blocking command; i. Ramp blocking command; j. Remedial Action Schemes status and settings; k. Active power flow direction command, if applicable; l. Fast active power reversal command, if applicable; m. Redundancy reductions and auxiliary power single source status; n. Other project-specific set-points and commands, as specified by NSO.	Detailed testing instructions will be provided at the implementation stage.
34)	Please confirm the frequency of the records of grid support services that need to be provided to the NSO as specified in A.05.22(a)v. What is the frequency of the records? What is the form of the records (for example, IP phone or email)?	Please refer Addendum 01
35)	The three simulation models are mentioned in A.05.23(b). Do we need to provide all the three simulation models?	It is compulsory to provide PSSE and PSCAD models.
36)	According to section 1.2 of Volume I, the Annex NB/CID documents must be complied with. However, Annex B does not contain any section describing energy storage. Is the owner of the energy storage plant subject to the management requirements related to the role of TRANSMISSION LICENSEE or Users, or is there a separate set of management requirements?	There is no Annex NB/CID specified in the RFP.
37)	If the TRANSMISSION LICENSEE is involved, it is mentioned that the black start function can be provided as required. Is the black start function mandatory in this project? If yes, what is the scope of the black start function?	No
38)	It needs to be clarified whether the BESS is considered as a generating unit. If it is, the reactive power provided within the power factor range	Please refer A 05.13 of Annex A



	conflicts with that specified in Annex A. Which one should be followed?	
39)	Section 3.17.6.3 in Annex B mentions that the PPM needs to be equipped with TFR. Is this clause applicable to this project? If yes, are there any requirements for the TFR specifications, such as sampling precision, measurement period, and fault recording length?	the TFR requirement is already covered under Clause A.05.22 of Annex A. Accordingly, the requirements specified under Clause A.05.22 of Annex A shall be complied with, including the applicable requirements for TFR specifications, measurement, sampling, and fault recording. Therefore, the Proponent shall provide and configure the TFR in accordance with the requirements specified under Clause A.05.22 of Annex A.
40)	Due to factors such as the accuracy of the electricity meter, environmental conditions, and human operation, there may be errors in the final performance test. Should we consider adding relevant clauses regarding test errors during the performance acceptance process, for example, an error within 1% can be considered as meeting the standard?	No
41)	Proposal Security Beneficiary Address Kindly confirm the name and address of the beneficiary/addressee to be inserted in the Proposal Security. Please provide the exact wording to be used in these documents to ensure compliance with the tender requirements.	Proposal security shall be addressed to CEO of NSO.
42)	i. Whether a Bidder is permitted to propose more than one BESS, PCS, or EMS supplier within a single bid for the project; and ii. If multiple suppliers are permitted, whether there is any limit on the number of suppliers per equipment category, and what technical or contractual conditions (e.g., interoperability, single-point warranty responsibility, common EMS integration) would apply.	Please refer addendum no 01
43)	3.2 of VOLUME 1: Instruction to project proponents -Transmission line 1. Could you clarify ownership and responsibility of the maintenance of the transmission line.	1. Accordingly, the ownership and maintenance of the transmission line shall be the responsibility of the Distribution Licensee. 2. EDL, as the Distribution Licensee, shall be responsible for identifying and marking the required wayleaves for the



	2. Please clarify whether the Employer will facilitate the obtaining of wayleave consents and all other necessary approvals required for the construction of the transmission line. If so, kindly specify the extent of the Employer's responsibilities and the approvals that will be facilitated.	Medium Voltage (MV) line. The Developer shall be responsible for obtaining the necessary approvals and clearances for the MV line route, including making all applicable payments and completing any required arrangements for clearing the route, at its own cost. EDL shall issue the necessary letters to the relevant authorities, landowners, and other parties requesting approval for the construction and drawing of the Medium Voltage line along the identified route.
44)	Clause No. 1.3.1 states, "Agreement to lease" (at least for 17 years) in favour of the Project Proponent, attested by a Notary Public, reserved for a period of at least 6 months from the closing date of submission of proposals, with the certified copies of the Deed of the land and the survey plan (clearly indicating the extent to be utilized for the plant). We trust that certification of the Deed and the Survey Plan by a Notary Public satisfies this requirement. Please confirm.	It shall be attested by a Notary Public. Although registration of the Deed (Agreement to Lease) is not mandatory, it must be duly attested by a Notary Public.
45)	We understand that bidding based on a "Letter of Intent to enter into a Joint Venture" is permissible. In this regard, please clarify the following: - Whether the purchase of the tender document by one intended JV partner is sufficient; - Whether an "Agreement to Lease" executed in favour of one intended JV partner is sufficient; and - Whether it is mandatory for the Bid Bond to be submitted in the name of the intended JV.	- Yes - Yes - Not mandatory. The Bid Security may be submitted in the name of the Lead Partner of the Joint Venture.
46)	As per the tender document, Six (6) of the Grid Substations (GSS) can each accommodate two (2) nos. of 10 MW/40 MWh systems. Please clarify whether the purchase of one (1) tender document is sufficient for a bidder to submit bids for both 10 MW/40 MWh systems at such a GSS	Please refer to Clause 1.3 of the RFP, which states: "Project Proponents shall purchase RFPs separately for each and every proposal they intend to submit for each Grid Substation." Accordingly, a separate RFP must be purchased for each proposal submitted under a Grid Substation.
47)	During the pre-bid meeting, it was clarified that the successful bidder/developer shall be responsible for obtaining the Bonded Warehouse Facility. The approval process, including the required documentation and regulatory clearances, typically takes approximately two months. Also, it will take additional time to get other regulatory approvals. Therefore, we kindly request that the scheduled commissioning date be extended by three (3) months. This extension would	Obtaining the bonded warehouse facility is the responsibility of the Bidder. However, please refer to Addendum No. 1, under which the Scheduled Commercial Operation Date (SCOD) has been extended by two (2) months.

	adequately account for the time required to obtain the necessary approvals without impacting on the project implementation schedule .	
48)	Kindly confirm whether the Bonded Warehouse Facility can be availed for all imported Balance of Plant (BOP) equipment , including transmiss ion line materials, accessories, and other ancillary equipment required for the project.	The Bonded Warehouse Facility is applicable only to imported equipment that forms part of the Battery Energy Storage System (BESS) facility. Transmission line materials, accessories, and other equipment required for the external grid interconnection works are outside the BESS facility and, therefore, are not eligible for the Bonded Warehouse Facility.
49)	Kindly clarify what would be considered as "Other financial resources" .	Such resources may include, but are not limited to, readily available and unpledged long-term deposits, loans receivable, and other liquid financial resources, provided that such resources can be demonstrated to be available to the Bidder for meeting the financial requirements of the Contract. The Bidder shall submit appropriate documentary evidence to substantiate the availability and adequacy of such financial resources.
50)	Volume 1 requires distribution frames/patch panel terminating 48 cores; Volume III requires 16 cores. Both specify 2 cables of 8 single mode cores.	It shall be 16 cores.
51)	Please confirm 1) whether and HVAC load is drawn through the Main Meter (therefore captured within RTE) or through a separate retail-tariff supply; and b)whether auxiliary load sits inside or outside the RTE calculation.	(a) Auxiliary and HVAC loads that are directly associated with the operation of the BESS Facility shall be supplied through the BESS electrical system and shall be accounted for in the RTE calculation. (b) General site loads that are not directly related to the operation of the BESS, such as CCTV, security systems, general lighting, and other similar facility loads, shall not be included in the RTE calculation. The RTE calculation shall therefore account only for the energy consumed by auxiliary systems and equipment directly required for the operation of the BESS Facility, in accordance with the specified RTE measurement and calculation methodology
52)	Article 3.2 lists events of issued document does not termination consequences-payment or buy-out formula GOSL political force majeure, force majeure. Please issue the termination provisions including the a) NSO default b) Political/FM and c) Prolonged FM	No separate termination compensation or buy-out formula is prescribed for termination arising from (a) NSO default, (b) political force majeure attributable to the Government of Sri Lanka, or (c) prolonged natural force majeure, other than the rights and obligations expressly provided in the ESA.
53)	By Contract Year 15, the Minimum Dispatchable Storage Capacity (DSC) is expected to reduce to approximately 68% of the Contracted Storage Capacity (CSC), equivalent to approximately 2.7 hours at the Contracted Power Capacity (CPC). Please confirm: (a) whether, in any Contract Year, NSO's Dispatch Instructions	For Contract Year 15, the applicable minimum ADSC shall be determined in accordance with the degradation requirements specified in the ESA. The resulting ADSC, rather than a fixed four-hour discharge duration, shall constitute the applicable energy limit for Dispatch Instructions. Eg: Assume:



	will be limited to the prevailing Available Dispatchable Storage Capacity (ADSC), and therefore NSO will not issue a continuous four-hour discharge instruction at CPC where the prevailing ADSC is less than four times the CPC; (b) how Dispatch Availability will be determined when the ADSC is expressed in MWh rather than as a fixed duration, particularly where a Dispatch Instruction would require energy exceeding the prevailing ADSC or the available State of Charge; and (c) whether any resulting shortfall in such circumstances will be excluded from the Company's Dispatch Availability performance assessment. A worked example illustrating the calculation of Dispatch Availability for Contract Year 15 would be appreciated.	- Contracted Power Capacity (CPC) = 10 MW - Contracted Storage Capacity (CSC) = 40 MWh - Minimum Dispatchable Storage Capacity (DSC) in Year 15 = $68\% \times 40 \text{ MWh} = 27.2 \text{ MWh}$ - Therefore, the Year-15 ADSC corresponds to 2.72 hours at 10 MW, not four hours. - A 15-minute dispatch at 10 MW requires 2.5 MWh.
54)	Please confirm an aggregate cap on liquidated damages per Contract Year and over the full 15 year Term, and confirm whether the round trip efficiency damage falls inside or outside those caps. Please also confirm an overall limitation of the Company's liability under the Agreement and a mutual exclusion of indirect and consequential loss.	- There is no aggregate cap on liquidated damages either per Contract Year or over the full 15-year Term. - The applicable cap on liquidated damages is monthly, as specified in Clause 2 of Appendix A of Volume III. - The Round Trip Efficiency (RTE) liquidated damages, if applicable, are subject to the relevant monthly liquidated-damages provisions/cap in Clause 2. - However, capacity charge deductions for failure to achieve the required 97% availability are not liquidated damages and therefore do not fall within the monthly LD cap. - Consequently, if the BESS fails to meet the 97% availability requirement, the capacity charge payable for that month may be reduced, potentially down to LKR 0, depending on the extent of unavailability.
55)	Please state whether a minimum State of Charge reserve, and charging and discharging power headroom, must be maintained continuously for frequency response, synthetic inertia, oscillation damping and AGC ; and if so their required magnitude. Please confirm that (a) any reserved power and energy is nonetheless treated as available for Capacity Availability and Contracted Storage Capacity purposes, and (b) energy exchanged in providing these services is excluded from the 400 Full Equivalent Cycle allowance and from the round-trip efficiency calculation.	(a) No. Any power or energy reserved for such services shall not be treated as available for the purposes of Capacity Availability and Contracted Storage Capacity. (b) No. Energy exchanged in providing such services shall not be excluded from the 400 Full Equivalent Cycle allowance or from the Round Trip Efficiency (RTE) calculation.
56)	Please confirm whether "Financial Closure" at this milestone means executed facility agreements and satisfied conditions precedent, or a committed term sheet or letter of intent. If the former, please extend the period to not less than six months from ESA signing, and confirm that NSO will provide the Direct Agreement, termination compensation regime and payment	Financial Closure shall mean that the financing required for the Project has been approved by the relevant lender(s). A committed term sheet or letter of intent shall not, by itself, constitute Financial Closure. Further financial closure should be achieved within 3 months from the execution of the ESA.

	security that lenders will require. As drafted, this milestone is achievable only on a balance sheet-funded basis, which narrows the bidder field and raises the price. loan should be approved.	
57)	Please specify the documents accepted as evidence of financial resources beyond audited working capital: whether bank certificates or reference letters, undrawn committed credit lines, sponsor support or shareholder undertakings, parent company guarantees, or letters of intent from lenders are acceptable, and in each case the required I form, addressee, currency and date of issue relative to the closing date.	Other Financial Resources refers to financial resources available to the Bidder for financing its current contractual commitments and the subject Contract, other than the Working Capital stated under Item 1 and the Credit Line stated under Item 2. Such resources may include, but are not limited to: • Long-term deposits / fixed deposits, provided that such deposits are available for use and have not already been included in the Bidder's declared Working Capital; and • Amounts receivable by the Bidder from financial institutions under loans or other financing arrangements, provided that such amounts are sufficiently certain and supported by appropriate contractual or documentary evidence. The Bidder shall submit appropriate documentary evidence to substantiate the availability and value of such financial resources. Such resources shall be available for use and shall not be otherwise committed, pledged, encumbered, or earmarked for other obligations.
58)	Manufacturer qualification requires 1 GWh of installed battery modules/cells, 1 GW of installed inverter products, and two projects using the same PPC product family, each "within the last three (3) years Please confirm: (a) whether the thresholds are cumulative global installed volume or annual;(b) whether shipped/contracted volume counts or only commissioned volume; (c) whether manufacturer self-certification on letterhead is acceptable evidence; (d) the acceptable form of the Expression of Interest, and whether an OEM's standard letter format is acceptable; and (e) whether the qualifications at cl.2.7.3 may be satisfied by a named subcontractor or by a consortium member, rather than by the Project Proponent itself.	a) Cumulative global installed volume achieved during the relevant qualification period, rather than an annual volume. b) Should be installed/commissioned volume, because the requirement says "installed." c) A manufacturer-issued declaration on official letterhead can be accepted as evidence, provided it clearly identifies the product, installed quantity/capacity, project(s), location, commissioning/installation date and relevant manufacturer. NSO may reserve the right to request supporting evidence. d) An OEM's standard Expression of Interest/letter format should be acceptable, provided it contains all information required by the RFP and is duly signed by an authorized representative of the manufacturer. e) The qualification should be satisfied based on the manufacturer/component supplier's experience, and therefore need not be experience of the Project Proponent itself.
59)	The PCS AC-side current must operate continuously at 110% of rated current, sustain 120% for 2 minutes, and "preferably" support 150% for 10 seconds . Please confirm whether 110% continuous is a firm requirement (it effectively mandates a 10% PCS oversize on top of the reactive requirement), and whether the 150% I 10 s capability is	Please comply with A.05.02 of Annex A

	mandatory or preferred. Please confirm the ambient temperature at which these ratings are to be demonstrated .	
60)	he RFP distinguishes equipment manufacturers and subcontractors from the Project Proponent, and permits a manufacturer, supplier or technical partner to support the proposal through an Expression of Interest or as a subcontractor . However, where such an entity becomes a member of the Joint Venture / consortium , cl.2.8.2.2 and the FIN forms appear to require every partner to demonstrate at least 25% of the Rs.600 million financial-resources requirement, regardless of whether that member has only a technical , manufacturing or supply role and provides little or no equity.Please confirm whether a battery, PCS or PPC manufacturer, equipment supplier, EPC contractor or other technical partner may participate in the bid without demonstrating financial resources where it is: (a) a named manufacturer / supplier or subcontractor but not a member of the Project Proponent; or (b) a non-equity or minority technical member of a Joint Venture / consortium . If every formal member must satisfy the 25% requirement, please confirm the permitted structure for including a technical partner without subjecting it to the financial resources test, and identify which entity or entities must complete Forms FIN-1 to FIN-4.	A battery manufacturer, PCS/PPC manufacturer, equipment supplier, EPC contractor or other technical partner may participate in supporting the bid without being a member of the Project Proponent/Joint Venture consortium, provided that such entity is identified as a manufacturer, supplier, technical partner or subcontractor in accordance with the RFP and provides the required Expression of Interest or subcontractor commitment, as applicable. However, where such an entity is included as a formal member of the Joint Venture/consortium, it shall be considered a consortium member for the purposes of Clause 2.8.2.2 and shall comply with the applicable financial-resources requirement, including the minimum 25% share of the required Rs. 600 million, irrespective of the nature or extent of its technical, manufacturing, supply or EPC role. Accordingly, where a technical or manufacturing partner is not intended to satisfy the financial-resources requirement, it shall be structured as a manufacturer, supplier, technical partner or subcontractor of the Project Proponent/consortium, and shall not be included as a formal member of the Joint Venture/consortium. The FIN-1 to FIN-4 forms shall be completed by each formal member of the Project Proponent/Joint Venture/consortium, as required by the RFP.
61)	where 2 BESS projects are connected to the same gss and both projects are awarded to the same bidder, would it be acceptable to utilize a single PPC and common communication infrastructure for both plants provided that the system is capable of independently controlling monitoring and communicating with each BESS plant in accordance with the applicable technical and operational requirements.	It should function as a common hardware platform providing two independent project-level control functions. Failure of the common PPC must not result in an uncontrolled or unsafe condition for either BESS. Appropriate redundancy/failover arrangements should therefore be provided. A common PPC must not cause one project's operating constraints or dispatch instructions to affect the other project. The communication interface with NSO/NSCC should allow the two projects to be addressed and controlled as two independent BESS facilities, even though the underlying PPC hardware is common.
62)	Most BESS suppliers have recently upgraded their BESS packages to more economical, higher-capacity solutions, such as 6.25MWh systems in 20-ft containers. These new packages generally utilize cells, racks, and other major components from the same product families that were used in their earlier certified platforms. However, due to the lengthy certification process and limited availability of certification bodies, the international certifications for some of these newly introduced BESS	Yes. Where the exact proposed BESS package is a newly introduced product and the relevant international certifications are still under certification, the bidder may submit, at the technical proposal stage, the currently available valid certifications for the applicable cells, racks, major components and/or established product family, together with documentary evidence demonstrating the relationship and technical equivalence between the

	packages are still in progress. In such cases, would it be acceptable to submit the technical proposal with the currently available certificates for the relevant cell, rack and or product family with the required certifications for the exact proposed BESS package to be submitted at a later stage prior to signing the ESA.	certified components/product family and the proposed BESS package.
63)	The RFP requires the installation of a firewall at the Grid Substation and refers to an "appropriate firewall/network switch" at the BESS end . Since the required firewall will already be installed at the Grid Substation, please clarify whether a separate firewall is also mandatory at the BESS facility, or whether a suitable managed network switch at the BESS end will be acceptable	A separate firewall is required at the BESS facility with suitable management system.
64)	The present RFP requires the PCS AC-side current to sustain 120% of the rated current for at least two minutes. However, during the previous tender process, this requirement was revised from two minutes to one minute. Accordingly, we kindly request that the requirement be amended to allow the PCS to sustain 120% of the rated current for at least one minute	Please comply with A.05.02 of Annex A
65)	The Capacity Charge Rate is variously expressed as LKR/MW, LKR/MW /month and LKR/kWh . Please confirm the correct unit for quotation, evaluation and monthly payment.	LKR/MW/month Clause 2.8.1 of Volume I should be corrected as : Capacity Charge Rate proposed by the Project Proponent = Y LKR/MW/month Applicable Capacity Charge Rate: $0.15 \times Y + (0.85 \times Y \times P2/P1)$ LKR/MWh/month
66)	Please confirm that the capacity payment during Contract Year I will be calculated using an ADSC/MDSC factor of 1.0, since no Year 0 ADSC or MDSC exists .	No. The reference to Contract Year 1 in the table refers to the end of the first Contract Year and does not imply during the 1st year. During Contract Year 1, the applicable Contract Storage Capacity shall be the capacity declared by the Bidder in Section 1 of Volume II at the bidding stage. The same declared Contract Storage Capacity is required to be achieved and demonstrated during commissioning.
67)	Please confirm the ownership, operation and maintenance responsibility for the dedicated MV interconnection line after commissioning. Volume I refers to ownership/maintenance by EDL, while Volume III assigns maintenance responsibility to the Company .	EDL
68)	Please confirm that delays attributable to GSS access, feeder outages, NSO/DL approvals or works within the GSS will result in an extension of the COD without forfeiture or damages.	Please refer clause 4.2 of the ESA
69)	For multiple proposals, please confirm whether the LKR 600 million financial- resource requirement applies separately to each project and how cumulative eligibility will be calculated.	The financial resource requirement of LKR 600 million shall apply separately to each project.

		Accordingly, where a Bidder submits proposals for multiple projects, the required financial resources shall be calculated cumulatively based on the number of projects for which proposals are submitted. For example: • 1 project: LKR 600 million • 2 projects: LKR 1,200 million
70)	Please confirm whether each proposal requires a completely separate submission, Proposal Security and RFP purchase, while common corporate and OEM documents may be cross referenced?	Each proposal shall constitute a complete and separate submission and shall independently satisfy all requirements of the RFP.
71)	Please clearly define the physical and contractual scope boundary between the developer, NSO and the relevant DL for the complete grid-interconnection facilities, from the BESS facility up to and including the Point of Interconnection at the Grid Substation.	Please refer Tri-partite agreement
72)	Please clearly identify the Termination Point, Metering Point, Grid Point and Point of Interconnection in a single approved drawing and specify the ownership and responsibility boundary applicable at each point.	Please refer the addendum no 1
73)	a) Clause 2.7.3 of Volume I and Section 10 of Volume II require the project proponent to nominate the manufacturers of the battery modules and cells, the inverters and PPC and to submit their experience records and Expressions of Interest with the proposal. The proposal is therefore bound, as submitted, to a single nominated supplier for each item. b) We respectfully request that NSO permit the successful Project Proponent to change a nominated supplier after award, provided that the replacement equipment fully complies with the specifications and qualification criteria set out in the RFP and that NSO's prior written approval is obtained.	a) Clause 2.7.3 of Volume I and Section 10 of Volume II require the Project Proponent to nominate the manufacturers of the battery modules/cells, PCS/inverters, PPC and other major equipment, together with the relevant experience records and Expressions of Interest. As clarified under Addendum No. 1, a bidder may submit proposals based on up to two alternative manufacturers/complete solutions. However, each proposal shall constitute a complete and technically integrated BESS solution, including the battery modules/cells, PCS/inverters, PPC, transformer and other applicable major equipment, as proposed by the respective manufacturers. The two proposals shall be considered as separate and complete solutions. The bidder shall not be permitted, during detailed design, construction or implementation, to combine or interchange major equipment between the two submitted solutions, such as using the battery system from one proposed solution together with the PCS/inverter or PPC from the other proposed solution. Any equipment supplied for the project shall therefore be consistent with one of the complete solutions submitted with the proposal and shall comply with the applicable technical requirements and approved design. b) No
74)	As per clause 5.6 of ESA it is understood that the interconnection facilities shall be constructed by the Company and handed over to the distribution licensee upon commissioning, following which the interconnection facilities shall be operated and maintained by the DL.	No. The Company will continue to be entitled to the applicable Capacity Charge in accordance with the ESA. Accordingly, the unavailability of the interconnection facilities shall not be considered to result in a loss of



	In this regard, will Company be entitled to compensation for any loss of availability, energy delivery or associated revenue resulting from the unavailability outage or failure of the interconnection facilities after they have been handed over to and are under the operation and maintenance responsibility of the DL.	revenue to the Company for which additional compensation is payable.
75)	At locations where the available network capacity permits the connection of two (02) 10 MW/40 MWh BESS projects (i.e., a total capacity of 20 MW), would it be permissible for both projects to utilize a common grid interconnection line, and, in such circumstances, would the same bidder be permitted to develop both projects using the same grid interconnection arrangement, subject to the approval of the relevant Distribution Licensee?	Due to network constraints, only one BESS project can be connected to a single 33 kV feeder. Accordingly, where two prospective projects are located such that their nearest feasible point of connection is the same 33 kV feeder, it is technically not feasible to accommodate both projects through the same feeder.
76)	Would it be possible for a prospective bidder to obtain or lease suitable land from the Board of Investment (BOI) for establishing the proposed BESS project, with the intention of connecting the project to the Horana Grid Substation (GSS) ?	The Board of Investment (BOI) has provided a Letter of confirmation that 80 perches of land within the Horana Export Processing Zone (HEPZ) may be allocated for the proposed BESS project to the successful bidder, subject to the prevailing land lease terms applicable to HEPZ at the time of signing the lease agreement. Prospective bidders may contact the BOI directly for further information regarding the availability, allocation, lease terms and other conditions applicable to the said land.



