

Test Report

Sample information					
Sample name	Specification/Model	Sample serial number	Sample quantity	Sample number	Date of Arrival
Energy Storage system	ENPCS-2520	/	1	YP2025122601	2025/12/26
Sample collection	The entrusting party sends samples.				
Manufacturer	Envision Energy Co., Ltd.				
Address of manufacturer	No. 3, Shengzhuang Road, Shengang Street Jiangyin City, 214443 Jiangsu P.R. China				
Sample state before test	The visual appearance of the sample is good and the structure is normal				
Laboratory information					
Test address	Building 10, No. 365 Lianyang Road, Songjiang Zone, Shanghai		Date of Test	2025/12/26~2025/12/31	
Ambient temperature	17.5°C~20.1°C	Ambient relative Humidity	41%~66%	Ambient atmospheric pressure	Atmosphere standard
Summary of test results					
Serial number	Project name	Test criterion	Test results	Page	
1	Constant damp heat test	IEC 60068-2-78 :2012	Meet the requirements	3	
2	Alternating damp heat Test	IEC 60068-2-30 :2005	Meet the requirements	3	
Written by	史玉洁	Reviewed by	罗宏		
Approved by	毛永光	Date of issue	2025/12/31		
Remark	/				