

TEST REPORT	
EN 50530:2010	
Overall efficiency of grid connected photovoltaic inverters	
Report reference No.:	CXBL-ESH-P25091384-4
Date of issue	2026-01-21
Total number of pages	49
Tested by	Damon Qian Test Engineer 
Approved by	Robin Wu Project Manager 
Testing Laboratory Name.....:	BUREAU VERITAS LCIE CHINA COMPANY LIMITED
Address	Building 4, No, 518, Xinzhuan Road, Caohejing Songjiang High-Tech Park, Shanghai, P,R,China (201612)
Testing Location	Zhejiang Fangyuan Test Group Co., Ltd.
Address	No.400, Guangqiong Road, Jiaxing, Zhejiang, China
Applicant's Name	Envision Energy Co., Ltd.
Address	No. 3, Shengzhuang Road, Shengang Street Jiangyin City, 214443 Jiangsu P.R. China
Test specification	
Standard.....:	EN 50530:2010
Non-standard test method	None
Test Report Form No.,	EN 50530
Master TRF:	BUREAU VERITAS LCIE CHINA COMPANY LIMITED
Test item description	Energy Storage System
Trademark.....:	 Envision
Model / Type	ENPCS-2520

Model / Type :	ENPCS-2520
DC operation voltage range [V]	1000-1500
Max. Input DC voltage [V].....	1500
Input DC current [A]	2829
Output AC voltage	3L/PE, 690V, 50Hz
Max. Output AC current [A].....	2320
Rated output active power [kW].....	2520
Max. output apparent power [kVA] ..	2772