

Envision Energy

Design Calculation Description for Sri Lanka 10MW/40MWh project

29/07/2026
V1.0

Table of Contents

1	Introduction	3
2	Key Project Information.....	3
3	General BESS Design Parameters.....	3
4	Proposed BESS Design	4
4.1	<i>Proposed Overall Solution.....</i>	4
4.2	<i>Performance Curves.....</i>	5
4.3	<i>Design Sizing.....</i>	8
4.3.1	DC Unit	8
4.3.2	AC Skid	8
4.4	<i>Assumptions</i>	9
5	PCC Requirements.....	9
6	Conclusion.....	10

Disclaimer

While every precaution has been taken in the preparation of this document, Envision Energy assumes no liability with respect to the operation or use of Envision Energy products and documentation described herein, for any act or omission of Envision Energy concerning such products or this documentation, for any interruption of service, loss or interruption of business, loss of anticipatory profits, or for punitive, incidental or consequential damages in connection with the furnishing, performance, or use of the Envision Energy products and documentation provided herein. Please use the applicable specifications in their latest versions. Images do not necessarily reflect the exact scope of supply. The actual scope of supply can be subject to technical alterations at any time.


1 Introduction

This document describes design calculations for the Sri Lanka 10MW/40MWh BESS project.

2 Key Project Information

Project name	Sri Lanka 10MW/40MWh BESS project
Environmental conditions	-30°C to +45°C.
Auxiliary losses	Calculated at 35°C
Voltage at Point of Connection (POC)	33kV
Power output at Point of Connection (POC)	10 MW (nominal)
Usable energy at Beginning of Life (BoL)	40 MWh required / 40.2 MWh offered
Cycles per day	1.1
Proposed solution	1 sets ENS-D10E-20100-10100-00 , 1 sets ENS-Do6G-24120-10100-000

3 General BESS Design Parameters




AC skid	PCS rated power	4 x 2520 kW
	Transformer voltages	0.69 kV / 33 kV
	Transformer type	3 windings
	Transformer rated capacity	10100 kVA
DC container	Voltage range of DC system	1165 VDC to 1500 VDC
	Rack configuration	10 racks per DC container

4 Proposed BESS Design

4.1 Proposed Overall Solution

1 sets ENS-D10E-20100-10100-00 , 1 sets ENS-D06G-24120-10100-000




Item	Value	Unit	Comments
Rated power	15.1	MVA	
Required active power	10	MW	At PoC
Usable active power	14	MW	At PoC
Installed capacity	44.2	MWh	
Usable capacity @ POC	40.2	MWh	At BoL


4.2 Performance Curves

1.1 cycles/day										
Year	Usable capacity at 33 kV including aux power (MWh)	Usable capacity at 33 kV excluding aux power (MWh)	System SoH including aux power	System SoH excluding aux power	RTE including aux power	RTE excluding aux power	DC Usable Discharge Capacity (MWh)	DC-DC RTE	Export in Previous Year (MWh)	Cumulative Export (MWh)
BoL	40.2	40.8	100%	100%	86.3%	89%	41.9	94.4%		
1	39.4	40.1	98.2%	98.3%	86.1%	89%	41.2	94.3%	15992	15992
2	38.5	39.1	95.8%	95.9%	85.9%	88.9%	40.2	94.3%	15659	31652
3	37.6	38.3	93.7%	93.8%	85.8%	88.9%	39.4	94.2%	15295	46947
4	36.9	37.5	91.8%	92%	85.7%	88.8%	38.6	94.1%	14976	61923
5	36.2	36.8	90.1%	90.3%	85.6%	88.8%	37.9	94.1%	14685	76609
6	35.5	36.2	88.4%	88.7%	85.5%	88.7%	37.2	94%	14415	91024
7	34.9	35.6	86.9%	87.2%	85.5%	88.7%	36.6	94%	14160	105185
8	34.3	35	85.5%	85.7%	85.4%	88.6%	36	94%	13919	119104
9	33.8	34.4	84.1%	84.3%	85.3%	88.6%	35.4	93.9%	13689	132793
10	33.2	33.9	82.7%	83%	85.2%	88.6%	34.8	93.9%	13468	146261
11	32.7	33.3	81.4%	81.7%	85.2%	88.5%	34.3	93.9%	13256	159518

12	32.2	32.8	80.2%	80.5%	85.1%	88.5%	33.8	93.8%	13051	172569
13	31.7	32.4	79%	79.3%	85%	88.5%	33.3	93.8%	12854	185424
14	31.3	31.9	77.8%	78.2%	85%	88.5%	32.8	93.8%	12663	198087
15	30.8	31.4	76.7%	77%	84.9%	88.4%	32.3	93.7%	12478	210566



*Usable capacity at PCC including the auxiliary losses



*Note that the above values are contingent upon the assumed loss factors shown in the following table. Furthermore, it is important to note that these values may exhibit a slight variation of 1-2 % in response to actual site conditions, attributable to fluctuations in ambient temperature (± 5 °C deviation) and the measurement accuracy of external metering equipment (such as PT, CT, etc.). Rest assured, we remain committed to ensuring precision and transparency throughout this project's execution.

4.3 Design Sizing

4.3.1 DC Unit

ENS-D10E-20100-10100-00	Value	Unit	Comments
DC container configuration	10051	kWh	10 racks connected in parallel per Container
Nameplate capacity type 1	20.101	MWh	2 containers connected per AC twin-skid

ENS-D06G-24120-10100-000	Value	Unit	Comments
DC container configuration	6030	kWh	6 racks connected in parallel per Container
Nameplate capacity type 2	24.121	MWh	4 containers connected per AC twin-skid

4.3.2 AC Skid

Item	Value	Unit	Comments
Step up transformer	10.1	MVA	
PCS	2.52	MVA	
AC unit	10.08	MW	MV AC container. 4x PCS & 1x transformer

4.4 Assumptions

Item	Efficiency	Remarks
Calendar degradation	97 %	From cell manufacture to Site Acceptance Test (SAT). Assuming 6 months from Factory Acceptance Test (FAT) to SAT
Usable DC capacity ratio	98 %	Includes battery cell efficiency & DOD limitations
LV DC cables	99.9 %	Assuming that the cables are aluminium @ 30m, provided by BoP
PCS	98.5%	At Rated Power, provided by Envision
LV/MV transformer	99.2%	Compliance with EU Ecodesign standards, provided by Envision
MV/HV transformer	100 %	Assumed, provided by BoP
MV cable	99.5 %	Assumed, provided by BoP
HV cable	100 %	Assumed, provided by BoP


Item	Energy consumption	Remarks
Aux consumption at BoL	0.16 MW x 4.02 h	Auxiliary consumption cannot be guaranteed separately

Item	Impedance	Remarks
LV/MV transformer	9 %	Compliance with EU Ecodesign standards
MV/HV transformer	16 %	Assumed, provided by BoP

5 PCC Requirements

Parameter	Unit	Discharge-Overexcitation	Discharge-Underexcitation	Charge-Overexcitation	Charge-Underexcitation
P required at PCC	MV	10	10	-10	-10
S required at PCC	MVA	10.53	10.53	10.53	10.53
Q required at PCC	MVAR	3.29	-3.29	3.29	-3.29
Power factor at PCC	-	0.95	-0.95	0.95	-0.95
P required at PCS	MW	10.34	10.34	-9.66	-9.66
S required at PCS	MVA	11.24	10.57	10.6	9.91

Q required at PCS	MVAR	4.41	-2.17	4.37	-2.21
Power factor at PCS	-	0.92	-0.98	0.91	-0.97



*Note that the above power flow calculation results are only valid when the PCS terminal voltage is within 0.9–1.1 pu range.

6 Conclusion

This document describes and proposes 1 set ENS-D10E-20100-10100-00, 1 set ENS-D06G-24120-10100-000 for the Sri Lanka 10MW/40MWh BESS project. It outlines the essential parameters of the DC unit of the BESS with representative images of the DC containers, including details of the performance curves, State of Health (SoH) of battery and Round-Trip Efficiency (RTE) of the battery in accordance with the project's stipulated requirement. The yearly usable energy capacity of the system has also been presented in the performance curve table throughout the design life of the project.

Whilst every effort has been taken to ensure accuracy of the report, we reserve all rights to amend and update our materials, data and images without providing prior notification. We remain committed to providing you our best support.