



TEST CERTIFICATE

(This certificate is not valid without a hologram)

Page : 1/1

Sample : Heat Insulation Tile	Report No. : 21001487
Sample Description : COOLA-Heat Insulation Tile	
Customer Ref : Nil, Dt.-28/06/2019	Report Issue Date: 08/07/2019
Customer Name & Address : Maxshield Insutech Technologies No-65, Arun Complex, D.V.G. Road, Basavangudi, Bangalore, Karnataka - 560004	Job Code STRC/21001487
	Sample Received On 02/07/2019
	Date of Testing 02/07/2019-06/07/2019
	Sample Quantity 6 Piece of sample
	Sample Condition: Packed in carton box

S. No.	Test Parameters	Test Results	Test Method
1.	Thermal Conductivity, W/m-K	0.188	IS: 3346-1980
2.	Test Sample Dimension, mm	202x198	--
3.	Thickness as Tested Sample, mm	30.06	--
4.	Test Density, kg/m ³	2282	--
5.	Mean Temperature of test, °C	24.9	--
6.	Orientation of test samples	Horizontal	--
7.	Special Remarks	Two specimen were used at testing time	--

***** End of Report *****

Shanmy
(PRIVANKA)

Format No.: STRC/7.8/F/TC/Z/03



WWW.SIGMA TEST.O

(1) The Test results listed refer only to tested samples and applicable parameters. Endorsement of product is neither inferred nor implied. (2) Total liability of our Lab is limited to the invoiced amount. (3) Sample(s) are retained for 7 days (in case of perishable items) and 30 days for non perishable samples or unless otherwise specified. This Test Report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of Law and should not be used in any advertising media without our special permission in writing. (5) The Test Report refers to the sample submitted to us and not drawn by Sigma Test & Research Centre unless mentioned otherwise.