

3.3.9. Inspect DFE Rack for Component Warnings

Estimated Frequency	Estimated Time	Press Down	Suggested Personnel
Monthly	15 minutes	No	1 person
Objective			
Inspect the components looking for red and orange lights indicating component warnings.			
Personal Protective Equipment (PPEs)		Tools/Materials	
<input type="checkbox"/> None		<input type="checkbox"/> None	

Procedure

1. Access the DFE rack room.
2. Inspect the rack looking for orange and red lights. These warning lights indicate that the components may be near, or have reached a failed state. Please see the attached photos.
3. If there are failure warnings on the components contact the call center or Engineering Support Personnel.



Note the red lights as indicated by the arrows.

Figure 28. Looking for hard drive warnings on the DFE rack