

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Memo/School/038/25-26

Dated: 16/06/2025

It is certified that an inspection team headed by Dr. Shailendra Yadav with Team

(Name of Officers with designation) from PHE Meerahy PHED

inspected the Kayatari Gaurukul Public School, Saray Kalidas, Meerahy Jounpur

(Name & Address of the school) on 16/06/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. RW.T.L./VNS/405/25-26 dated 14/06/2025

of Regional Water Analysis Laboratory PHED Jal Nigam Bhojpur Varanasi

the Kayatari Gaurukul Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One Year 16/06/2026

Signature with Seal:

Name :

Designation :

Name & Address of the Office / Department :

To The Manager

(Name & Address of the Institution)

Kayatari Gaurukul Public School Meerahy Jnp.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



REGIONAL WATER ANALYSIS LABORATORY, UTTAR PRADESH JAL NIGAM
Bhagwanpur, Varanasi – Uttar Pradesh 221005



*** TEST REPORT ***

<u>Gayatri Gurukul Public School,</u> <u>Saraikalidas, Mariahu, Jaunpur, U.P.</u>			Customer Reference No.		No: 405/VNS/09 Dated: 14/06/2025	
			Sample Submitted by		SOHAN LAL VISHWAKARMA	
			Date of Sample Receipt		14/06/2025	
			Analysis Starting Date		14/06/2025	
			Analysis completion Date		14/06/2025	
Discipline: Chemical Testing			Group: Water			
Test Report No.:	RWTL/VNS/405/25-26		Date of Issue:		14/06/2025	
Registration no.:	RWTL/SNG/2526/REG405		Condition of Sample:		Unsealed	
Source:	NA		Quantity/Type of Bottle:		1000 ml / Amber Colored Glass Bottle	
Scheme:	NA		Location/Depth:		RO plant Gayatri Gurukul Public School, Saraikalidas, Mariahu, Jaunpur, U.P./ NA	
Village:	SARAYKALIDAS		Habitation:		NA	
Block: -	MARIAHU		District:		Jaunpur	
Latitude:	NA		Longitude:		NA	
Sample Type: Treated Water						
Sr. No	Parameter	Result	As per 15-10500:2012 (2 nd Rev.)		Unit	Reference Method:
			Acceptable Limit	Permissible Limit		
1	pFI	7.90	6.5-8.5	No Relaxation		IS 3025 (Part 11-1993) Electrometric Method
2	Colour	01	5	15	Hazen	IS 3025(Part 4-2021) V i s u a l Comparison Method
3	Odour	Agreeable	Agreeable	Disagreeable		IS 3025 (Part 5 -2018) (Second Revision)
4	TDS	210	500	“2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	1.19	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	130	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	170	200	600	mg/l	I63025 (Pan 21- 2019) EDTA Method
8	Calcium	83	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	23	30	100	m\$/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	81	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition:

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed)
5. * Value not available or test not performed for this parameter.



Dr. Ramesh Yadav
Quality Manager
Authorized Signatory
For, Regional Water Analysis,
Laboratory Jal Nigam Varanasi- UP.

End of the Test Report