Heat Transfer in Fires	
rieat iransier iir riies	
Fire	
Fire can be described in many ways - here are a few:	
NFPA 921: "A rapid oxidation process, which is a chemical reaction resulting in the evolution of light and heat in varying intensities."	
Webster's Dictionary: "A fire is an exothermic chemical reaction that	
emits heat and light"	
Fire can also be explained in terms of the Fire Tetrahedron	
a geometric representation of what is required for fire to exist,	
I fuel, an oxidizing agent,	
Dheat, and	
an uninhibited chemical reaction.	

Meas	urina	Fire
Micas	uiiig	

- Heat Energy is a form of energy characterized by vibration of molecules and capable of initiating and supporting chemical changes and changes of state (NFPA 921).
- In other words, it is the energy needed to change the temperature of an object add heat, temperature increases; remove heat, temperature decreases.
- Heat energy is measured in units of Joules (J), however it can also be measured in Calories (1 Calorie = 4.184 J) and BTU's (1 BTU = 1055 J).


- **Temperature** is a measure of the degree of molecular activity of a material compared to a reference point.
- Temperature is measured in degrees Farenheit (melting point of ice = 32 ° F, boiling point of water = 212 ° F) or degrees Celsius (melting point of ice = 0 ° C, boiling point of water = 100 ° C).

Temperature	Response
°C (°F)	
37.0 °C (98.6 °F)	Average normal human oral/body temperature ¹
38 °C (101 °F)	Typical body core temperature for a working fire fighter ²
43 °C (109 °F)	Human body core temperature that may cause death ³
44 °C (111 °F)	Human skin temperature when pain is felt ⁴
48 °C (118 °F)	Human skin temperature causing a first degree burn injury 4
54 °C (130 °F)	Hot water causes a scald burn injury with 30 s exposure 5
55 °C (131 °F)	Human skin temperature with blistering and second degree burn injury ⁴
62 °C (140 °F)	Temperature when burned human tissue becomes numb 4
72 °C (162 °F)	Human skin temperature at which tissue is instantly destroyed 4
100 °C (212 °F)	Temperature when water boils and produces steam ⁶
250 °C (482 °F)	Temperature when charring of natural cotton begins
>300 °C (>572 °F)	Modern synthetic protective clothing fabrics begin to char 7
≥400 °C (≥752 °F)	Temperature of gases at the beginning of room flashover 8
≈1000 °C (≈1832 °F)	Temperature inside a room undergoing flashover 8


· Heat Release Rate (HRR) is th	a rate at which fire releases	
energy - this is also known as pov		
• HRR is measured in units of		
International System unit equal to	one Joule per second.	
· Depending on the size of the fir	e, HRR is also measured in	
Kilowatts (equal to 1,000 Watts) of	r Megawatts (equal 1,000,000	
Watts).		
		-
 Heat Flux is the rate of heat energy area - kW/m². 	gy transferred per surface unit	
area RVV/III .		
	Evample	
Heat Flux (kW/m²)	Example Sunny day	
	Sunny day	
Heat Flux (kW/m²)		
Heat Flux (kW/m²) 1 2.5	Sunny day Typical firefighter exposure	
Heat Flux (kW/m²) 1 2.5 3-5	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test	
Heat Flux (kW/m²) 1 2.5 3-5 20 84	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971)	
Heat Flux (kW/m²) 1 2.5 3-5 20	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test	
Heat Flux (kW/m²) 1 2.5 3-5 20 84	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971)	
Heat Flux (kW/m²) 1 2.5 3-5 20 84	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971)	
Heat Flux (kW/m²) 1 2.5 3-5 20 84	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971)	
Heat Flux (kW/m²) 1 2.5 3-5 20 84	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971)	
Heat Flux (kW/m²) 1 2.5 3-5 20 84	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971)	
Heat Flux (kW/m²) 1 2.5 3-5 20 84	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971)	
Heat Flux (kW/m²) 1 2.5 3-5 20 84	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971)	
Heat Flux (kW/m²) 1 2.5 3-5 20 84	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971)	
Heat Flux (kW/m²) 1 2.5 3-5 20 84	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971)	
Heat Flux (kW/m²) 1 2.5 3-5 20 84	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971)	
Heat Flux (kW/m²) 1 2.5 3-5 20 84 60 - 200	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971) Flames over surface	
Heat Flux (kW/m²) 1 2.5 3-5 20 84	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971) Flames over surface	
Heat Flux (kW/m²) 1 2.5 3-5 20 84 60 - 200	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971) Flames over surface	
Heat Flux (kW/m²) 1 2.5 3-5 20 84 60 - 200	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971) Flames over surface	
Heat Flux (kW/m²) 1 2.5 3-5 20 84 60 - 200	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971) Flames over surface	
Heat Flux (kW/m²) 1 2.5 3-5 20 84 60 - 200 Fundamentals of Heat Tra	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971) Flames over surface	
Heat Flux (kW/m²) 1 2.5 3-5 20 84 60 - 200	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971) Flames over surface	
Heat Flux (kW/m²) 1 2.5 3-5 20 84 60 - 200 Fundamentals of Heat Tra • Concept of Specific heat • Joule, watt, calorie	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971) Flames over surface	
Heat Flux (kW/m²) 1 2.5 3-5 20 84 60 - 200 Fundamentals of Heat Tra	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971) Flames over surface	
Heat Flux (kW/m²) 1 2.5 3-5 20 84 60 - 200 Fundamentals of Heat Tra • Concept of Specific heat • Joule, watt, calorie	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971) Flames over surface	
Heat Flux (kW/m²) 1 2.5 3-5 20 84 60 - 200 Fundamentals of Heat Tra • Concept of Specific heat • Joule, watt, calorie	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971) Flames over surface	
Heat Flux (kW/m²) 1 2.5 3-5 20 84 60 - 200 Fundamentals of Heat Tra • Concept of Specific heat • Joule, watt, calorie	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971) Flames over surface	
Heat Flux (kW/m²) 1 2.5 3-5 20 84 60 - 200 Fundamentals of Heat Tra • Concept of Specific heat • Joule, watt, calorie	Sunny day Typical firefighter exposure Pain to skin within seconds Threshold flux to floor at flashover Thermal Protective Performance Test (NFPA 1971) Flames over surface	

Fundamentals of Heat Transfer


- Fire is combustion
- The process of combustion and its sustenance is all about heat transfer.



Fundamentals of Heat Transfer







Flame	
Fundamentals of Heat Transfer	
Why is heat transfer so important to understand?	
• to understand how a fire may have spread from one area of a structure to another through no readily visible path.	
 Indicates how a fire may start in one building and spread to another, again with no direct contact being made by flame. 	
Heat transfer is defined by NFPA 921 Guide to Fire and Explosion Investigation as	
"the transport of heat energy from one point to another caused by a temperature difference between those points."	


Fundamentals of Heat Transfer




Heat Transfer and Heat Flux

Combustion requires energy to activate the fuel components


and initiate the burning process (activation energy).






Heat Transfer and Heat Flux	
In general, however, heat transfer during a fire is primarily by	
convection and radiation while heat transfer by conduction is	
relatively low.	
Modes of Heat Transfer	
vioues of fleat flatister	
he spread of fire from one body to another may materialize by:	
continuity of a burning object with combustibles that are not burning,	
physical transport of burning objects (like sparks), or	
transfer of heat energy through one of the three modes of heat	
transfer Conduction, Convection, Radiation	
Heat transfer is a major factor in the ignition, growth, spread,	
decay and extinction of a fire.	
It is important to note that heat is <i>always</i> transferred <i>from</i> the	
hotter object to the cooler object heat energy transferred to and object increases the object's	
temperature, and heat energy transferred from and object decreases the object's	
temperature.	

MODES OF HEAT TRANSFER





Conduction

 "Conduction" is the transfer of heat from one part of a substance to another part of the same substance, or from one substance to another in physical contact with it, without appreciable displacement of molecules forming the substance.

HEAT TRANSFER BY CONDUCTION

- FOURIER'S LAWS OF HEAT CONDUCTION
- The rate of flow of heat through a simple homogeneous solid is...



FOURIER'S LAWS OF HEAT CONDUCTION

$$Q = - k \cdot A \frac{dt}{dx}$$

• The governing equation for heat transfer by conduction is:


$$\dot{q} = \frac{kA(T_{Hot} - T_{Cold})}{L}$$

Where

- T is temperature (in Kelvin),
- A is the exposure area (meters squared),
- L is the depth of the solid (meters), and
- k is a constant that unique for different materials known as the thermal conductivity and has units of (Watts/meters*Kelvin).

TI 10 1 11 11 (11)	
Thermal Conductivity (K)	
$\bullet Q = KA*(t_1 - t_2)/L$	
• unit of thermal conductivity	
• W/m° C.	
Thermal Conductivity (K)	
Thermal conductivity (a property of material) depends essentially	
upon the following factors :	
(i) Material structure	
(ii) Moisture content	
(iii) Density of the material	
(iv) Pressure and temperature (operating conditions).	
Thermal Conductivity	
 Thermal conductivity of most metals decreases with the increase in temperature (aluminium and uranium being the exceptions). 	
• In most of <i>liquids</i> the value of thermal conductivity tends to decrease	
with increase in temperature (water being an exception) due to	
decrease in density with increase in temperature.	
 In case of gases the value of thermal conductivity increases with increase in temperature. 	
moreuse in temperature.	

Copper = 387	Gypsum = 0.48
Steel = 45.8	Oak = 0.17
Glass = 0.76	Pine = 0.14
Brick = 0.69	PPE = 0.034 - 0.136
Water = 0.58	Air = 0.026




Summary

- Conduction is the form of heat transfer that takes place within solids when one portion of an object is heated.
- Energy is transferred from the heated area to the unheated area at a rate dependent on the difference in temperature and the thermal conductivity (k) of the material.

T	
Example	
 Metal I-Beam or truss located in a room and passing through a wall to another room that is being impinged upon by a fire. 	
 As the beam or truss heats, the temperature increases along the I- Beam or truss to the cooler end. 	
 The end opposite the fire heats up, and if it reaches the auto ignition temperature of combustible materials close to it, a second fire will 	
start.	
 The subsequent second fire may lead one to identify two separate points of origin. 	
Heat Transfer by Convection	
Convection	
"Convection" is the transfer of heat within a fluid by mixing of one	
portion of the fluid with another.	
Convection is possible only in a fluid medium and is directly linked	
with the transport of medium itself.	
Convection currents Coolet	
T _{cad} Warmer water descends	
waterrises	

Heat Transfer by Convection



Heat Transfer by Convection



Heat Transfer by Convection

- Fire scenarios can demonstrate a combination of both forms of convective heat transfer and analyses must address both phenomena.
- Newton's law: Q = h A Δt

The	governing	equation	for	heat	transfer	by
conv	ection is:					

$$\dot{q} = h(T_{Hot} - T_{Cold})A$$

Where:

T is temperature (in Kelvin),


A is the area of exposure (in meters squared), and

h is a constant that is unique for different materials known as

the convective heat transfer coefficient, with units of W/m2*K.

These values are found *empirically*, or, by experiment.

For free convection, values usually range between 5 and 25. But for forced convection, values can range anywhere from 10 to 500.



Summary

- "Convection is the transfer of heat energy by the movement of heated liquids or gases from the source of heat to a cooler part of the environment.
- An example of convection is air contacting heating elements, as in a furnace, and being heated to comfort temperature.
- Convection plays a significant role in fire investigation because it is one of the initial means for fire to spread by the hot or super heated gases and products of combustion spreading out into the upper portions of the room or area of origin.
- This is why we see soot and other products of combustion spread throughout a structure and even in rooms that are a significant distance away and have no direct flame impingement.

Dadiation	
Radiation	
• "Radiation" is the transfer of heat through space or matter by means	
other than conduction or convection.	

T _{Hot} \longrightarrow \triangle	
→ → →	
Heat Transfer by Radiation	
Radiation is an important mode of heat transfer in large fires that may	
cause the fire to spread to other combustible materials.	
• In the case of radiant heat transfer between two surfaces, the	
tendency of the cooler body to get heated depends on the type of surface of the cooler body.	
surface of the cooler body.	
Heat Transfer by Radiation	

Heat	Transfer	hν	Radiation

- The famous Stefan-Boltzmann equation states the energy emitted by a body as Q = $\epsilon \sigma A t^4$
- where σ is the Stefan-Boltzmann constant (5.67 x $10^{\text{-}8}$ W/m²K) and
- \bullet ϵ is the emissivity of the surface, which is a measure of the efficiency of the surface as a radiator of heat.

The governing equation for heat transfer by radiation is:

$$\dot{q} = (\varepsilon \alpha T_{Hot}^4) A$$

Where


Tis temperature (in Kelvin),
A is the area of exposure (in meters squared),

 α is the thermal diffusivity (a measure of how quickly a material will adjust it's temperature to the surroundings, in meters squared per second) and ϵ is the emissivity (a measure of the ability of a materials surface to emit energy by radiation).

Effects of thermal radiation

Incident thermal radiation (kW/m ²)	Effect
37.5 sustained	Damage to equipment and exposed steel structures
30.0 sustained	Limit for Class 1 building materials
12.5 sustained	Melting plastic
4.0	Blistering on skin on brief exposure
1.6	Severe hot feeling
1.0	Received at sea level on the equator at noon


		·



Summary

- "Radiation is the transfer of heat energy from a hot surface or gas, the radiator, to a cooler material, the target, by electromagnetic waves without the need of an intervening medium.
- Radiant energy can be transferred only by line of sight and will be reduced or blocked by intervening materials."
- A good example of radiation heat transfer is the "heat from the sun being radiated to the earth through a vacuum."
- Another example of radiant heating is the heat that you feel that is being radiated from a fireplace when you stand in front of it.


Temperatures Vs Heat in Fire



Temperatures Vs Heat in Fire

- combustion is a rapid exothermic chemical reaction but combustion itself may be of different types.
- temperature is important in a fire
- vital parameters to determine sustenance and spread of fire...
- temperature
- $\mbox{\ }^{\mbox{\tiny .}}$ total heat generated by the combustion process,
- as well as the heat release rate (HRR).
- temperatures like flash point, fire point and ignition temperatures

During a fire scenario....




Growth of Fire


- Concept of heat of combustion
- In real fires, however, different fuels may be burning simultaneously and also, fires normally do not reach complete combustion even if there is adequate ventilation.
- A part of the chemical heat release rate is transferred beyond the ignition zone through the fuel as conductive heat flux and another part as convective and radiative heat fluxes from the flame.

1	ጸ

Country of Fina	
Growth of Fire	
If this heat transfer meets the criteria (Critical Heat Flux and Thermal Response Parameter)	
chemical the process	
increase in flame height, heat release rate for further fire growth	
- 1 6-	
Growth of Fire	
As the fire propagates and grows, pyrolysis and hence, mass loss due	
to gasification of the burning material also increases till it reaches a steady state.	
• The mass loss rate depends on factors such as the heat flux reaching	
the burning material from the flame and external sources, the heat flux lost from the fuel surface by reradiation and the heat of	
gasification.	
stages of a fire	
FUEL	
• The NFPA and most other standards classify four stages of a fire.	
1.Ignition 2.Growth	
3.Fully Developed 4.Decay	

Fire Development is a function of many factors including	
fuel properties,	
fuel quantity,	
ventilation (natural or mechanical),	
compartment geometry (volume and ceiling height),	
• location of fire, and	
ambient conditions (temperature, wind, etc).	
Fully Developed	
Growth Decay	
E Grown	
f /	
Ignition	·
Time	
•	
Stage 3	
Fully-developed	
Ignition / Incipient stage is when it's crucial to fight a fire	
it is assigned to a superson it at this assign through a superson that the same	
it is easiest to suppress it at this point, It will cause the least damage	
difficult to manually fight and extinguish a fire when it is in this	
stage because of the time it takes to identify the fire, locate a	
handheld extinguisher, and perform the proper steps to spray the	
fire.	
Firetrace's detection tubing detects and suppresses fires	
automatically during this early stage.	
automatically during this early stage.	
Fire suppression systems allow you to suppress the fire right after	
ignition without needing a person to be present.	
w 2 0	
fire reaches this stage, it becomes harder to control	
If a fire detector recognizes a fire at this point, you have little time to	
put it out before it reaches flashover.	
flashover as "a transitional phase in the development of a	
compartment fire in which surfaces exposed to thermal radiation reach	
its ignition temperature more or less simultaneously and fire spreads	
rapidly throughout the space resulting in full room involvement or total	
involvement of the compartment or enclosed area."	
This means there is a sudden ignition of everything combustible in a	
contained area. Temperatures can rise to 1,000 degrees Fahrenheit in	
just a few seconds. Humans are not likely to survive in a compartment	
that has a flashover Ignition Flashover Decay Time	
agranor namorus Loudy IIII e	





Fire severity

- Fire severity is a quantitative measure of the effects of a fire on the environment, typically considering both the damage to vegetation and the impacts on the soil.
- · Fire severity is described along a spectrum,
 - Unburned/low severity,
 Moderate severity, and

 - · High severity.

 Fire severity is driven by multiple factors that affect how a fire behaves. Those factors are often depicted in what's called a "fire behavior triangle." The three major factors in the triangle are: The weather conditions during the fire (wind, temperature, humidity) The topography of the landscape (slope, aspect) The amount, arrangement, and types of fuels that are present during the fire 	
When fires burn during extreme weather conditions, weather almost always overrides the other local factors when fuels are present. Weather that can lead to rapid fire growth and extreme conditions wind speeds are greater than 20 miles per hour at slightly above ground level, temperatures are at 80°F or greater, and relative humidity is less than 20 percent. Weather conditions on a fire can change daily or even within the day.	
 Fire severity is also influenced by topography. Fires tend to be more severe on mid- and upper-slope positions than on lower slopes because wind speeds and convection winds are often greater on the upper slopes due to drainages, canyons, and saddles that channel upslope winds. In most cases, south- and west-facing slopes burn more severely than north-facing slopes because these aspects get more sun for longer periods. Natural barriers such as rock outcroppings and waterways can help to slow the spread of a fire and decrease the severity. 	

•	The amount, arrangement, type of fuels (including live	and
	dead vegetation), and the duration of the burn are import	tant
	factors that determine how a given fire will respond to	the
	landscape and to the degree of fire severity.	

- For example, high-severity burned areas are generally associated with two types of forests:
 - Dense, multi-layered forests with "ladders" of flammable materials that allow a ground fire to ignite the canopy; and
 - Uniform, young, even-aged forests.

Factors contributed to an overall increase in fire severity

- warmer and drier climate conditions,
- past management practices (removal of fire-resistant trees and excess fuels left on the site),
- an increase in human-caused fires, and
- fire suppression (which allows the amount of fuel to increase)
- For example, areas of central, eastern, and southwestern Oregon, where fires have historically burned frequently at low and moderate severities, are now experiencing a greater proportion of high-severity fires.



Top and middle photos: Stephen Fitzgerald, © Oregon State Univers

1	2
7	.5

 A high-severity fire in a watershed can have negative effects on water quality due to runoff and sedimentation, or on aquatic species due to increased water temperatures from 	
overstory vegetation damage or death.	
 However, high-severity fires don't always lead to negative impacts on resources of value. 	
 They can also provide habitat for some species and enhance early seral biodiversity. 	-
 In fact, many species of birds, mammals, insects, and plants depend on high-severity fire to meet their ecological 	
requirements. • The black-backed woodpecker is one good example.	
This bird uses patches of dead trees for nesting and foraging.	
One can't manipulate weather or topography to affect fire	
severity, we can manipulate fuels. Land managers use treatments such as thinning and	
prescribed fire, where appropriate, to prevent excessive fuel buildup.	
 These efforts can help minimize the impact of a fire on the vegetation and soil. 	
 However, such measures must be deployed over large areas in order to affect a fire's behavior and severity. 	
<u>†</u>	
Fire under	
Fre under verifished	

Spontaneous Heating and	
Spontaneous Combustion	
Maria Ma	
highlights to all mi	
New Kenda coal mine accident in Bihar meed for safety measures	
measures	
The Total Sea Marie	

Spontaneous Heating and Spontaneous Combustion

- pilot ignition: preheating and ignition by an external source
- Spontaneous heating: process of self-heating due to microbial growth and biochemical oxidation reactions of living organisms.

Types of combustion:



Difference between rapid and spontaneous combustion

Rapid combustion	Spontaneous combustion		
It is to be initiated once.	It take place by itself.		
External heat is required to start it once.	No external heat is required to start it.		
 Large amoutn of heat and light is evolved in a short time. 	Small amount of heat and light is evolved.		



Spontaneous Heating and Spontaneous Combustion	
To develop into self-ignition, the activities must be exothermic and three factors interact to control the chain of events, viz.,	
The dimensions of the stored material, The ambient temperature and	
Heat conduction through the material.	
Spontaneous Heating and Spontaneous Combustion	
Spontaneous heating and fire in coal mines is a major problem worldwide Majority of fires existing today in different coalfields are mainly due to spontaneous combustion of coal. The auto oxidation of coal ultimately leads to spontaneous combustion which is the major root cause for the disastrous of coal mine in leading and coal producing countries like USA, China, Australia, India and Germany. It is a slow process and the heat evolved is carried away by air.	
Spontaneous Heating and Spontaneous	
Combustion	
process of self-heating of coal or other carbonaceous material resulting eventually in its ignition is termed as "spontaneous heating" or "auto oxidation".	
Coal can interact with oxygen in the air at ambient temperature liberating heat.	
If the heat is allowed to accumulate the interaction rate increases and may ultimately lead to fires – known as spontaneous fires.	

Spontaneous	Heating	and	Spontaneous
Combustion			


- The exact mechanism of the reaction of oxygen with coal is not completely understood as the chemical nature of coal is not yet fully established.
- Most popular hypothesis is that the overall reaction proceeds through
 a chain mechanism with moisture facilitating the formation of free
 radicals that act as chain carrier.

Heat Release Rate (HRR)

- size of a fire: People often perceive it by the height of flames or the damage done.
- Fire engineers, expressing the 'size' of a fire, by *heat release rate* (HRR).

Temperature vs. Heat Release Rate





2	R



