

INDIAN STANDARD: IS 10500 : 2012
DRINKING WATER · SPECIFICATION (Second Revision)

1. SCOPE

This standard prescribes the requirements and the methods of sampling and test for drinking water.

2. REQUIREMENTS

Drinking water shall comply with the requirements given in Tables 1 to 4.

Thermal, organoleptic and physical parameters:

- Color: Max 5 Hazen units (Permissible limit in absence of alternate source: 15)
- Odor: Agreeable
- pH value: 6.5 to 8.5 (No relaxation)
- Total Dissolved Solids (TDS): Max 500 mg/l (Permissible limit: 2000 mg/l)
- Turbidity: Max 1 NTU (Permissible limit: 5 NTU)
- Total Hardness (as CaCO₃): Max 200 mg/l (Permissible limit: 600 mg/l)
- Chloride (as Cl): Max 250 mg/l (Permissible limit: 1000 mg/l)
- Fluoride (as F): Max 1.0 mg/l (Permissible limit: 1.5 mg/l)

3. MICROBIOLOGICAL REQUIREMENTS

All water intended for drinking shall be free from pathogenic organisms and indicators of fecal pollution (E. coli or