

Rooftop solar report

Friend roof test · 11 Sept 2026 to 10 Oct 2026

Made on 10 Oct 2026

System ID f6dbb17d66

The system

Size	4 kW	Panels face	south, 20° tilt
Location	28.7500, 77.1100	Watched since	10 Oct 2026
Promise	None given (SuryaWatch's estimate is used)		Value of one unit ₹6.5

Summary

Days with readings	Units made	Sunlight allowed, after haze
6 (5 full days)	78.4 kWh	76.7 kWh
Performance after haze	Lost to dust or faults	Lost to smog and haze
102%	2.4 kWh · ₹15	9.1 kWh

A healthy system gives 92% or more of the output the sunlight allows, after haze.

What needs attention

- 1. The inverter showed an error, or output dropped suddenly, on 1 day(s). Please inspect the inverter and the messages listed below.
- 2. Dust cut output on 1 day(s). Cleaning is the owner's job; no visit is needed for this.

Promised vs got

Period	Promised	Got	Share
This month so far (5 Oct to 9 Oct)	80	78	97%
Since tracking began (5 Oct to 9 Oct)	80	78	97%

Units are kWh.

Inverter Total counter

8,136 kWh on 4 Oct, 6:20 PM to 8,213 kWh on 9 Oct, 6:20 PM: 77.6 kWh in between.

Inverter faults and messages

When	The display showed
Wed, 7 Oct, 1:05 PM	Fault E031


Cleanings

8 Oct 2026, 7:30 AM

Cleaning on 8 Oct 2026 changed output from 102% to 105% of possible (+3.3%).

Day by day

Share of possible output each full day, after haze (%)



Date	Made (kWh)	Sunlight allowed (kWh)	Haze	Performance after haze	Result
Sun, 4 Oct	15.6	16.8	18%	112%	Smog day
Mon, 5 Oct	16.6	18.3	1%	92%	Clean panels
Tue, 6 Oct	13.9	16.6	18%	101%	Smog day
Wed, 7 Oct	–	–	–	–	Possible fault
Thu, 8 Oct	15.6	16.4	18%	116%	Smog day
Fri, 9 Oct	16.7	17.8	1%	95%	Working well

How this report was made

- Readings come from photos of the inverter display, read by AI and checked by the owner, or typed in.
- Expected output uses the sun's position over this roof, measured sunlight from Open-Meteo, and the system's size, tilt and direction.
- Haze comes from the air-quality data (aerosol optical depth). Output lost to haze is not counted against the panels.
- Each day is judged on its evening E-Today reading; a part day had no evening reading.
- These are estimates to guide a check-up. A site visit is the final word.

Made with SuryaWatch. Open this report online: <http://localhost:8095/?system=f6dbb17d66&from=2026-09-11&to=2026-10-10#report>