

3520WV/3520WFV Silhouette Handrail

Suggested Specification





STANDARD 3520WV



OPTION

 7-7/8" (200mm) height x 1-½" (38mm) round gripping diameter, extends 3-¼" (82mm) from the wall

- 3520WV Wood handrail available in maple with an integrated vinyl wall guard
- 3520WFV Wood handrail available in maple with an integrated faux-woodgrain pattern vinyl wall guard
- Lower wall guard is mounted on a sturdy .080" (2mm) thick, continuous aluminum retainer
- Meets ADA and ANSI criteria
- Manufactured in 8' 16' (2.44m 4.88m) standard lengths
- All mounting fasteners are included with each order

IPC.2218/REV.2



3520WV/3520WFV Silhouette Handrail

Suggested Specification

PART 1 GENERAL

1.01 SUMMARY

A. Handrail systems for pedestrian safety and wall protection

1.02 SECTIONS INCLUDES

A. 3520WV/3520WFV Silhouette Handrail System, round wood handrail with integrated wall quard.

1.03 REFERENCES

A. American National Standards Institute (ANSI)

B. American Society for Testing and Materials (ASTM)

C. American with Disabilities Act (ADA)

D. National Building Code of Canada (NBC)

E. National Fire Protection Association (NFPA)

F. Society of Automotive Engineers (SAE)

G. Underwriters Laboratory (UL)

H. Underwriters Laboratory of Canada (ULC)

I. Uniform Building Code (ÚBC)

1.04 SYSTEM DESCRIPTION

A. Performance Requirements: Provide wood handrail systems with integrated impact bumpers that conform to the following requirements of regulatory agencies and the quality control of IPC Door and Wall

Protection Systems, InPro Corporation.

- 1. Fire Performance Characteristics: Provide UL Classified impact bumper conforming with NFPA Class A fire rating. Surface burning characteristics, as determined by UL-723 (ASTM E-84), shall be flame spread of 10 and smoke development of 350 450. Provide ULC (Canada) listed impact bumper conforming to the requirements of the National Building Code of Canada 2010, Subsection 3.1.13. Surface burning characteristics, as determined by CAN/ULC-5102.2, shall be flame spread of 15 and smoke developed of 35.
- 2. Self-Extinguishing: Provide impact bumpers with a CC1 classification, as tested in accordance with the procedures specified in ASTM D-635-74, Standard Test Method for Rate of Burning and/or Extent and Time of Burning of Self-Supporting Plastics in a Horizontal Position, as referenced in UBC 52-4-1988.
- 3. Impact Strength: Provide rigid vinyl profile materials that have an impact strength of 30.2 ft-lbs/inch of thickness as tested in accordance with the procedures specified in ASTM D-256-90b, Impact Resistance of Plastics.
- 4. Chemical and Stain Resistance: Provide impact bumpers that show resistance to stain when tested in accordance with applicable provisions of ASTM D-543.
- 5. Fungal and Bacterial Resistance: Provide rigid vinyl that does not support fungal or bacterial growth as tested in accordance with ASTM G-21 and ASTM G-22.
- 6. Color Consistency: Provide thermoplastic components matched in accordance with SAE J-1545 (Delta E) with a color difference no greater than 1.0 units using CIE Lab, CIE CMC, CIE LCh, Hunter Lab or similar color space scale systems.
- 7. Cold, heat and chemical resistance: Provide wood handrail with a finish that complies with the applicable provisions of ANSI/KCMA A161.1-1990 for cold check, heat and chemical resistance.
- 8. Environmental compliance: Provide wood handrail and with a finish that does not off gas or emit any VOC, after a full cure, as tested in accordance to the EPA, NESHAP, Method 24, 40CFR, Volume 60, Appendix A.
- 9. Code Compliance: Provide handrails that comply with all current ANSI and ADA requirements.

1.05 SUBMITTALS

 $\label{eq:A.Product} A. \ Product\ Data: Manufacturer's\ printed\ product\ data\ for\ each\ product\ indicated\ in\ this\ section.$

B. Detail Drawings: Mounting details with appropriate fasteners for specific project substrates.

C. Loaner Samples: Verification samples of handrail, 15"

(381mm) long, in full size profiles with one return and one mounting bracket of each type and color indicated. Return samples to IPC after review.

D. Manufacturer's Installation Instructions: Printed installation instructions for each handrail.

1.06 DELIVERY, STORAGE AND HANDLING

A. Deliver materials in unopened factory packaging to the jobsite.

B. Inspect materials at delivery to assure that specified products have been received.

C. Store in original packaging in a climate controlled environment away from direct sunlight.

1.07 WARRANTY

A. Standard IPC limited lifetime warranty against material and manufacturing defects.

PART 2 PRODUCTS

2.01 MANUFACTURERS

A. Acceptable Manufacturer: IPC Door and Wall Protection Systems.

InPro Corporation

PO Box 406, Muskego, WI 53150 USA

Telephone 800-543-1729, Fax: 888-715-8407

Internet address: www.inprocorp.com

B. Substitutions: Not permitted

C. Provide all handrails and wall protection from a single manufacturer.

2.02 MANUFACTURED UNITS

A. Wood Handrail

- 1. 3520WV Silhouette Handrail, 7- "(200mm) height x 1-½" (38mm) round gripping diameter, system extends 3-¼" (82mm) from the wall. Integrated vinyl cover, 5" (127mm) high. Inner impact bumper, 1- "(48mm) high.
- a. Standard: molded returns, corners, bracket with stainless bracket stem.
- b. Optional cast aluminum one-piece bracket
- c. Optional stainless-steel returns and corner
- 2. 3520WFV Silhouette Handrail, 7- "(200mm) height x 1-½" (38mm) round gripping diameter, system extends 3-¼" (82mm) from the wall. Integrated vinyl cover, 5" (127mm) high. Inner impact bumper, 1- "(48mm) high. Wall guard shall have a full wrap faux-wood pattern.
- a. Standard: molded returns, corners, bracket with stainless bracket stem.
- b. Optional cast aluminum one-piece bracket c. Optional stainless-steel returns and corner

2.03 MATERIALS

A. Wood

1. Shall be FAS grade, kiln dried solid maple with moisture content of 5-9%.

C. Viny

1.Snap-on covers of .080" (2mm) thickness shall be extruded from chemical and stain resistant unplasticized polyvinyl chloride (uPVC) with the addition of impact modifiers. No plasticizers shall be added (plasticizers may aid in bacterial growth). Inner snap-on vinyl impact bumper of .070" (1.8mm) thickness shall be extruded from chemical and stain resistant unplasticized polyvinyl chloride (uPVC) with the addition of impact modifiers. No plasticizers shall be added (plasticizers may aid in bacterial growth). Woodland pattern when used shall be of polyvinyl chloride (PVC).

C. Aluminum

- 1. Continuous aluminum retainer of .080" (2mm) thickness shall be fabricated from 6063-T5 aluminum with a mill finish
- Cast aluminum brackets shall be fabricated of ADC 12 cast aluminum with a metallic gray powder-coated finish.
 Stainless Steel

- 1. Stainless steel brackets shall be type 304 stainless steel with a #4 satin finish.
- 2. Stainless steel returns, corners and brackets shall be made of type 201SS.
- E. Zinc: Bracket adapters shall be cast from zinc.

2.04 COMPONENTS

A. Molded handrail returns, corners and brackets shall be made of injection molded thermoplastic.

B. Handrail, returns, and corners shall be fabricated of wood in a finish/color from Inpro wood finish options. C. Stainless steel bracket shall be fabricated from cast stainless steel with a brushed finish or a solid color powder coat metal tone finish.

D. One-piece cast aluminum bracket to be finished with a gray metallic powder coat.

E. Fasteners: All mounting systems accessories appropriate for substrates indicated on the drawings shall be provided.

2 05 FINISHES

A. Fabricated Wood handrail, returns, and corners shall be finished in color from Inpro wood finish options.

B. Aluminum Brackets: One piece cast bracket to be finished with metallic powder coat.

C. Stainless Steel Brackets

1. Color of the stainless steel bracket to be selected by the architect from the solid color metal tone color palette.

2. Color of stainless steel brackets shall be #4 satin finish stainless steel.

D. Molded Components: Molded handrail returns and corners shall be of a color matching the handrail. Surface shall have a pebblette texture. Molded bracket components shall be a color matching the wall guard. Surface shall have a pebblette texture.

E. Vinyl Covers: Color of the vinyl cover to be selected, by the architect, from the IPC finish selection. Surface shall have a pebblette texture.

PART 3 EXECUTION

3.01 INSTALLERS

A. Installer should be familiar with the installation of fine finished wood products.

3.02 EXAMINATION

A. Examine areas and conditions in which handrail will be installed.

 Complete all finishing operations, including painting, before beginning installation of handrail system materials.
Wall surface shall be dry and free from dirt, grease and loose paint.

3.03 PREPARATION

A. General: Prior to installation, clean substrate to remove dust, debris and loose particles.

3.04 INSTALLATION

A. General: Locate the handrail as indicated on the approved detail drawing for the appropriate substrate and in compliance with the IPC installation instructions. Install handrail level and plumb at the height indicated on the drawings.

3.05 CLEANING

A. At completion of the installation, clean surfaces in accordance with the IPC clean-up and maintenance instructions

