

CLIENT : APTAR PHARMA INDIA.PVT.LTD.
SURVEY NO.120/3/A AND 120/4, 120/7,120/10/B,PALAVA INDUSTRIAL & LOGISTIC PARK USATANE AMBARNATH, TALUKA-THANE MAHARASTRA
TEST CARRIED OUT BY : Mr.NANDKISHOR GANDOLE
TEST WITNESSED BY : Mr.MAHESH AKHADE
TEST CARRIED OUT : RECOVERY TEST
AREA : PRODUCTION
AHU NO. : 04
VALIDATION DATE : 18/06/2025

Instrument Details			
Instrument Used	LASAIR_III Particle Counter	Model	5100
Sr. No.	123592	Make	PMS
Calibration Date	22/05/2025	Calibration Due on	22/05/2026


Room Name & No.	Condition	Time of Reading	Particles Count in Mt ³		Remarks
			0.5μ	5.0μ	
ASSEMBLY AREA GF-10	ON	10:13:27	37492	1861	RECOVERY PERIOD IS 07 MIN.
	OFF	10:19:43	11910872	3465153	
	ON	10:20:43	9037984	1125643	
		10:21:43	5964704	266608	
		10:22:43	4307074	88247	
		10:23:43	2033584	42375	
		10:24:43	944238	18952	
		10:25:43	403534	8131	
		10:26:43	65667	1060	

A] Time at which Particle Counter is Switched "ON" : 10:19 Min
B] Time at which Specified Class Condition is Achieved : 10:26 Min
Recovery Period = [B-A] : 00:07 Min

ACCEPTANCE CRITERIA : RECOVERY PERIOD IS LESS THAN 15 MINUTE

Certified that the test were carried out in accordance with ISO-14644-3:2019 (E)

Test Carried Out By,



**For, Micron HVAC Pvt.Ltd.
Pune**

Test Witnessed By,

**For, Aptar Pharma India Pvt .Ltd
Mumbai**

Micron HVAC Private Limited

Regd. Office : Greens Centre, 0-309 / 310, S No. 26, CTS No. 5401, Thergaon, Pune - 411 033. INDIA

Tel. : +91 20 29529739, Mob. : +91 9552764776, 9552554775

Email : info@micronhvac.com | Web : www.micronhvac.com | CIN No. : U74999PN2016PTC166600

RECOVERY TEST Annexure I

AHU NO./EQUIPMENT ID NO.: AHU NO-4	DATE: 18/06/2025
ROOM NAME: ASSEMBLY AREA	AREA NAME: PRODUCTION
ROOM NO: GF-10	TEST TAKEN: AT REST

Final Sample Report

Instrument ID: Lasair III
Serial Number: 123592
Calibrated: 22/05/2025
Location: RC GF-10
18/06/2025 10:12:27
18/06/2025 10:13:27 #1
Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	24688	37492
1.0	6842	12804
2.0	4101	5962
5.0	840	1861
10.0	760	1020
25.0	260	260

00:01:00

0.099967 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 123592
Calibrated: 22/05/2025
Location: RC GF-10
18/06/2025 10:19:43
18/06/2025 10:20:43 #2
Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	2873056	9037984
1.0	1493829	6164928
2.0	3545456	4671099
5.0	866896	1125643
10.0	232387	258748
25.0	26361	26361

00:01:00

0.099920 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 123592
Calibrated: 22/05/2025
Location: RC GF-10
18/06/2025 10:21:43
18/06/2025 10:22:43 #4
Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	2767494	4307074
1.0	890749	1539579
2.0	560583	648830
5.0	62315	88247
10.0	24182	25932
25.0	1750	1750

00:01:00

0.099992 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 123592
Calibrated: 22/05/2025
Location: RC GF-10
18/06/2025 10:18:43
18/06/2025 10:19:43 #1
Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	1965284	11910872
1.0	478032	9945588
2.0	6002404	9467556
5.0	2499721	3465153
10.0	835686	965432
25.0	129745	129745

0.1000 m³

0.100027 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 123592
Calibrated: 22/05/2025
Location: RC GF-10
18/06/2025 10:20:43
18/06/2025 10:21:43 #3
Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	3176340	5964704
1.0	1246402	2788364
2.0	1275354	1541962
5.0	198893	266608
10.0	61034	67714
25.0	6680	6680

00:01:00

0.099993 m³/m

Final Sample Report


Instrument ID: Lasair III
Serial Number: 123592
Calibrated: 22/05/2025
Location: RC GF-10
18/06/2025 10:22:43
18/06/2025 10:23:43 #5
Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	1316291	2033584
1.0	412988	717293
2.0	261930	304305
5.0	29473	42375
10.0	12031	12901
25.0	870	870

00:01:00

0.099989 m³/m

Performed By



Witnessed By

Checked By

RECOVERY TEST

Annexure I

AHU NO./EQUIPMENT ID NO.: AHU NO-4	DATE: 18/06/2025
ROOM NAME: ASSEMBLY	AREA NAME: PRODUCTION
ROOM NO: GF-10	TEST TAKEN: AT REST

Final Sample Report

Instrument ID: Lasair III
Serial Number: 123592
Calibrated: 22/05/2025
Location: RC GF-10

18/06/2025 10:23:43

18/06/2025 10:24:43

#6

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	613686	944238
1.0	191617	330552
2.0	119983	138935
5.0	13038	18952
10.0	5503	5914
25.0	410	410

00:01:00

0.099939 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 123592
Calibrated: 22/05/2025
Location: RC GF-10

18/06/2025 10:25:43

18/06/2025 10:26:43

#8

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	46719	65667
1.0	11895	18948
2.0	5992	7053
5.0	830	1060
10.0	220	230
25.0	10	10

00:01:00

0.099958 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 123592
Calibrated: 22/05/2025
Location: RC GF-10

18/06/2025 10:24:43

18/06/2025 10:25:43

#7


Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	264099	403534
1.0	81595	139436
2.0	49709	57841
5.0	5621	8131
10.0	2310	2510
25.0	200	200

00:01:00

0.099982 m³/m

Performed By



Witnessed By

Checked By