

TEST CERTIFICATE

CLIENT : PREMIUM SERUMS AND VACCINES PVT.LTD.
S.NO 354-1 ,354-2A/1 AT & POST-NARAYANGAON
TAL.JUNNAR. DIST PUNE- 410504

TEST CARRIED OUT BY : Mr.SHUBHAM NIRGUDE

TEST WITNESSED BY : Mr.AMAN PATHAN

TEST : CFM MEASUREMENT & ACPH

VALIDATION DATE : 20/07/2023

TEST TAKEN : AT REST

AHU NO : AHU B 01

ROOM NAME & NO. : PRODUCTION OFFICE (14)

INSTRUMENT USED		CALIBRATION DATE		CALIBRATION DUE DATE		
AIR CAPTURE HOOD MODEL NO.: 8380 MAKE : TSI ACCUBALANCE SR. NO. : T83801931003		19-02-2023		18-02-2024		
Sr. No.	Room Name & No.	Filter Code	Actual CFM	Total CFM	Room Vol. (Ft ³)	ACPH
1	PRODUCTION OFFICE (14)	AHU-B01-14-SH-07	302	678	1513.20	26.88
		AHU-B01-14-SH-08	376			
ACCEPTANCE CRITERIA : AIR CHANGES SHOULD NOT BE LESS THAN 20 ACPH						
Refrance:-AS PER PROTOCOL No.PSV/PRO/001						
RESULT : Meets / Does Not Meet Validation Acceptance Criteria As Per ISO 14644-3:2019 (E)						

TEST CARRIED OUT BY	TEST WITNESSED BY	TEST REVIEWED BY
Sign & Date	Sign & Date	Sign & Date
For, Micron HVAC Pvt. Ltd.	For,Premium Serums and Vaccines Pvt. Ltd.	