

TEST CERTIFICATE

CLIENT : PREMIUM SERUMS AND VACCINES PVT.LTD.
S.NO 354-1 ,354-2A/1 AT & POST-NARAYANGAON
TAL.JUNNAR. DIST PUNE- 410504

TEST CARRIED OUT BY : Mr.ROSHAN BOLKE

TEST WITNESSED BY : M. GAUTAM NIKODI

TEST : AIRBORNE PARTICLE COUNT

VALIDATION DATE : 16/03/2022

TEST TAKEN : AT REST/IN OPERATION

AHU NO : AHU B 01

ROOM NAME & NO. : WASHING ROOM (51)

Instrument Details			
Instrument Used:	Lasair_III Particle Counter		
Sr. No.	168867	Make	PMS
Flow Rate	100 LPM	Model No.	5100
Sampling Volume	0.10000 m ³ /m	Sampling Time	1 Min
Calibration Date	22/05/2025	Calibration Due on	22-05-2026

Sr. No.	Room Name & No.	Location	No. of Particles in m ³		Remarks
			0.5μ	5.0μ	
1	WASHING ROOM (51)	L1			Passes Class ISO 8 In At Rest Condition
		L2			
		L3			
		L4			
		L5			

Refrance:-AS PER PROTOCOL No.PSV/PRO/001

ACCEPTANCE CRITERIA AS PER ISO-14644-2:2015 (E) / EU

Maximum Permitted number of particles/m³ equal to or less than

No.	CLASS	0.5μ	5.0μ
1	ISO-8	3520000	29300

TEST CARRIED OUT BY	TEST WITNESSED BY	TEST REVIEWED BY
For,Micron HVAC Pvt.Ltd.	For,Premium Serums and Vaccines Pvt. Ltd.	