

TEST CERTIFICATE

CLIENT : PREMIUM SERUMS AND VACCINES PVT.LTD.
S.NO 354-1 ,354-2A/1 AT & POST-NARAYANGAON
TAL.JUNNAR. DIST PUNE- 410504

TEST CARRIED OUT BY : Mr. SHANKAR PATIL

TEST WITNESSED BY : Mr. SHUBHAM BADHE

TEST : HEPA FILTER INTEGRITY TEST

VALIDATION DATE : 16/03/2022

TEST TAKEN : AT REST

AHU NO : AHU B 01

ROOM NAME & NO. : PACKING MATERIAL TESTING (45)

INSTRUMENT USED		CALIBRATION DATE			CALIBRATION DUE DATE		
AEROSOL PHOTOMETER		02/10/2021			01/10/2022		
MODEL NO. :ATI 2i							
SR NO. :37504							
Room Name & No.	Filter No.	Upstream Conc. 20 To 80 µgm/lit (Before)	Leakage (%)	Upstream Conc. 20 To 80 µgm/lit (After)	Upstream Conc. 85% To 115% (After÷Before×100)	PAO Test Result	Remarks
PACKING MATERIAL TESTING (45)	AHU-B01-45-SH-50	12	0.000%	13	108.33	PASS	CLEARs PAO TEST
	AHU-B01-45-SH-51	14	0.001%	13	92.86	PASS	CLEARs PAO TEST
ACCEPTANCE CRITERIA : LEAKAGE NMT 0.01%							
RESULT : Meets / Does Not Meet Validation Acceptance Criteria As Per ISO 14644-3:2019 (E)							
Refrance:-AS PER PROTOCOL No.PSV/PRO/001							
TEST CARRIED OUT BY		TEST WITNESSED BY			TEST REVIEWED BY		
For,Micron HVAC Pvt.Ltd.		For,Premium Serums and Vaccines Pvt. Ltd.					