

RECOVERY TEST

CLIENT : PREMIUM SERUMS AND VACCINES PVT.LTD.
 S.NO 354-1 ,354-2A/1 AT & POST-NARAYANGAON
 TAL.JUNNAR. DIST PUNE- 410504
TEST CARRIED OUT BY : Mr.HARSHVARDHAN PATIL
TEST WITNESSED BY : Mr.GAUTAM NAIKODI
TEST CARRIED OUT : RECOVERY TEST
VALIDATION DATE : 29/10/2025
AHU NO. : AHU F 12

Instrument Details						
Instrument Used	LASAIR_III Particle Counter					
Sr. No.	72573				Make	PMS
Flow Rate	28.3 LPM				Model No.	310C
Sampling Volume	0.0283 m ³ /m				Sampling Time	01 min
Calibration Date	08/10/2025				Calibration Due on	08/10/2026
Room Name & No.	AHU Condition	Time of Reading		No of Particles in m ³		Remarks
		START	END	0.5µm	5.0µm	
STERILITY ROOM (FS 103)	Initial	10:39:33	10:40:33	4343	0	RECOVERY PERIOD IS 03 MIN.
	Generation	10:46:18	10:47:18	515570	16910	
	Recovery Period	10:47:18	10:48:18	377947	3567	
		10:48:18	10:49:18	161210	1166	
		10:49:18	10:50:18	53267	212	
		10:50:18	10:51:18	6111	71	
		10:51:18	10:52:18	2508	0	
A] Time at which Specified Class AHU Condition is ON : 10:47:18 B] Time at which Specified Class Condition is Achieved : 10:50:18 Recovery Period = [B-A] : 0:03:00						
Refrance:-AS PER PROTOCOL No.PSV/PRO/001						
RESULT : Meets / Does Not Meet Validation Acceptance Criteria As Per ISO 14644-3:2019 (E)						
ACCEPTANCE CRITERIA:- NMT 15 Min AS PER ISO-14644-3:2019 (E)						
Maximum Permitted number of particles/mt ³ equal to or less than						
No.	CLASS	0.5µm			5.0µm	
1	ISO 6	35200			293	
TEST CARRIED OUT BY,		TEST WITNESSED BY			TEST REVIEWED BY	
For Micron HVAC Pvt.Ltd.Pune		For,Premium Serums and Vaccines Pvt. Ltd.				