

AIRBORNE PARTICLE COUNT

ROOM NAME : ASSEMBLY AREA

TEST TAKEN : IN OPERATION

ROOM NO : GF-10

DATE : 21/03/2026

Final Sample Report

Instrument ID: Lasair III
Serial Number: 168867
Calibrated: 22/05/2025
Location: GF-10 L1

21/03/2026 14:38:08

21/03/2026 14:39:08 #1

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	73076	112985
1.0	18446	39909
2.0	17408	21462
5.0	3246	4055
10.0	709	809
25.0	100	100

00:01:00 0.100128 m^3/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 168867
Calibrated: 22/05/2025
Location: GF-10 L3

21/03/2026 14:40:59

21/03/2026 14:41:59 #1

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	90901	144188
1.0	21941	53287
2.0	24300	31347
5.0	5418	7047
10.0	1499	1629
25.0	130	130

00:01:00 0.100043 m^3/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 168867
Calibrated: 22/05/2025
Location: GF-10 L5

21/03/2026 14:43:42

21/03/2026 14:44:42 #1

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	85941	144654
1.0	25109	58713
2.0	26628	33605
5.0	5987	6977
10.0	950	990
25.0	40	40

00:01:00 0.100046 m^3/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 168867
Calibrated: 22/05/2025
Location: GF-10 L2

21/03/2026 14:39:29

21/03/2026 14:40:29 #1

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	87467	137788
1.0	22252	50321
2.0	22382	28069
5.0	5028	5688
10.0	660	660
25.0	0	0

00:01:00 0.100038 m^3/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 168867
Calibrated: 22/05/2025
Location: GF-10 L4

21/03/2026 14:42:19

21/03/2026 14:43:19 #1

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	73266	110873
1.0	16949	37608
2.0	16549	20659
5.0	3270	4110
10.0	750	840
25.0	90	90

00:01:00 0.100006 m^3/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 168867
Calibrated: 22/05/2025
Location: GF-10 L6

21/03/2026 14:45:17

21/03/2026 14:46:17 #1

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	85696	144072
1.0	24350	58377
2.0	26699	34026
5.0	6597	7327
10.0	640	730
25.0	90	90

00:01:00 0.100040 m^3/m

TEST CARRIED OUT BY :

TEST WITNESSED BY :

