

ATI Photometer 2i  
Serial#: 37504  
Cal Due: 01 Oct 2022  
Date: 16 Mar 2022

ID: 031188001  
Setup: Aerosol  
Reagent: PAO  
Actual Conc: 12  
Upstream Val:  
Start Time: 15:28:15

Leakage Alarm: 0.0100%  
Alarm Exceeded: No  
Max Pen.: 0.000%

Leakage Alarm: 0.0100%  
Alarm Exceeded: No  
Max Pen.: 0.000%

End Time: 15:31:50  
Scan Time: 3 min 9 sec  
Operator:

ATI Photometer 2i  
Serial#: 37504  
Cal Due: 01 Oct 2022  
Date: 16 Mar 2022

ID: 031188002  
Setup: Aerosol  
Reagent: PAO  
Actual Conc: 12  
Upstream Val:  
Start Time: 15:32:32

Leakage Alarm: 0.0100%  
Alarm Exceeded: No  
Max Pen.: 0.001%

End Time: 15:36:31  
Scan Time: 3 min 59 sec  
Operator:

ATI Photometer 2i  
Serial#: 37504  
Cal Due: 01 Oct 2022  
Date: 16 Mar 2022

ID: 031188003  
Setup: Aerosol  
Reagent: PAO  
Actual Conc: 12  
Upstream Val: -  
Start Time: 15:37:08

Leakage Alarm: 0.0100%  
Alarm Exceeded: No  
Max Pen.: 0.005%

End Time: 15:40:41  
Scan Time: 3 min 33 sec  
Operator:

ATI Photometer 2i  
Serial#: 37504  
Cal Due: 01 Oct 2022  
Date: 16 Mar 2022

ID: 031188004  
Setup: Aerosol  
Reagent: PAO  
Actual Conc: 12  
Upstream Val:  
Start Time: 15:41:15

Leakage Alarm: 0.0100%  
Alarm Exceeded: No  
Max Pen.: 0.000%

End Time: 15:44:57  
Scan Time: 3 min 42 sec  
Operator:

ATI Photometer 2i  
Serial#: 37504  
Cal Due: 01 Oct 2022  
Date: 16 Mar 2022

ID: 031188000  
Setup: Aerosol  
Reagent: PAO  
Actual Conc: 13  
Upstream Val:  
Start Time: 15:47:22