

TriStar MPPT MODBUS® Specification

v10.4
17 February 2017

Morningstar Corporation
8 Pheasant Run
Newtown, PA 18940
www.morningstarcorp.com
info@morningstarcorp.com

General Information

The TriStar MPPT supports the industry standard MODBUS® application protocol via its serial RS-232 and EIA-485 interfaces and MODBUS TCP via the Ethernet port (TS-MPPT-60 models only). This document assumes the user is familiar with both MODBUS® protocols. Please refer to the documents listed in the [References](#) section for more information.

MODBUS® is a registered trademark of Modbus-IDA (www.modbus.org/specs.php)

Parameters

The TriStar MPPT supports RTU mode only.
16bit MODBUS addresses (per the modbus.org spec)

The serial communication parameters:

- BPS 9600 baud
- Parity None
- Data bits 8
- Stop bits 1 or 2*
- Flow control None

*The TriStar accepts either 1 or 2 stop bits. It will send 2 stop bits to provide extra byte padding. The connected PC can be set to receive either 1 or 2 stop bits.

The default TCP communication parameters:

- DHCP enabled
- Port 502
- MODBUS ID 1
- NETBIOS address tsmpt + serial number (no spaces)
- LiveView Web address <http://tsmpptXXXXXXX> (where X is the serial number)

If DHCP fails, the following default parameters will be assigned:

- IP 192.168.1.253
- Gateway 192.168.1.1
- Primary DNS 192.168.1.1
- Secondary DNS 192.168.1.1
- Subnet Mask 255.255.255.0

Note: the TCP socket is closed by the TS-MPPT after each MODBUS response (change pending)

All addresses listed are for the request PDU.

Supported MODBUS Functions

Read Holding Registers (0x03) and Read Input Registers (0x04)

RAM

PDU Addr	Logical Addr	Variable name	Variable description	Units	Signed	Scaling or Range
Scaling Values						
0x0000	1	V_PU hi	Voltage scaling, whole term	V		-
0x0001	2	V_PU lo	Voltage scaling, fractional term	-		-
0x0002	3	I_PU hi	Current scaling, whole term	A		-
0x0003	4	I_PU lo	Current scaling, fractional term	-		-
0x0004	5	ver_sw	Software Version	-		-
0x0005 – 0x0017	6-9	RESERVED				
Filtered ADC						
0x0018	25	adc_vb_f_med	Battery voltage, filtered ($\tau \approx ?s$)	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0x0019	26	adc_vbterm_f	Batt. Terminal voltage, filtered ($\tau \approx ?s$)	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0x001A	27	adc_vbs_f	Battery Sense voltage, filtered ($\tau \approx ?s$)	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0x001B	28	adc_va_f	Array voltage, filtered ($\tau \approx ?s$)	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0x001C	29	adc_ib_f_shadow	Battery current, filtered ($\tau \approx ?s$)	A	√	$n \cdot I_{PU} \cdot 2^{-15}$
0x001D	30	adc_ia_f_shadow	Array current, filtered ($\tau \approx ?s$)	A	√	$n \cdot I_{PU} \cdot 2^{-15}$
0x001E	31	adc_p12_f	12 volt supply, filtered ($\tau \approx ?s$)	V	√	$n \cdot 18.612 \cdot 2^{-15}$
0x001F	32	adc_p3_f	3 volt supply, filtered ($\tau \approx ?s$)	V	√	$6.6 \cdot 2^{-15}$
0x0020	33	adc_pmeter_f	MeterBus voltage, filtered ($\tau \approx ?s$)	V	√	$n \cdot 18.612 \cdot 2^{-15}$
0x0021	34	adc_p18_f	1.8 volt supply, filtered ($\tau \approx ?s$)	V	√	$n \cdot 3 \cdot 2^{-15}$
0x0022	35	adc_v_ref	reference voltage	V	√	$n \cdot 3 \cdot 2^{-15}$
Temperatures						
0x0023	36	T_hs	Heatsink temperature	C	√	-127 to +127
0x0024	37	T_rts	RTS temperature (0x80 = disconnect)	C	√	-127 to +127
0x0025	38	T_batt	Battery regulation temperature	C	√	-127 to +127
Status						
0x0026	39	adc_vb_f_1m	Battery voltage, filtered ($\tau \approx 1min$)	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0x0027	40	adc_ib_f_1m	Charging current, filtered ($\tau \approx 1min$)	A	√	$n \cdot I_{PU} \cdot 2^{-15}$
0x0028	41	vb_min	Minimum battery voltage	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0x0029	42	vb_max	Maximum battery voltage	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0x002A	43	hourmeter_HI	hourmeter, HI word	h		-
0x002B	44	hourmeter_LO	hourmeter, LO word	h		-
0x002C	45	fault.all	Controller faults bitfield	-		-
0x002D	46	reserved				
0x002E	47	alarm_HI	alarm bitfield – HI word	-		-
0x002F	48	alarm_LO	alarm bitfield – LO word	-		-
0x0030	49	dip.all	DIP switch positions bitfield	-		-
0x0031	50	led.state	State of LED indications	-		-
Charger						
0x0032	51	charge_state	Charging stage	-		-
0x0033	52	vb_ref	Target regulation voltage	V	√	$n \cdot V_{PU} \cdot 2^{-15}$

0x0034	53	Ahc_r HI	Ah charge – resetable	Ah		n·0.1
0x0035	54	Ahc_r LO		-		
0x0036	55	Ahc_t HI	Ah charge – total	Ah		n·0.1
0x0037	56	Ahc_t LO		-		
0x0038	57	kwhc_r	kWhr charge resetable	-		
0x0039	58	kwhc_t	kWhr charge total	-		
MPPT						
0x003A	59	power_out_shadow	Output Power	W		$n \cdot V_{PU} \cdot I_{PU} \cdot 2^{-17}$
0x003B	60	power_in_shadow	Input Power	W		$n \cdot V_{PU} \cdot I_{PU} \cdot 2^{-17}$
0x003C	61	sweep_Pin_max	Max. Power of last sweep	W		$n \cdot V_{PU} \cdot I_{PU} \cdot 2^{-17}$
0x003D	62	sweep_vmp	Vmp of last sweep	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0x003E	63	sweep_voc	Voc of last sweep	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0x003F	64	RESERVED				
Logger – Today’s values						
0x0040	65	vb_min_daily	Min. daily battery voltage	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0x0041	66	vb_max_daily	Max. daily battery voltage	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0x0042	67	va_max_daily	Max. daily input voltage	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0x0043	68	Ahc_daily	Total Ah charge daily	Ah		n·0.1
0x0044	69	whc_daily	Total Wh charge daily	Wh		
0x0045	70	flags_daily	Daily flags bitfield	-		
0x0046	71	Pout_max_daily	Max. Power Out, daily	W		$n \cdot V_{PU} \cdot I_{PU} \cdot 2^{-17}$
0x0047	72	Tb_min_daily	Min. battery temp. daily	C	√	-127 to +127
0x0048	73	Tb_max_daily	Max. battery temp. daily	C	√	-127 to +127
0x0049	74	fault_daily	Faults, daily	-		
0x004A	75	RESERVED				
0x004B	76	alarm_daily HI	Daily alarms bitfield	-		
0x004C	77	alarm_daily LO		-		
0x004D	78	time_ab_daily	cumulative time in absorption, daily	s		
0x004E	79	time_eq_daily	cumulative time in equalize, daily	s		
0x004F	80	time_fl_daily	cumulative time in float, daily	s		
0x0050 – 0x0058	81 - 89	RESERVED				
Manual Control						
0x0059	90	vb_ref_slave	battery voltage regulation override	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0x005A	91	va_ref_fixed	Array V fixed voltage target	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0x005B	92	va_ref_fixed_pct	Array V % of Voc voltage target	%		$n \cdot 100 \cdot 2^{-16}$
Active TCP Network Settings						
0x1000		ProcessorB_Version	Processor B Firmware version	-		
0x1001 – 0x100E		RESERVED				
0x100F		IPAddrByte [1][0]	IP Address Bytes	-		
0x1010		IPAddrByte [3][2]	IP Address Bytes	-		
0x1011		SubNetMask [1][0]	Subnet Mask Bytes	-		
0x1012		SubNetMask [3][2]	Subnet Mask Bytes	-		
0x1013		Gateway [1][0]	Gateway Bytes	-		
0x1014		Gateway [3][2]	Gateway Bytes	-		
0x1015		PrimaryDNS [1][0]	PrimaryDNS Bytes	-		
0x1016		PrimaryDNS [3][2]	PrimaryDNS Bytes	-		
0x1017		SecondaryDNS [1][0]	SecondaryDNS Bytes	-		
0x1018		SecondaryDNS [3][2]	SecondaryDNS Bytes	-		
0x1019-0x101C		RESERVED				
0x101D–		ControllerID	String of 16 bytes, 00 terminates	-		ASCII

0x1024			string			
0x1025		NetFlags	0x4000=DHCP Enabled, 0x0=DHCP disabled	-		
0x1026		MACAddress[1],[0]	MAC Address Bytes	-		
0x1027		MACAddress[3],[2]	MAC Address Bytes	-		
0x1028		MACAddress[5],[4]	MAC Address Bytes	-		
0x1029– 0x1030		NetBIOS Name	String of 16 bytes, 00 terminates string	-		ASCII

EEPROM

PDU Addr	Logical Addr	Variable name	Variable description	Units	Signed	Scaling or Range
TCP Network Settings						
0x151B	5404	HTTPPort	HTTP Port Number	-		1 to 65535
0x151C	5405	MBIPPort	MODBUS IP Port Number	-		1 to 65535
0x151D	5406	NetRules	BIT0: IP Bridging Enabled	-		0 or 1
0x151E	5407	SNMPTrapRecPort	SNMP Trap Destination NMS Port	-		1 to 65535
0x151F	5408	Ethernet Power Save Mode	Bit0: Power Save On=1	-		
0x1520	5409	BETA 8.21 VLAN Enable	Bit0: Vlan Tagging regognition/sending = 1			
0x1521	5410	BETA 8.21 VLAN Parameters	Bit 0-11 VID 0-4094, 4095 reserved, Bit 12 CFI (usually 0) Bits 15-13 PCP Priority 0-7			
0x1522 – 0x1528	...	RESERVED				
0x152B – 0x1534	...	RESERVED				
Charge settings						
0xE000	57345	EV_absorp	Absorption voltage @ 25°C	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0xE001	57346	EV_float	Float voltage @ 25°C Set to zero to disable float	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0xE002	57347	Et_absorp	absorption time	s		0-(2 ¹⁶ -1)
0xE003	57348	Et_absorp_ext	absorption extension time	s		0-(2 ¹⁶ -1)
0xE004	57349	EV_absorp_ext	absorp. Extension threshold voltage	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0xE005	57350	EV_float_cancel	Voltage that cancels float	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0xE006	57351	Et_float_exit_cum	Exit float timer	s		0-(2 ¹⁶ -1)
0xE007	57352	EV_eq	Equalize V @ 25°C Set 0 to disable	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0xE008	57353	Et_eqcalendar	days between eq cycles	days		0-255
0xE009	57354	Et_eq_above	equalize time limit above Vreg	s		0-(2 ¹⁶ -1)
0xE00A	57355	Et_eq_reg	equalize time limit at Veq	s		0-(2 ¹⁶ -1)
0xE00B	57356	Et_batt_service	battery service timer	days		
0xE00C	57357		not used	-		
0xE00D	57558	EV_tempcomp	temp. compensation coefficient Note:2^-16 scaling, negative assumed	V		$n \cdot V_{PU} \cdot 2^{-16}$
0xE00E	57359	EV_hvd	Battery High Voltage Disconnect	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0xE00F	57360	EV_hvr	Battery High Voltage Reconnect	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0xE010	57361	Evb_ref_lim	battery charge reference limit	V	√	$n \cdot V_{PU} \cdot 2^{-15}$

0xE011	57362	ETb_max	max. temp comp limit	C	√	
0xE012	57363	ETb_min	min. temp comp limit	C	√	
0xE013	57364		not used			
0xE014	57365		not used			
0xE015	57366	EV_soc_g_gy	LED threshold: green to green/yellow	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0xE016	57367	EV_soc_gy_y	LED threshold: green/yellow to yellow	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0xE017	57368	EV_soc_y_yr	LED threshold: yel to yel/red	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0xE018	57369	EV_soc_yr_r	LED threshold: yellow/red to red	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0xE019	57370	Emodbus_id	MODBUS slave address	-		1-247
0xE01A	57371	Emeterbus_id	MeterBus address	-		1-15
RESERVED						
RESERVED						
0xE01D	57374	Elb_lim	Battery Current Limit	A	√	$n \cdot I_{PU} \cdot 2^{-15}$
RESERVED						
RESERVED						
0xE020	57377	EVa_ref_fixed_init	Array V fixed target voltage	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0xE021	57378	EVa_ref_fixed_pct_init	Array V fixed target V (% of Voc)	%		$n \cdot 100 \cdot 2^{-16}$
Read only section						
0xE080	57473	Ehourmeter_LO	hourmeter	h		0 to $(2^{24}-1)$
0xE081	57474	Ehourmeter_HI				
0xE082	57475	EAhc_r_LO	Ah charge resetable	Ah		$n \cdot 0.1$
0xE083	57476	EAhc_r_HI		-		
0xE084	57477	EAhc_t_LO	Ah charge total	Ah		$n \cdot 0.1$
0xE085	57478	EAhc_t_HI		-		
0xE086	57479	EkWhc_r	kWh charge resetable	kWh		
0xE087	57480	EkWhc_t	kWh charge total	kWh		
0xE088	57481	EVb_min	Vb minimum	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0xE089	57482	EVb_max	Vb maximum	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0xE08A	57483	EVa_max	Va maximum	V	√	$n \cdot V_{PU} \cdot 2^{-15}$
0xE08B	57484	Etmr_eqcalendar	days since last equalize	days		
0xE08C	57485	Etmr_batt_service	battery service timer	days		
RESERVED						
0xE0C0– 0xE0C3	57537 – 57540	Eserial	Serial Number	-		
0xE0CC	57548	Emodel	Model: 0 = 45A, 1=60A version	-		0 or 1
0xE0CD	57549	Ehw_version	Hardware version, vMajor.Minor	-		none

Read Coils (0x01), Read Discrete Inputs (0x02), Write Single Coil (0x05)

PDU Addr	Logical Addr	Variable description
0x0000	1	Equalize triggered
0x0001	2	reserved
0x0002	3	Charge disconnect (1 will force charger into a disconnect state)
...	4-16	reserved
0x0010	17	Clear Ah 7esettable (set only, will always read 0)
0x0011	18	Clear Ah total (set only, will always read 0)
0x0012	19	Clear kWh 7esettable (set only, will always read 0)
0x0013	20	Reset battery service calendar
0x0014	21	Clear faults
0x0015	22	Clear Alarms
0x0016	23	Force EEPROM update (set only, will always read 0)
0x0017	24	reserved
0x0018	25	Clear kWh total (set only, will always read 0)
0x0019	26	Clear Vb_min and Vb_max (set only, will always read 0)
...	27-240	reserved
0x00F0	241	test a single phase (test mode only)
...	242-255	reserved
0x00FF	256	Reset control (respond and then reset?)
0x1000	4096	Send Test Notification 1
0x1001	4097	Send Test Notification 2
0x1002	4098	Send Test Notification 3
0x1003	4099	Send Test Notification 4
0x10FF	4351	Reset Communications Server

Write Single Register (0x06)

Any write to EEPROM will set an “EEPROM changed” fault. The control must be reset to clear this fault.

Note: No verify is performed on the write.

See EEPROM table in Read Input Registers(0x04).

Read Device Identification (0x2B, subcode 0x0E)

Only supports “basic device identification (stream access)” (ID code 0x01)

Object Id	Object Name/Description	Typical Value
0x00	VendorName	“Morningstar Corp.”
0x01	Product Code	“TS-MPPT-45” or “TS-MPPT-60”
0x02	MajorMinorRevision (hardware major.minor. software revision)	“v01.01.01”

Variables and Definitions

Variable_name

[Logical Address][PDU Address] (Units). *Short description.*
Definition.

Read Holding and Read Input Registers

Located in processor RAM, updated continuously.

V_PU hi, V_PU lo

[1,2][0x0000, 0x0001] (V). *voltage scaling.*

The scaling value for all voltages. The scaling value is defined as:

$$V_{\text{scaling}} = \text{whole.fraction} = [\text{V_PU hi}].[\text{V_PU lo}]$$

Example:

$$\text{V_PU hi} = 0x004E = 78$$

$$\text{V_PU lo} = 0x03A6 = 934$$

V_PU lo must be shifted by 16 (divided by 2^{16}) and then added to V_PU hi

$$V_{\text{scaling}} = 78 + 934/(2^{16}) = 78.01425$$

I_PU hi, I_PU lo

[3,4][0x0002, 0x0003] (V). *current scaling.*

The scaling value for all currents. The scaling value is defined as:

$$I_{\text{scaling}} = \text{whole.fraction} = [\text{I_PU hi}].[\text{I_PU lo}]$$

See the V_PU scaling example above

ver_sw

[5][0x0004] (). *Software version.*

Firmware version for the controller. This is not the version number for the network software, which can be found in the web page views. The value is stored in binary coded decimal (BCD) format. Decimal version 12 is thus stored as 0x0012 not as 0x000c.

Filtered ADC

Vb

[25][0x0018] (V). *battery voltage, filtered.*

Battery voltage used for regulation by the TS-MPPT. This voltage will be the same as the Battery Sense voltage if the sense connections are connected and valid. Otherwise, this value is the same as Vb_term voltage.

Vb_term

[26][0x0019] (V). *battery terminal voltage, filtered.*

Voltage measured directly at the battery power connections on the TriStar MPPT.

Vb_sense

[27][0x001A] (V). *battery sense voltage, filtered.*

Voltage measured by the Battery Sense connections on the TriStar MPPT.

Va

[28][0x001B] (V). *solar input voltage, filtered.*

Va is the terminal voltage of the solar input connection.

Ib

[29][0x001C] (A). *battery charge current, filtered.*

Charging current to the battery as measured by on-board shunts.

Ia

[30][0x001D] (A). *solar input current, filtered.*

Input current from the solar array.

NOTE: Input current is not measured by precision shunts and may differ from the actual input current by +/- 20%.

Vp12

[31][0x001E] (V). *12 volt supply.*

12 Volt power supply voltage.

Vp3

[32][0x001F] (V). *3 volt supply.*

3 Volt power supply voltage.

Vmeter

[33][0x0020] (V). *MeterBus supply voltage.*
MeterBus power supply voltage.

Vp1.8

[34][0x0021] (V). *1.8 volt supply.*
1.8 Volt power supply voltage.

V_ref

[35][0x0022] (V). *reference voltage.*
External voltage reference

Temperatures**T_hs**

[36][0x0023] (C). *Heatsink Temperature.*
Sunsaver MPPT Heatsink temperature. Reported in degrees C.

T_rts

[37][0x0024] (C). *RTS Temperature.*
Temperature as measured by the optional Remote Temperature Sensor(RTS). Reported in degrees C.

T_batt

[38][0x0025] (C). *Battery Temperature.*
Battery temperature as measured by the ambient temperature sensor or the optional RTS (if connected).
Reported in degrees C.

Status**Vb_slow**

[39][0x0026] (V). *battery voltage, slow filtered ($\tau \approx 1\text{min}$).*
Heavily filtered battery voltage reading. Ideal for use in threshold alarms.

Ib_slow

[40][0x0027] (A). *battery charge current, slow filtered ($\tau \approx 1\text{min}$).*

Heavily filtered charging current value.

Vb_min

[41][0x0028] (V). *minimum battery voltage.*

Long term minimum battery voltage. Resets when Ah(resettable) is reset.

Vb_max

[42][0x0029] (V). *maximum battery voltage .*

Long term maximum battery voltage. Resets when Ah(resettable) is reset.

hourmeter_HI / hourmeter_LO

[43, 44][0x002A, 0x002B] (hrs). *hour meter counter.*

Reports total hours of operation.

Faults

[45][0x002C] (bit-field). *TS-MPPT self-diagnostic faults.*

Reports faults identified by self diagnostics. Each bit corresponds to a specific fault.

Faults Table	
Bit	Fault
0	overcurrent
1	FETs shorted
2	software bug
3	battery HVD
4	array HVD
5	settings switch changed
6	custom settings edit
7	RTS shorted
8	RTS disconnected
9	EEPROM retry limit
10	Reserved
11	Slave Control Timeout
12	Fault 13
13	Fault 14
14	Fault 15
15	Fault 16

Example:

Bit 0 is the LSB

Faults = 0x0013 indicates the following faults have been detected:

[bit 0] overcurrent

[bit 1] MOSFETs shorted

[bit 4] array HVD

alarm_HI / alarm_LO

[47, 48][0x002E, 0x002F] (bitfield). *Controller self-diagnostics alarms.*

Reports alarms identified by self diagnostics. Each bit corresponds to a specific alarm.

Alarms Table	
Bit	Alarm
0	RTS open
1	RTS shorted
2	RTS disconnected
3	Heatsink temp sensor open
4	Heatsink temp sensor shorted
5	High temperature current limit
6	Current limit
7	Current offset
8	Battery sense out of range
9	Battery sense disconnected
10	Uncalibrated
11	RTS miswire
12	High voltage disconnect
13	Undefined
14	system miswire
15	MOSFET open
16	P12 voltage off
17	High input voltage current limit
18	ADC input max
19	Controller was reset
20	Alarm 21
21	Alarm 22
22	Alarm 23
23	Alarm 24

dip_switch

[49][0x0030] (bit-field). *settings switch positions.*

Each bit in the bit-field corresponds to an individual DIP switch setting. Useful for remote applications where access to the TriStar MPPT to verify DIP positions is not feasible. Bit 0 (LSB) corresponds to settings switch 1.

LED_state

[50][0x0031] ().

Reports the LED state.

Value	LED State
0	LED_START
1	LED_START2
2	LED_BRANCH
3	FAST GREEN BLINK
4	SLOW GREEN BLINK
5	GREEN BLINK, 1HZ
6	GREEN_LED
7	UNDEFINED
8	YELLOW_LED
9	UNDEFINED
10	BLINK_RED_LED
11	RED_LED
12	R-Y-G ERROR
13	R/Y-G ERROR
14	R/G-Y ERROR
15	R-Y ERROR (HTD)
16	R-G ERROR (HVD)
17	R/Y-G/Y ERROR
18	G/Y/R ERROR
19	G/Y/R x 2

Charger

Charge_state

[51][0x0032] (). *Charge state.*
Reports the charge state.

Value	Charge State
0	START
1	NIGHT_CHECK
2	DISCONNECT
3	NIGHT
4	FAULT
5	MPPT
6	ABSORPTION
7	FLOAT
8	EQUALIZE
9	SLAVE

V_target

[52][0x0033] (V). *Target Voltage.*

Voltage to which the battery will be charged at any given time. This value changes with each charge stage and is temperature compensated.

Ahc_r_HI / Ahc_r_LO

[53,54][0x0034, 0x0035] (ah). *Charge amp-hours (reset-able counter).*

Reports total solar amp-hours since last ah reset.

Ahc_t_HI / Ahc_t_LO

[55,56][0x0036, 0x0037] (ah). *Charge amp-hours (Total cumulative counter).*

Reports total solar amp-hours since last ah reset.

kWhc_r

[57][0x0038] (kWh). *Charge kilowatt-hours (reset-able counter).*

Reports total solar kilowatt-hours since last ah/kWh reset.

kWhc_t

[58][0x0039] (kWh). *Charge kilowatt-hours (total counter).*

Reports total solar kilowatt-hours.

MPPT**Power_out**

[59][0x003A] (W). *Charge output power.*

Output power to the battery.

Power_in

[60][0x003B] (W). *Array input power.*

Input power from the solar array. Input current is not measured by precision shunts, therefore the reported input power may have significant error.

Sweep_Pmax

[61][0x003C] (W). *Maximum array power.*

Maximum power output of the solar array found during last sweep.

Sweep_Vmp

[62][0x003D] (V). *Solar array Vmp.*

Maximum power voltage of the solar array found during last sweep.

Sweep_Voc

[63][0x003E] (V). *Solar array Voc.*

Open circuit voltage of the solar array found during last sweep.

Logger**Vb_min_daily**

[65][0x0040] (V). *Today's minimum battery voltage.*

Minimum battery voltage measured today. This value is stored in the daily record at the end of each charging day. A new daily record is created X hours after NIGHT state.

Vb_max_daily

[66][0x0041] (V). *Today's maximum battery voltage.*

Maximum battery voltage measured today. This value is stored in the daily record at the end of each charging day. A new daily record is created X hours after NIGHT state.

Va_max_daily

[67][0x0042] (V). *Today's maximum array voltage.*

Maximum battery voltage measured today. This value is stored in the daily record at the end of each charging day. A new daily record is created X hours after NIGHT state.

Ahc_daily

[68][0x0043] (Ah). *Today's total charge amp-hours.*

Total charging amp-hours accumulated today. This value is stored in the daily record at the end of each charging day. A new daily record is created X hours after NIGHT state.

whc_daily

[69][0x0044] (wh). *Today's total charge watt--hours.*

Total watt-hours accumulated today. This value is stored in the daily record at the end of each charging day. A new daily record is created at dawn the next day. Reports increments of 10 Whrs.

flags_daily

[70][0x0045] (bit-field). *Today's event flags (sticky).*

Reports daily flags, as defined below, that occurred today.

Bit	Flag
0 (LSB)	Reset detected
1	Equalize triggered
2	Entered float
3	an alarm occurred
4	a fault occurred

Pout_max_daily

[71][0x0046] (bit-field). *Maximum power out today.*

Reports maximum power delivered to the battery today.

Tb_min_daily

[72][0x0047] (bit-field). *Today's minimum battery temperature.*

Reports the lowest battery temperature that occurred today.

Tb_max_daily

[73][0x0048] (bit-field). *Today's maximum battery temperature.*

Reports the highest battery temperature that occurred today.

fault_daily

[74][0x0049] (bit-field). *Today's self-diagnostic faults (sticky).*

Reports faults identified by self diagnostics that occurred today. Each bit corresponds to a specific fault. If a bit is set, that fault occurred at least once today. Bit order is identical to the **fault** bitfield.

alarm_HI_Daily / alarm_LO_Daily

[76,77][0x004B, 0x004C] (bitfield). *Today's controller self-diagnostics alarms (sticky).*

Reports alarms identified by self diagnostics that occurred today. Each bit corresponds to a specific alarm. If a bit is set, that alarm occurred at least once today. Bit order is identical to the **alarm_hi/alarm_lo** bitfield.

time_ab_daily

[78][0x004D] (s). *Cumulative time in Absorption today.*

Reports the cumulative number of seconds the battery has been in the Absorption charge stage today. Counter resets at night.

time_eq_daily

[79][0x004E] (s). *Cumulative time in Equalization today.*

Reports the cumulative number of seconds the battery has been in the Equalization charge stage today. Counter resets at night.

time_fl_daily

[80][0x004F] (s). *Cumulative time in Float today.*

Reports the cumulative number of seconds the battery has been in the Float charge stage today. Counter resets at night.

Vb_ref_slave

[90][0x0059] (V). *Battery regulation override*

Write a voltage value to this register to override the battery regulation. This allows for system control of 1 or more controllers via Modbus. Writing a non-zero value to this register forces the controller into “slave” state. The register value must be updated every 60 seconds or less, else the controller will fault. Writing to the register after a timeout will exit fault state and resume operation.

Va_ref_fixed

[91][0x005A] (V). *Array Voltage fixed target*

Write a voltage value to this register to fix the Array input voltage to a specific value. If this register is a non-zero value, the MPPT function of the controller will stop (sweeping and tracking are disabled) and the array input will be fixed to the specified voltage. This value can be written at anytime during operation to adjust the array voltage target value. On start-up, this value is initialized with the non-volatile EEPROM value in register 0xE020.

Supported in processor A - V09 firmware and later.

Va_ref_fixed_pct

[92][0x005B] (%). *Array Voltage percent of Voc voltage target*

Write a value to this register to fix the Array input voltage to a percent of the Array open circuit voltage. If this register is a non-zero value, the MPPT function of the controller will stop (sweeping and tracking are disabled) and the array target voltage will be fixed to the specified % of array Voc. The controller will perform periodic Voc checks and move the array voltage if needed to maintain the correct % target. If this register value is changed, the array voltage will not adjust until the next Voc check.

On start-up, this value is initialized with the non-volatile EEPROM value in register 0xE021.

Supported in processor A - V09 firmware and later.

Note: if the Va_ref_fixed (0x005A) register is non-zero, it will override this setting.

EEPROM

TCP Network Settings

HTTPPort

[5404][0x151B](). *HTTP port number*

Port number assigned to the web server. Port 80 default.

MBIPPort

[5405][0x151C](). *MODBUS IP port number*

Port number used for MODBUS IP requests to the controller. Port 502 default.

NetRules

[5406][0x151D](). *Enable / Disable IP bridging to EIA-485*

Set the register bit 0 = 1 to enable bridging of MODBUS requests via Ethernet to the EIA-485 port. If this bit is set, any MODBUS requests received through Ethernet that are not addressed to the controller will be sent out to the EIA-485 port for other devices to receive/respond. All other bits reserved for future use.

Note: all requests, read and write, will be bridged to the EIA-485 network!

SNMPTrapRecPort

[5407][0x151E](). *Trap receive port*

Port number on which to broadcast a SNMP message. Port 162 default.

Ethernet Power Save Mode

[5408][0x151F](). *“Green Ethernet” feature on/off*

Set bit 0 = 1 to turn on the Green Ethernet feature. When on, the Ethernet port will power down unless an Ethernet connection is detected. The controller will check periodically for an established connection. Conserves power in systems with no Ethernet connection. Off by default.

Charge Settings

EV_absorp

[57345][0xE000](V). *Absorption voltage @ 25°C.*

The battery will charge at 100% charge current until battery voltage reaches this setpoint. The controller will begin to taper input current so that this setpoint is maintained, but not exceeded.

EV_float

[57346][0xE001](V). *Float voltage @ 25°C*

After Et_float seconds in absorption, when the battery is fully charged, the battery will transition to this lower voltage charge setting to reduce gassing.

Set to zero to disable float stage

Et_absorp

[57347][0xE002](seconds) *time before entering float*

Defines the length of time in Absorption charge stage before transitioning to Float stage.

Et_absorp_ext

[57348][0xE003](seconds) *time before entering float due to low battery*

If the battery voltage discharges too low during the previous night, this value allows the user to specify a longer period of time before entering float stage.

EV_absorp_ext

[57349][0xE004](V). *Voltage that triggers absorption extension time*

Battery voltage that will trigger a longer period of time (Et_absorp_ext) before entering float.

EV_float_cancel

[57350][0xE005](V). *Battery voltage threshold to cancel float*

A battery voltage threshold that will cancel float on the next charge cycle. If the battery discharged too low the previous night, the user may want to cancel float for the next day.

Et_float_exit_cum

[57351][0xE006](V). *Exit float timer*

Specify (cumulative) amount of time below float voltage before exiting the float stage. Battery voltage may drop below the target float voltage due to insufficient charge current or a system load draws more current from the battery than the array can provide.

EV_eq

[57352][0xE007](V). *Equalize voltage @ 25°C*

Battery equalize voltage. Periodic equalization equalizes cell voltages, bubbles the electrolyte, and helps prevent sulfation of the battery.

Set to zero to disable equalization

Et_eqcalendar

[57353][0xE008](days). *days between eq cycles*

Specify the number of days between equalizations. Equalizing on a calendar basis ensures proper maintenance of batteries.

Et_eq_above

[57354][0xE009](seconds) *equalize time limit above Vreg.*

Equalization will timeout after the specified number of seconds above PWM regulation voltage. If the battery is charged above absorption voltage but has not yet reached the equalization setting, this value serves as a safety timeout to prevent partial equalizations for extended periods of time.

Et_eq_reg

[57355][0xE00A](seconds) *equalize time limit at Veq*

Equalization will stop after the specified number of seconds at the equalization setpoint voltage.

Et_batt_service

[57356][0xE00B](days) *battery service reminder*

Specifies the number of days between battery service reminders. Sets an alarm, prompting the user to check batteries for water, health, etc. Clear the alarm with the pushbutton, meter, or MODBUS alarm reset command.

EV_tempcomp

[57358][0xE00D](V/C). *temperature compensation.*

Battery chemistry changes with temperature. Temperature compensation coefficient specifies the amount that regulation voltage will be shifted with temperature. 25°C reference, the negative is implied (write a positive value). 12V lead-acid battery temperature compensation is approximately 0.03 V/C

EV_hvd

[57359][0xE00E] *High Voltage Disconnect @ 25°C*

Flag a fault/alarm if the battery voltage exceeds this setpoint. Also attempts to open the MOSFETs to stop charging. Set to zero to disable HVD

EV_hvr

[57360][0xE00F](V) *High Voltage Reconnect*

The HVD fault/alarm will be cleared once the battery voltage drops below this setpoint.

Evb_ref_lim

[57361][0xE010](V) *Maximum regulation limit*

An absolute limit on the battery regulation voltage. This is not a temperature compensated value. Protects high voltage sensitive system loads. Set to zero to disable.

ETb_max

[57362][0xE011](C) *Maximum temperature compensation limit*

Maximum temperature to clamp temperature compensation.

ETb_min

[57363][0xE012](C) *Minimum temperature compensation limit*

Maximum temperature to clamp temperature compensation.

EV_soc_g_gy

[57366][0xE015](V). *green to green/yellow limit*

LED transition setpoint. Specifies the battery voltage at which the LED state will change from Green to Green/Yellow.

EV_soc_gy_y

[57367][0xE016](V). *LED Green/Yellow to Yellow limit*

LED transition setpoint. Specifies the battery threshold voltage at which the LEDs will change from green/yellow to yellow indication.

EV_soc_y_yr

[57368][0xE017](V). *LED Yellow to Yellow/Red limit*

LED transition setpoint. Specifies the battery threshold voltage at which the LEDs will change from Yellow to Yellow/Red indication.

EV_soc_yr_r

[57369][0xE018](V). *LED Yellow/Red to Red limit*

LED transition setpoint. Specifies the battery threshold voltage at which the LEDs will change from Yellow/Red to Red indication.

Emodbus_id

[57370][0xE019](). *MODBUS ID*

MODBUS address which uniquely identifies the controller on the MODBUS network.

Emeter_id

[57371][0xE01A](*).* *MeterBus ID*

Address which uniquely identifies the controller on the Morningstar proprietary Meter Bus network. Devices are daisy-chained on the Meter Bus network via the RJ-11 connections. Addresses are limited to the range of 1-15

EIb_lim

[57374][0xE01D](*A*). *Battery Current Limit*

Set to a non-zero value to limit the maximum battery current. Set to zero to use the default 60 Amp current limit.

EVa_ref_fixed_init

[57377][0xE020](*V*). *Array Voltage fixed target - initialize*

Write a voltage value to this register to fix the Array input voltage to a specific value. If this register is a non-zero value, the MPPT function of the controller will be disabled (sweeping and tracking are disabled) and the array input will be fixed to the specified voltage. On start-up, the value in this register is copied to the volatile RAM register 0x005A, which allows for real-time control of Va.

EVa_ref_fixed_pct_init

[57378][0xE021](*%*). *Array Voltage percent of Voc voltage target - initialize*

Write a value to this register to fix the Array input voltage to a percent of the Array open circuit voltage. If this register is a non-zero value, the MPPT function of the controller will be disabled (sweeping and tracking are disabled) and the array target voltage will be fixed to the specified % of array Voc. The controller will perform periodic Voc checks and move the array voltage if needed to maintain the correct % target. On start-up, the value in this register is copied to the volatile RAM register 0x005B, which allows for real-time control of Va.

Note: if the Va_ref_fixed_init (0xE021) register is non-zero, it will override this setting.

Read-Only Variables

Ehourmeter_LO / Ehourmeter_HI

[57473,57474][0xE080,0xE081](hours). *Hourmeter*

Cumulative hours the controller has been running. Non-volatile, written every 24hrs.

EAhc_r_LO / EAhc_r_HI

[57475,57476][0xE082,0xE083](amp-hours). Charge *resetable Ah*

Cumulative amp-hours typically used for short-term logging. Resettable.

EAhc_t_LO / EAhc_t_HI

[57477,57478][0xE084,0xE085](amp-hours). Charge *total Ah*

Cumulative amp-hours for long term logging. Can be reset if needed.

EkWhc_r

[57479][0xE086](kWh). Charge *Kilowatt hours resettable*

Cumulative charging kilowatt hours. Resettable counter.

EkWhc_t

[57480][0xE087](kWh). Charge *Kilowatt hours total*

Cumulative charging kilowatt hours. Total counter.

EVb_min

[57481][0xE088](V). *Minimum battery voltage*

Minimum battery voltage over last 24 hours. Written once every 24hrs.

EVb_max

[57482][0xE089](V). *Maximum battery voltage*

Maximum battery voltage over last 24 hours. Written once every 24hrs.

EVa_max

[57483][0xE08A](V). *Maximum array voltage*

Maximum array voltage over last 24 hours. Written once every 24hrs.

Etmr_eqcalendar

[57484][0xE08B](V). *Equalize calendar timer*

Number of days since last equalize.

Etmr_batt_service

[57485][0xE08C](days). *days since last battery service*

Reports the number of days since the last battery service reminder.

Eserial

[57537-57540][0xE0C0 – 0xE0C3](ASCII). *Controller serial number*

ASCII string of characters that represents the serial number.

Example serial number: 01234567

0xE0C0 = 0x3130 [1][0]

0xE0C1 = 0x3332 [3][2]

0xE0C2 = 0x3534 [5][4]

0xE0C3 = 0x3736 [7][6]

Emodel

[57548][0xE0CC](). *Controller model flag.*

0 = TSMPPT-45, 1=TSMPPT-60

Ehw_version

[57549][0xE0CD](). *Hardware version.*

Not ASCII. Major version stored in upper byte, minor version stored in lower byte.

0xE0CD = 0x0102 → HW version: 1.2

Examples

Read Holding Register, Scaling a voltage value

Read and scale the following value:

Variable (RAM): Battery Voltage
 Register Address: 0x0018

The voltage scaling term is stored in variable V_PU at addresses 0x0000 and 0x0001.

Suppose the following values are read from RAM:

Address	Value(hex)	Variable Name
0x0000	0x007B	V_PU HI byte
0x0001	0xE041	V_PU LO byte
0x0018	0x0DB0	Battery Voltage value

1. Compute voltage scaler

Whole term = 0x007B → 123

Fractional term = 0xE041 / 2¹⁶ → 0.876

Voltage scaler = 123 + 0.876 = 123.876

Scaling for this variable is: $n * V_PU * 2^{-15}$ (as listed in the table of RAM variables)

2. Convert hexadecimal Vbattery register value to decimal

0x0DB0 → 3504

3. Scale Vbattery value

Vbattery = (3504 * 123.876) / 32768 = 13.25 Volts

Read Holding Register, 2 Word values

Variable (RAM): hours (hourmeter)

LO Register Address: 0x002A

HI Register Address: 0x002B

Scaling for this variable: none

1. read LO Register value(hex): 0x13D8
2. read HI Register value(hex): 0x0022
3. combine register values(hex): 0x002213D8
4. Convert to decimal: 2,233,304 hours

References

- Visit <http://www.modbus-ida.org/> for full protocol documentation, news, and technical resources
- MODBUS® Protocol Reference Guide, Modicon, June 1996, PI-MODBUS-300 Rev.J
- MODBUS® Application Protocol Specification, modbus.org, 8May02,
- Modbus_application_protocol_v1

Document Revision History

V01: First Release

V02: added EEPROM variable EV_soc_y_yr (0xE017) to variable list, shifted remaining variables

Added EEPROM variable serial number (0xE0C0)

Added EEPROM variable Ehdw_version (0xE0CD)

Specified some missing scaling values

V03: Reordered address space for RAM

Added RAM variable sw_ver (0x0005)

Added flags, PoutMax, TbMin, TbMax to daily logged values list

V04: Changed scaling values for RAM power supply voltages

Added Vb_ref_slave variable for modbus control of regulation

Changed scaling of daily Whr charge from 0.1 to 1 (no scaling)

Change to NetFlags (0x1517), 0x4000 turns on DHCP.

Modified the default network settings on front page. DHCP enabled by default.

Documented active network settings, netbios name, and ethernet power save mode register.

MACAddress bytes are READ-ONLY

V05: Added definitions for EEPROM values

V06: If DHCP fails, default IP is 192.168.1.253 – updated this info in Parameters section.

V07: Added va_ref_fixed RAM variable and definition (0x005A).

Added va_ref_fixed_pct RAM variable and definition (0x005B).

Added va_ref_fixed EEPROM variable and definition (0xE020).

Added va_ref_fixed_pct EEPROM variable and definition (0xE021).

Added EIb_lim EEPROM variable and definition (0xE01D).

Fixed the scaling in the *Examples* scaling section, step 1 – is now 2^{-15}

V08: Clarified 1-2 stop bits

Added signed data column

Added sw_ver BCD coding information

Added Vb_min/max coil reset command

Correct adc_v_ref scaling

kWhc resettable and total definitions were incorrectly documented.

V09: Added VLAN registers for Processor B v8.21 Beta

V10: Updated/corrected Fault bit field (0x002C), Slave timeout fault bit in incorrect location: bit10 -> bit11

V10.2 Corrected minor typos in array V scaling, used I_scaling value and wrong units.