

SCHEDULE OF TECHNICAL REQUIREMENTS: FIRE SPRINKLER SYSTEM

State Disaster Response and Fire Services

1. Scope:

Installation of automatic wet pipe fire sprinkler and fire hydrant protection system.

- Equipment: Pendant and upright quartzoid glass bulb automatic fire sprinklers
- Rated temperature: 68 deg C (Red bulb)
- Fire hydrant landing valves, 63 mm instantaneous female coupling
- Riser pipework: Heavy duty seamless steel fire water pipes
- Fire alarm check valve with water motor gong.