

Install an addressable fire alarm and clean-agent suppression system for a data hall: smoke detectors, aspirating detection, releasing panel, cylinders, distribution pipework, sounders and cause-effect programming. Include integrated cause-and-effect testing and authority inspection. A small jockey pump serves the adjacent fire-water header.