

Supply two standard pump sets for a plant utility service, 5 HP, 415 V, 50 Hz. Fluid, suction arrangement, well type, duty head and discharge are to be confirmed during detailed engineering.