

Calibration Of Low Cost Sensor

With the development of sensor technology for air pollution it has attracted a majority of researchers as well as common people to explore and understand more about the pollutants and its effects. This has given freedom for one to set up their own monitoring system at residences, office or even at schools. The problem with this is to identify how accurate the data collected from these commodity sensors to the reference monitoring system. If the system is giving values which is way too different from the reference value then it brings down the advantages of this technology. This issue can be dealt through calibration which will reduce the uncertainty in data and makes the output more accurate.

Calibration can be defined as the act of evaluating and adjusting the precision and accuracy of measurement equipment [4]. If the measured output from the sensor is not equals to the actual output then it shows that there is a need for calibration. Usually all the electronic instruments are calibrated according to a particular conditions in the laboratory and acquires a certification of calibration before its sold out in the markets. Even then the measured value does not reach accuracy as the condition or the environment where it was calibrated changes that leaves the user with some raw values that gives no information. This issue was taken up and explored by a few researchers in the US Environmental Protection Agency(EPA) and came up with three so called 'Straw-Man Approach' to improve the usability of such data and presented in the Air sensor Workshop [7].

The first approach was by a signal-based calibration technique which requires the data from the remote stations, which is the reference station, to be broadcasted to the local station where the sensor is located and will receive this data and performs a single point calibration of the response. This approach would have been easy if the sensor was already equipped with the data collection and would process automatic calibration.

The next option for calibrating is called the direct sensor calibration that involves placing the sensor in a chamber in which a known concentration of pollutant is set and response is observed. As the concentration of the pollutant is already known the output curve can be compared with it and calibrated accordingly. This is the most common method used for calibration as is often called as laboratory evaluation. Another way of approaching direct calibration is by inspecting the pre-defined response given by the manufacturer and checking how accurate the sensor is to the given concentration. In either case the calibration requires equipment and skills to give accurate concentration value.

The last option is by secondary data normalization in which the concentration values of the pollutant from the low cost sensor is normalized in accordance with the federal reference method (FRM) or federal equivalent method (FEM) analyzers. This approach is cost effective when compared to the other techniques and is less complex. This could be achieved by the use of a linear mathematical equation model that will convert the non-calibrated data into data of an acceptable form. The linear relationship equation $y = mx + c$ where m is the slope and c is the intercept of the sensor raw data is compared with analyzer data and a relationship pattern is found out from this. The drawback of this is that the sensor data does not always give a linear response and thus not applicable for all the curves.

Even though these 'Straw-Man Approach' was defined well it was still hard to implement it practically. This eventually led to the development of the 'Air Sensor Toolbox' by the Environmental Protection Agency (EPA) [6] which introduced a tool called 'Macro Anal-

ysis Tool' (MAT) for performing comparisons of air sensor data with reference data and interpreting the results [2].

Calibration Procedure

The Air Sensor Toolbox provide guidelines for researchers, citizen scientists and developers with working of low cost sensor and its calibration to give more insight about air quality [1]. The Air Sensor guidebook[2] provides a three step procedure for calibrating a sensor:

1. Comparing the data from the low cost sensor with a reference instrument.

This means the data collected from the sensor system should be compared with the data from an already calibrated system which is placed by the local authority. This type of comparison is called as 'collocation' and in order to collocate, first find out where the reference system is placed and get access to the data from these system. After getting access to these system place the sensor system at the same level as the standard reference. Once this is done the data collected from both the system can be downloaded in the desired format.

2. Creating a calibration curve with the help of Macro Analysis Tool (MAT).

The relationship between the response of an analytical instrument to the concentration or amount of an analyte introduced into a known instrument is referred to as the "calibration curve" [3]. The MAT tool by EPA is used for drawing the calibration curve and will give an error function as output. This error function is an equation which can be used for calibrating the sensor.

3. Repeating the calibration periodically.

This procedure of calibration should be done periodically as the performance of instruments changes often. There will be changes in the equation and graph each time and this should be noted so as to get accurate value.

Macro Analysis Tool -MAT

The development of MAT tool gives a huge reliefs for the researchers in calibrating sensor data. This is an Excel based user-friendly macro tool that compares sensor data with reference data [5]. The user needs to insert the data from the sensor into the sensor page of the tool and the values from the reference station is inserted into the reference page of the tool. After these values are inserted the details of pollutant, time interval, measurement units and data completeness (amount of usable data obtained) needs to be added in the set up page of the MAT. After all the required fields are filled the output page as shown in the figure 1 shows the two sets of data being compared as per the control panel setting made in the tool [5].




Figure 1: MAT Output

Bibliography

- [1] U.S. Environmental Protection Agency. Air Sensor Toolbox for Citizen Scientists, Researchers and Developers. <https://www.epa.gov/air-sensor-toolbox>, 2018. [Online; accessed 04-December-2018].
- [2] U.S. Environmental Protection Agency. Macro Analysis Tool -MAT. https://cfpub.epa.gov/si/si_public_record_report.cfm?dirEntryId=340520&Lab=NERL, 2018. [Online; accessed 04-December-2018].
- [3] Epa and Ord. Calibration Curves: Program Use/Needs Final. (October), 2010.
- [4] Davis) Kejuruteraan, Fakulti Tekn, NIST Engineering Statistics Handbook Jenny Wu (University of California and 3. Instrument Calibration. pages 1–7, 2018.
- [5] NERLORD National Exposure Research Laboratory Office of Research and Development. How to Evaluate Low-Cost Sensors by Collocation with Federal Reference Method Monitors. pages 1–45, 2017.
- [6] Ron Williams, Vasu J Kilaru, Emily G Snyder, Amanda Kaufman, Timothy Dye, Andrew Rutter, Ashley Russell, and Hilary Hafner. Air Sensor Guidebook. *Epa/600/R-14/159*, (1):1–5, 2014.
- [7] Ron Williams, Tim Watkins, and Russell Long. Low Cost Sensor Calibration Options The Straw-Man Approach. 2013.