


TMV Servicing & Disinfection to TMV Code of Practice								
Customer: Camphill Holywood								
Building: 1 Riverside								
Completed by: Callum Jeffrey				Date: 23/09/2020				
Location	TMV size MM	Asset No:	Clean & Descale Y/N	Did Failsafe Work Y/N	Cold Temp	Hot Temp	Blended Temp	Comments
Downstairs WC WHB	15	1	Y	Y	10	59	43	
Downstairs WC Shower	15	2	Y	-	11	59	38	
1st Floor Bathroom Bath	22	3	Y	Y	13	62	43	
1st Floor Bathroom WHB	15	4	Y	Y	12	63	41	
1st Floor Bathroom Shower	15	5	Y	-	12	61	40	
Hot Press	15	6	Y	Y	14	64	39	2no. Isolation valves required
Hot Press	22	7	Y	Y	15	65	41	
Daniel Bedroom WHB	15	8	Y	Y	12	61	40	2no. Isolation valves required
Daniel Bedroom Shower	15	9	Y	-	11	63	38	
Helen Barbara WHB	15	10	Y	Y	13	59	41	
Helen Barbara Shower	15	11	Y	-	12	61	39	
CWSC 1 CLEANED AND DISINFECTED								

~This Certificate should be added to the System Log Book~

